



Corporate Headquarters
 550 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

209032470

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PAPA Doug

Day: Tuesday Date: 3/17/2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave @ Garage pipe insulation Phase I

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|-----------------------------------|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 1 | | | | U | GARAGE inside work area Northside | 1730 | 1930 | 120 | 15 | 15 | 15 | 1800 | |
| 2 | | | | U | GARAGE inside work area Eastside | 1732 | 1932 | 120 | 15 | 15 | 15 | 1800 | |
| 3 | | | | U | GARAGE inside work area center | 1734 | 1934 | 120 | 15 | 15 | 15 | 1800 | |
| 4 | | | | U | GARAGE inside work area Southside | 1736 | 1936 | 120 | 15 | 15 | 15 | 1800 | |
| 5 | | | | U | GARAGE inside work area Westside | 1738 | 1938 | 120 | 15 | 15 | 15 | 1800 | |
| 6 | | | | | field blank | | | | | | | | |
| 7 | | | | | field blank | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: PAPA Doug

Received By: cbf

Turnaround Time: Immediate

Type of Analysis

Date: 3-17-09

Date: 3/17/09

Results To: _____

Asbestos Lead

Time: _____

Time: 2045

Fax: 516-932-3288

Air Bulk

Office: 516-932-3228

PCM Chip Wipe

Cell Phone #: _____

TEM TCLP A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |

Dalyee 3/17/9 21:05p



Corporate Headquarters
 550 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

209032601

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PHDA Drug

Day: Wednesday Date: 3/18/2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave Garage pipe installation

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|---|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 1 | | V | | | Garage, at the decon next to electrical panel | 1230 | 1630 | 240 | 6 | 6 | 6 | 1440 | |
| 2 | | V | | | Garage, end of ramp at the critical barrier | 1232 | 1631 | 239 | 6 | 6 | 6 | 1434 | |
| 3 | | V | | | Garage, next to personal elction | 1234 | 1632 | 238 | 6 | 6 | 6 | 1428 | |
| 4 | | V | | | Garage next to waste decon | 1236 | 1633 | 237 | 6 | 6 | 6 | 1422 | |
| 5 | | V | | | Garage next to E. Panel at the critical barrier | 1238 | 1634 | 236 | 6 | 6 | 6 | 1416 | |
| 6 | | | | | field blank | | | | | | | | |
| 7 | | | | | field blank | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: PHDA Drug Received By: R. HEWITT
 Date: 3-18-09 Date: 3/18/09
 Time: _____ Time: 1805

Turnaround Time: 24H
 Results To: _____
 Fax: 516-932-3288
 Office: 516-932-3228
 Cell Phone #: _____

Type of Analysis
 Asbestos Lead
 Air Bulk
 PCMP Chip Wipe
 TEM TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



Corporate Headquarters
 550 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

209032602

Air Sample Chain of Custody

CNS Job #: A281048

Technician: APPA Dwyer

Day: Wednesday Date: 3/18/2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave GARAGE pipe insulation

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|---|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 1 | | | U | | GARAGE next to Boiler room area | 1410 | 1525 | 75 | 10 | 10 | 10 | 750 | |
| 2 | | | U | | Inside personal closet | 1412 | 1526 | 74 | 10 | 10 | 10 | 740 | |
| 3 | | | V | | Outside building next to containers. | 1414 | 1527 | 73 | 10 | 10 | 10 | 730 | |
| 4 | | | | | field bank | | | | | | | | |
| 5 | | | | | field bank | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: APPA Dwyer Received By: A. Herpin
 Date: 3-18-09 Date: 3/18/09
 Time: _____ Time: 1805

Turnaround Time: 24H
 Results To: _____
 Fax: 516-932-3288
 Office: 516-932-3228
 Cell Phone #: _____

Type of Analysis
 Asbestos
 Lead
 Air
 PCM
 TEM
 Chip
 Wipe
 TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



Corporate Headquarters
550 West Old Country Road
Suite 308
Hicksville, New York 11801
Tel: (516) 932-3228
Fax: (516) 932-3288

209032753

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PAPA Incy

Day: Thursday Date: 3/19/2009

License #: 04-0537

Site: 4650 Broadway, Sherman Ave GARAGE pipe insulation

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|---|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 8 | | ✓ | | | GARAGE, at the decon next to electrical panel | 0750 | 1230 | 230 | 6 | 6 | 6 | 1680 | |
| 9 | | ✓ | | | GARAGE, end of ramp next to critical barrier | 0752 | 1231 | 279 | 6 | 6 | 6 | 1674 | |
| 10 | | ✓ | | | Garage, next to Personnel decon | 0759 | 1232 | 272 | 6 | 6 | 6 | 1668 | |
| 11 | | ✓ | | | Garage, next to waste decon | 0756 | 1233 | 277 | 6 | 6 | 6 | 1662 | |
| 12 | | ✓ | | | Garage, at the critical barrier next to Panel Box | 0758 | 1234 | 276 | 6 | 6 | 6 | 1656 | |
| 13 | | ✓ | | | Garage, at the decon next to electrical panel | 1230 | 1630 | 240 | 6 | 6 | 6 | 1440 | |
| 14 | | ✓ | | | Garage, end of ramp next to critical barrier | 1231 | 1631 | 240 | 6 | 6 | 6 | 1440 | |
| 15 | | ✓ | | | Garage, next to Personnel decon | 1232 | 1632 | 240 | 6 | 6 | 6 | 1440 | |
| 16 | | ✓ | | | Garage, next to waste decon | 1233 | 1633 | 240 | 6 | 6 | 6 | 1440 | |
| 17 | | ✓ | | | GARAGE, at the critical barrier next to Panel Box | 1234 | 1634 | 240 | 6 | 6 | 6 | 1440 | |

Sent By: PAPA Incy Received By: [Signature]
Date: 3-19-09 Date: 3/19/09
Time: _____ Time: 1815

Turnaround Time: 24H
Results To: _____
Fax: 516-932-3288
Office: 516-932-3228
Cell Phone #: _____

Type of Analysis
 Asbestos Lead
 Air Bulk
 PCM Chip Wipe
 TEM TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



Corporate Headquarters
 350 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

209032865

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PRVA Day

Day: Friday Date: 3/20/2009

License #: 24-05317

Site: 4650 Broadway, Sherman Ave PIPELINE pipe insulation

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|--|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 20 | | ✓ | | | PIPELINE, at the clean next to Permit Box | 0756 | 1200 | 244 | 6 | 6 | 6 | 1464 | |
| 21 | | ✓ | | | GARAGE, end of ramp at the critical barrier | 0758 | 1201 | 243 | 6 | 6 | 6 | 1458 | |
| 22 | | ✓ | | | PIPELINE next to Personnel clean | 0800 | 1202 | 242 | 6 | 6 | 6 | 1452 | |
| 23 | | ✓ | | | PIPELINE next to waste clean | 0802 | 1203 | 241 | 6 | 6 | 6 | 1446 | |
| 24 | | ✓ | | | PIPELINE, at the critical barrier next to Box Panel | 0804 | 1204 | 240 | 6 | 6 | 6 | 1440 | |
| 25 | | ✓ | | | GARAGE, at the clean next to Permit Box | 1200 | 1605 | 245 | 6 | 6 | 6 | 1470 | |
| 26 | | ✓ | | | GARAGE, end of ramp at the critical barrier | 1201 | 1606 | 245 | 6 | 6 | 6 | 1470 | |
| 27 | | ✓ | | | PIPELINE, next to Personnel clean | 1202 | 1607 | 245 | 6 | 6 | 6 | 1470 | |
| 28 | | ✓ | | | PIPELINE, next to waste clean | 1203 | 1608 | 245 | 6 | 6 | 6 | 1470 | |
| 29 | | ✓ | | | PIPELINE, at the critical barrier next to Permit Box | 1204 | 1609 | 245 | 6 | 6 | 6 | 1470 | |

Sent By: PRVA Day Received By: A. [Signature]
 Date: 3/20/09 Date: 3/20/09
 Time: _____ Time: 1757

Turnaround Time: 24H
 Results To: _____
 Fax: 316-932-3288
 Office: 516-932-3228
 Cell Phone #: _____

Type of Analysis
 Asbestos Lead
 Air Bulk
 PCM Chip Wipe
 TEM TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



Corporate Headquarters
 550 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3226
 Fax: (516) 932-3288

209033126

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PAPA MARY

Day: Monday Date: 3 | 23 | 2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave CAFENCE pipe insulation

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|--|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 32 | | | V | | CAFENCE, end of ramp at the critical barrier | 0755 | 1215 | 260 | 6 | 6 | 6 | 1560 | |
| 33 | | | V | | inside personnel clean | 0757 | 1216 | 259 | 6 | 6 | 6 | 1554 | |
| 34 | | | V | | inside waste clean | 0759 | 1217 | 258 | 6 | 6 | 6 | 1548 | |
| 35 | | | V | | outside, opposite personnel clean | 0801 | 1218 | 257 | 6 | 6 | 6 | 1542 | |
| 36 | | | V | | CAFENCE, at the critical barrier next to E-Panel | 0803 | 1219 | 256 | 6 | 6 | 6 | 1536 | |
| 37 | | | V | | outside hushing at the barrier, exhaust | 0805 | 1220 | 255 | 6 | 6 | 6 | 1530 | |
| 38 | | | V | | CAFENCE, end of ramp at the critical barrier | 1215 | 1615 | 240 | 6 | 6 | 6 | 1440 | |
| 39 | | | V | | inside, personnel clean | 1216 | 1616 | 240 | 6 | 6 | 6 | 1440 | |
| 40 | | | V | | inside waste clean | 1217 | 1617 | 240 | 6 | 6 | 6 | 1440 | |
| 41 | | | V | | outside, opposite personnel clean | 1218 | 1618 | 240 | 6 | 6 | 6 | 1440 | |

Sent By: PAPA MARY Received By: L. BERMAN
 Date: 3-23-09 Date: 3/23/09
 Time: _____ Time: 1835

Turnaround Time: 24H
 Results To: _____
 Fax: 516-932-3288
 Office: 516-932-3228
 Cell Phone #: _____

Type of Analysis:
 Asbestos
 Lead
 Air
 PCM
 TEM
 Chip Wipe
 TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



Corporate Headquarters
 550 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PPPA Droy

Day: Monday Date: 3 12 2009

License #: 04-03317

Site: 4650 Broadway, Sherman Ave BRIDGE, pipe insulation

| Sample ID# | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|------------|-------------|-------------|-------------|-------------|-------------------------|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 42 | | | ✓ | | BRIDGE, at the critical | 1219 | 1619 | 240 | 6 | 6 | 6 | 1440 | |
| 43 | | | ✓ | | because next to E-panel | 1220 | 1620 | 240 | 6 | 6 | 6 | 1440 | |
| 44 | | | | | outside building at | | | | | | | | |
| 45 | | | | | the negative pressure | | | | | | | | |
| | | | | | field blank | | | | | | | | |
| | | | | | fold blank | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: PPPA Droy Received By: L. [Signature]
 Date: 3-23-09 Date: 3/23/09
 Time: _____ Time: 1835

Turnaround Time: 24H Type of Analysis:
 Results To: _____ Asbestos Lead
 Fax: 516-932-3288 Air Bulk
 Office: 516-932-3228 PCM Chip
 Cell Phone #: _____ TEM Wipe
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



209033127

Corporate Headquarters
 550 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

Air Sample Chain of Custody

CNS Job #: A281048

Technician: Paxa Drop

Day: Monday Date: 3/23/2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave Roof

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|------------------------------|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 1 | | | ✓ | | inside roof Northside LWA | 1430 | 1545 | 75 | 10 | 10 | 10 | 750 | |
| 2 | | | ✓ | | inside roof center LWA | 1432 | 1546 | 74 | 10 | 10 | 10 | 740 | |
| 3 | | | ✓ | | inside roof southside LWA | 1434 | 1547 | 93 | 10 | 10 | 10 | 730 | |
| 4 | | | | | field blank | | | | | | | | |
| 5 | | | | | field blank | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: Paxa Drop Received By: A. Kean
 Date: 3-23-09 Date: 3/23/09
 Time: _____ Time: 1835

Turnaround Time: 244
 Results To: _____
 Fax: 516-932-3288
 Office: 516-932-3228
 Cell Phone #: _____

Type of Analysis
 Asbestos Lead
 Air Bulk
 PCM Chip Wipe
 TEM TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



Corporate Headquarters
 550 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PAPA MARY

Day: Tuesday Date: 3/24/2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave CHFACE pipe insulation

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|---|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 32 | | | ✓ | | CHFACE, end of ramp at the critical barrier | 0158 | 1210 | 252 | 6 | 6 | 6 | 1512 | |
| 33 | | | ✓ | | Inside personnel clean | 0202 | 1211 | 251 | 6 | 6 | 6 | 1506 | |
| 34 | | | ✓ | | Inside waste clean | 0202 | 1212 | 250 | 6 | 6 | 6 | 1500 | |
| 35 | | | ✓ | | CHFACE, opposite personnel clean | 0204 | 1213 | 249 | 6 | 6 | 6 | 1494 | |
| 36 | | | ✓ | | CHFACE, at the critical barrier next to E Plant | 0206 | 1214 | 248 | 6 | 6 | 6 | 1488 | |
| 37 | | | ✓ | | Subside building at the negative containment | 0208 | 1215 | 247 | 6 | 6 | 6 | 1482 | |
| 38 | | | ✓ | | CHFACE, end of ramp at the critical barrier | 1210 | 1615 | 245 | 6 | 6 | 6 | 1470 | |
| 39 | | | ✓ | | Inside personnel clean | 1211 | 1616 | 245 | 6 | 6 | 6 | 1470 | |
| 40 | | | ✓ | | Inside waste clean | 1212 | 1617 | 245 | 6 | 6 | 6 | 1470 | |
| 41 | | | ✓ | | CHFACE, opposite personnel clean | 1213 | 1618 | 245 | 6 | 6 | 6 | 1470 | |

Sent By: PAPA MARY Received By: [Signature]
 Date: 3-24-09 Date: 3/24/09
 Time: _____ Time: 1743

Turnaround Time: 24H
 Results To: _____
 Fax: 516-932-3288
 Office: 516-932-3228
 Cell Phone #: _____

Type of Analysis
 Asbestos Lead
 Air Bulk
 PCM Chip Wipe
 TEM TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |

209033232



Corporate Headquarters
 550 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PADA Proj

Day: Tuesday Date: 3 | 24 2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave Garage pipe insulation

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|--|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 42 | | | V | | Garage, at the critical barrier next to E panel | 1214 | 1619 | 245 | 6 | 6 | 6 | 1470 | |
| 43 | | | V | | outside building at the negative extreme fuel island | 1215 | 1620 | 245 | 6 | 6 | 6 | 1470 | |
| 44 | | | | | fuel island | | | | | | | | |
| 45 | | | | | fuel island | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: PADA Proj Received By: [Signature]
 Date: 3-24-09 Date: 3/24/09
 Time: _____ Time: 17:15

Turnaround Time: 24 H Type of Analysis
 Results To: _____ Asbestos Lead
 Fax: 516-932-3288 Air Bulk
 Office: 516-932-3228 PCM Chip Wipe
 Cell Phone #: _____ TEM TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



209033363 Corporate Headquarters
 100 Old Country Road
 Suite 309
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PHAM DUONG

Day: Wednesday Date: 3/25/2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave

Garage pipe insulation

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|--|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 46 | | | ✓ | | Garage, end of ramp at the critical barrier | 0758 | 1230 | 272 | 6 | 6 | 6 | 1632 | |
| 49 | | | ✓ | | Inside personnel clean | 0800 | 1231 | 271 | 6 | 6 | 6 | 1626 | |
| 48 | | | ✓ | | Inside waste clean | 0802 | 1232 | 270 | 6 | 6 | 6 | 1620 | |
| 49 | | | ✓ | | Garage, opposite personnel clean | 0804 | 1233 | 269 | 6 | 6 | 6 | 1614 | |
| 50 | | | ✓ | | Garage, at the critical barrier next to E. Panel | 0806 | 1234 | 268 | 6 | 6 | 6 | 1608 | |
| 51 | | | ✓ | | outside building at the negative air exhaust | 0808 | 1235 | 267 | 6 | 6 | 6 | 1602 | |
| 52 | | | ✓ | | Garage, end of ramp at the critical barrier | 1230 | 1608 | 218 | 6 | 6 | 6 | 1308 | |
| 53 | | | ✓ | | Inside personnel clean | 1231 | 1609 | 218 | 6 | 6 | 6 | 1308 | |
| 54 | | | ✓ | | Inside waste clean | 1232 | 1610 | 218 | 6 | 6 | 6 | 1308 | |
| 55 | | | ✓ | | Garage, opposite personnel clean | 1233 | 1611 | 218 | 6 | 6 | 6 | 1308 | |

Sent By: Pham Duong Received By: [Signature]

Date: 3-25-09 Date: 3/25/09

Time: _____ Time: 2013

Turnaround Time: 24H

Results To: _____ Type of Analysis: Asbestos Lead

Fax: 516-932-3288 Air Bulk

Office: 516-932-3228 PCM Chip Wipe

Cell Phone #: _____ TEM TCLP A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



20903325
 Headquarters
 2500 Country Road
 Suite 300
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

Air Sample Chain of Custody

CNS Job #: A281048

Technician: HAPA Dwyer

Day: Wednesday Date: 3/25/2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave Garage pipe insulation

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|--|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 50 | | | U | | Garage, at the critical location next to E. panel | 1234 | 1612 | 218 | 6 | 6 | 6 | 1308 | |
| 57 | | | U | | outside building at the negative side exhaust field down | 1235 | 1613 | 218 | 6 | 6 | 6 | 1308 | |
| 58 | | | | | field down | | | | | | | | |
| 59 | | | | | field down | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: HAPA Dwyer Received By: Lind
 Date: 3-25-09 Date: 3/25/09
 Time: _____ Time: 2013

Turnaround Time: 24H
 Results To: _____
 Fax: 516-932-3288
 Office: 516-932-3228
 Cell Phone #: _____

Type of Analysis
 Asbestos Lead
 Air Bulk
 PCM Chip
 TEM Wipe
 TCLP A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



209033366

Corporate Headquarters
550 West Old Country Road
Suite 308
Hicksville, New York 11801
Tel: (516) 932-3228
Fax: (516) 932-3288

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PARA Dig

Day: Wednesday Date: 3/25/2009

License #: 04-0537

Site: 4650 Broadway, Sherman Ave GARAGE pipe insulation Phase II

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|--------------------------------------|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 1 | | | | ✓ | GARAGE, inside work area EAST side | 1735 | 1935 | 120 | 15 | 15 | 15 | 1800 | |
| 2 | | | | ✓ | GARAGE, inside work area, west side | 1737 | 1937 | 120 | 15 | 15 | 15 | 1800 | |
| 3 | | | | ✓ | GARAGE, inside work area center | 1739 | 1939 | 120 | 15 | 15 | 15 | 1800 | |
| 4 | | | | ✓ | GARAGE, inside work area, south side | 1741 | 1941 | 120 | 15 | 15 | 15 | 1800 | |
| 5 | | | | ✓ | GARAGE inside work area, north side | 1743 | 1943 | 120 | 15 | 15 | 15 | 1800 | |
| 6 | | | | | field blank | | | | | | | | |
| 7 | | | | | field blank | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: PARA Dig Received By: [Signature]
 Date: 3-25-09 Date: 3/25/09
 Time: _____ Time: 2043

Turnaround Time: immediate
 Results To: _____
 Fax: 516-932-3288
 Office: 516-932-3228
 Cell Phone #: _____

Type of Analysis
 Asbestos Lead
 Air Bulk
 PCM Chip Wipe
 TEM TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



Corporata Headquarters
 550 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

209033475

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PAPA Muf

Day: Thursday Date: 3/26/2009

License #: Oh-05317

Site: 4650 Broadway, Sherman Ave GARAGE pipe insulation

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|-------------------------------------|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 1 | | | ✓ | | GARAGE, next to holding area room | 1230 | 1335 | 65 | 10 | 10 | 10 | 650 | |
| 2 | | | ✓ | | GARAGE, end of ramp. | 1232 | 1336 | 64 | 10 | 10 | 10 | 640 | |
| 3 | | | ✓ | | outside building next to containers | 1234 | 1337 | 63 | 10 | 10 | 10 | 630 | |
| 4 | | | | | field blank | | | | | | | | |
| 5 | | | | | field blank | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: PAPA Muf Received By: Leona [Signature]
 Date: 3-26-09 Date: 3/26/09
 Time: _____ Time: 1710

Turnaround Time: 24H
 Results To: _____
 Fax: 516-932-3288
 Office: 516-932-3228
 Cell Phone #: _____
 Type of Analysis:
 Asbestos Lead
 Air Bulk
 PCB Chip
 TEM Wipe
 A.A. TCLP

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |

209033475 3/26/09 18:15 p



Corporate Headquarters
550 West Old Country Road
Suite 306
Hicksville, New York 11801
Tel: (516) 932-3288
Fax: (516) 932-3288

Air Sample Chain of Custody

209041135

CNS Job #: A281048

Technician: PAPA Drog

Day: Wednesday Date: 04/2 2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave

Roof - cooling tower.

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|-----------------------------|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 1 | | | ✓ | | Inside personnel decon OA | 0800 | 1200 | 240 | 6 | 6 | 6 | 1440 | |
| 2 | | | ✓ | | Inside waste decon OA | 0802 | 1201 | 239 | 6 | 6 | 6 | 1434 | |
| 3 | | | ✓ | | IA, next to personnel decon | 0805 | 1202 | 237 | 6 | 6 | 6 | 1422 | |
| 4 | | | ✓ | | IA, next to waste decon. | 0807 | 1203 | 236 | 6 | 6 | 6 | 1416 | |
| 5 | | | ✓ | | IA, opposite cooling tower | 0809 | 1204 | 235 | 6 | 6 | 6 | 1410 | |
| 6 | | | ✓ | | IA, next to microtrap | 0811 | 1205 | 234 | 6 | 6 | 6 | 1404 | |
| 7 | | | ✓ | | IA, between cooling tower. | 0813 | 1206 | 233 | 6 | 6 | 6 | 1398 | |
| 8 | | | ✓ | | Inside personnel decon | 1200 | 1610 | 250 | 6 | 6 | 6 | 1500 | |
| 9 | | | ✓ | | Inside waste decon | 1201 | 1611 | 250 | 6 | 6 | 6 | 1500 | |
| 10 | | | ✓ | | IA, next to personnel decon | 1202 | 1612 | 250 | 6 | 6 | 6 | 1500 | |

Sent By: PAPA Drog Received By: Lind
Date: 4-1-09 Date: 4/1/09
Time: _____ Time: 2033

Turnaround Time: 24H
Results To: _____
Fax: 516-932-3288
Office: 516-932-3228
Cell Phone #: _____

Type of Analysis
 Asbestos Lead
 Air Bulk
 PCM Chip Wipe
 TEM TCLP
A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |



Corporate Headquarters
 550 West Old Country Road
 Suite 308
 Hicksville, New York 11801
 Tel: (516) 932-3228
 Fax: (516) 932-3288

209041135

Air Sample Chain of Custody

CNS Job #: A281048

Technician: Pratt May

Day: Wednesday Date: 4/1/2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave Roof cooling tower

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|----------------------------|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 11 | | | U | | IA, next to waste decon. | 1203 | 1613 | 250 | 6 | 6 | 6 | 1500 | |
| 12 | | | U | | IA, opposite cooling tower | 1204 | 1614 | 250 | 6 | 6 | 6 | 1500 | |
| 13 | | | U | | IA, next to microwave | 1205 | 1615 | 250 | 6 | 6 | 6 | 1500 | |
| 14 | | | U | | IA, between cooling towers | 1206 | 1616 | 250 | 6 | 6 | 6 | 1500 | |
| 15 | | | | | field blank | | | | | | | | |
| 16 | | | | | field blank | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: Pratt May Received By: [Signature]
 Date: 4-1-09 Date: 4/1/09
 Time: _____ Time: 2033

Turnaround Time: 24H
 Results To: _____
 Fax: 516-932-3288
 Office: 516-932-3228
 Cell Phone #: _____

Type of Analysis
 Asbestos
 Lead
 Air
 PCM
 Bulk
 Chip
 Wipe
 TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |

209041127



Corporate Headquarters
550 West Old Country Road
Suite 308
Hicksville, New York 11801
Tel: (516) 932-3228
Fax: (516) 932-3288

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PAPA Prof

Day: Wednesday Date: 4/1/2009

License #: 04-05317

Site: 4650 Broadway, Sherman Ave cooling tower

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|--------------------------------------|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 1 | | | | ✓ | IA, Northwest of work area | 1730 | 1930 | 120 | 15 | 15 | 15 | 1800 | |
| 2 | | | | ✓ | IA Northwest of work area | 1732 | 1932 | 120 | 15 | 15 | 15 | 1800 | |
| 3 | | | | ✓ | IA, next to minotom | 1734 | 1934 | 120 | 15 | 15 | 15 | 1800 | |
| 4 | | | | ✓ | IA between cooling tower | 1736 | 1936 | 120 | 15 | 15 | 15 | 1800 | |
| 5 | | | | ✓ | IA Southeast corner of the work area | 1738 | 1938 | 120 | 15 | 15 | 15 | 1800 | |
| 6 | | | | | field blank | | | | | | | | |
| 7 | | | | | field blank | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: PAPA Prof Received By: Levi
Date: 4-1-09 Date: 4/1/09
Time: _____ Time: 2053

Turnaround Time: immediate Type of Analysis
Results To: _____ Asbestos Lead
Fax: 516-932-3288 Air Bulk
Office: 516-932-3228 PCMT Chip Wipe
Cell Phone #: _____ TEM TCLP
A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Tent |
| OB - Outside Building | |

24 byee 4/1/9 20:46p



209041233

Corporate Headquarters
550 West Old Country Road
Suite 308
Hicksville, New York 11801
Tel: (516) 932-3228
Fax: (516) 932-3288

Air Sample Chain of Custody

CNS Job #: A281048

Technician: PAPA MARY

Day: Thursday Date: 4/2/2009

License #: OK-05717

Site: 4650 Broadway, Sherman Ave Roof cooling towers

| Sample ID # | B K G | P R P | D U R | C L R | Sample Location | Time Start | Time End | Total Minutes | Flow Rate Start | Flow Rate End | Flow Rate Avg. | Total Liters | Results |
|-------------|-------------|-------------|-------------|-------------|------------------------------------|------------|----------|---------------|-----------------|---------------|----------------|--------------|---------|
| 1 | | | U | | 2nd fl. next to welding area room | 1230 | 1438 | 128 | 6 | 6 | 6 | 768 | |
| 2 | | | U | | 4th fl. end of stairwell | 1232 | 1439 | 127 | 6 | 6 | 6 | 762 | |
| 3 | | | U | | outside building next to container | 1234 | 1440 | 126 | 6 | 6 | 6 | 756 | |
| 4 | | | | | field blank | | | | | | | | |
| 5 | | | | | field blank | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Sent By: PAPA MARY Received By: [Signature]
Date: 4-2-09 Date: 4/2
Time: _____ Time: 1650

Turnaround Time: 24H
Results To: _____
Fax: 516-932-3288
Office: 516-932-3228
Cell Phone #: _____
Type of Analysis:
 Asbestos
 Lead
 Air
 PCM
 TEM
 Bulk
 Chip
 Wipe
 TCLP
 A.A.

| SAMPLE CODES | SAMPLE CODES |
|---------------------------|-----------------------------|
| IA - Inside Work Area | OSHA - Personnel Monitoring |
| OA - Outside Work Area | FC - Full Containment |
| HEPA - Micro-trap Exhaust | GB - Glovebag |
| DE - Decon Clean Room | TNT - Test |
| OB - Outside Building | |

Postage 4/2/09 18:48p

April 28, 2008

CNS Management Corporation
Attn: Charles Powers
560 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208044722
P.O. #A281048
A281048; Sherman Plaza; 4660 Broadway - 2nd Floor (Background)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Monday, April 28, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13

The 13 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cm³ of fiber area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,



Marvin E. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results
 A281048, Sherman Plaza, 4050 Broadway - 2nd Floor (Background)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (liters) | Folds | Fibers | Fiber Density (Fibers/cm ²) | Fibers Core (Fibers/cm ²) | TWA |
|--|-----------------|----------------|------------------------|----------------|-----------------------|-------|--------|---|---------------------------------------|-------|
| 01 | 01 | 04/23/08 | 20 | 100 | 1000 | 100 | 4 | 3.31 | 0.000 | 0.000 |
| Location: 1A Northwest Corner, 2nd Floor | | | | | | | | | | |
| 02 | 02 | 04/23/08 | 10 | 100 | 1000 | 100 | 16 | 22.53 | 0.007 | 0.007 |
| Location: 1A Southwest Corner, 2nd Floor | | | | | | | | | | |
| 03 | 03 | 04/23/08 | 10 | 100 | 1000 | 400 | 25 | 26.00 | 0.000 | 0.000 |
| Location: 1A Center, 2nd Floor | | | | | | | | | | |
| 04 | 04 | 04/23/08 | 10 | 100 | 1000 | 100 | 14 | 20.38 | 0.007 | 0.007 |
| Location: 1A East Inside Work Area | | | | | | | | | | |
| 05 | 05 | 04/23/08 | 10 | 100 | 1000 | 400 | 20 | 25.48 | 0.000 | 0.000 |
| Location: 1A Southwest Corner, 2nd Floor | | | | | | | | | | |
| 06 | 06 | 04/23/08 | 10 | 100 | 1000 | 100 | 16 | 18.11 | 0.000 | 0.000 |
| Location: 08 North Outside Building, 2nd Floor | | | | | | | | | | |
| 07 | 07 | 04/23/08 | 10 | 100 | 1000 | 400 | 8 | 8.35 | 0.002 | 0.002 |
| Location: 04 Highway By Elevator | | | | | | | | | | |
| 08 | 08 | 04/23/08 | 10 | 100 | 1000 | 100 | 28 | 26.87 | 0.011 | 0.011 |
| Location: 0A Entrance To Work Area | | | | | | | | | | |
| 09 | 09 | 04/23/08 | 20 | 100 | 1000 | 100 | 10 | 12.74 | 0.004 | 0.004 |
| Location: 0A South Of Work Area | | | | | | | | | | |
| 10 | 10 | 04/23/08 | 10 | 100 | 1000 | 100 | 16 | 24.28 | 0.008 | 0.008 |
| Location: 0A Top Of Stairway, 2nd Floor | | | | | | | | | | |
| 11 | 11 | 04/23/08 | 20 | 100 | 1000 | 100 | 8 | 3.82 | 0.000 | 0.000 |
| Location: 0A Northwest Of Work Area, 2nd Floor | | | | | | | | | | |



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-6000 • FAX: (212) 679-0292

April 28, 2008

CNS Management Corporation
Attn: Charles Fowers
850 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208044719
P.O. #A281048
A281048, Sherman Plaza, #600 Smartway - 2nd Floor (Prop)

Dear Charles Fowers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Monday, April 28, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14

The 14 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cc mm of fiber area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci verifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates the opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
PCM Manager

1-487

Phase Contrast Microscopy (PCM) Fiber Results
 AGS1048, Sherman Plaza, 4850 Broadway - 2nd Floor (Print)

| Analysis Sample # | Client Sample # | Date Collected | Flow Rate (m/min) | Duration (min) | Air Filtrate (lbm) | Folds | Fibers | Fiber Density (Fibers/mm ²) | Fiber Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|-------------------|----------------|--------------------|-------|--------|---|-------------------------|-----|
| 01 | 01 | 04/23/08 | 3.5 | 282 | 1441 | 100 | 13 | 13.78 | 0.004 | |
| Location: Personal Service Desk North | | | | | | | | | | |
| 02 | 02 | 04/23/08 | 3.5 | 288 | 1419 | 100 | 28 | 31.85 | 0.009 | |
| Location: 1A Northwest Corner, 2nd Floor | | | | | | | | | | |
| 03 | 03 | 04/23/08 | 3.5 | 284 | 1387 | 100 | 2 | 2.82 | 0.000 | |
| Location: 1A Southwest Corner, 2nd Floor | | | | | | | | | | |
| 04 | 04 | 04/23/08 | 3.5 | 290 | 1371 | 100 | 14 | 20.88 | 0.006 | |
| Location: 1A Central West Area, 2nd Floor | | | | | | | | | | |
| 05 | 05 | 04/23/08 | 3.5 | 299 | 1353 | 100 | 10 | 12.74 | 0.004 | |
| Location: 1A Northwest Corner, 2nd Floor | | | | | | | | | | |
| 06 | 06 | 04/23/08 | 3.5 | 262 | 1331 | 100 | 4 | 5.10 | 0.001 | |
| Location: 1A Southwest Corner, 2nd Floor | | | | | | | | | | |
| 07 | 07 | 04/23/08 | 3.5 | 298 | 1328 | 100 | 16.5 | 13.58 | 0.004 | |
| Location: 08 Central West Area, 2nd Floor of Building | | | | | | | | | | |
| 08 | 08 | 04/23/08 | 3.5 | 274 | 1287 | 100 | 4 | 5.18 | 0.001 | |
| Location: 0A Highway South, 2nd Floor | | | | | | | | | | |
| 09 | 09 | 04/23/08 | 3.5 | 276 | 1268 | 100 | 7 | 8.82 | 0.002 | |
| Location: 0A NE Front Desk Entrance | | | | | | | | | | |
| 10 | 10 | 04/23/08 | 3.5 | 285 | 1241 | 100 | 3 | 3.82 | 0.000 | |
| Location: 0A Entrance To West Area | | | | | | | | | | |
| 11 | 11 | 04/23/08 | 3.5 | 322 | 1221 | 100 | 1.8 | 1.81 | 0.000 | |
| Location: 0A Highway West, 2nd Floor | | | | | | | | | | |



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10018

TEL: (212) 879-8600 • FAX: (212) 879-8332

May 7, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208044552
P.O. 84281048
A281048, Sherman Plaza, 4650 Broadway, 2nd Floor, Dusing-Free (Report Amended 5/7/2008)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Tuesday, April 29, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15

The 15 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "X" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cc mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is provided and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothman
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results

AJH154E: Sherman Plaza, 4850 Broadway, 2nd Floor, Durning/Prop (Report Amended 5/7/2008)

| AmarSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (Hours) | Fields | Fibers | Fiber Density (Fibers/cm ²) | Fiber Count (Fibers/ft) | TWA |
|---|-----------------|----------------|-------------------------|-----------------|----------------------|--------|--------|---|-------------------------|-----|
| 01 | 01 | 04/23/08 | 1.1 | 304 | 2112 | 100 | 11 | 11.28 | 1,000 | |
| Location: Terminal D / Con Clean Room | | | | | | | | | | |
| 02 | 02 | 04/23/08 | 1.1 | 300 | 2095 | 100 | 8 | 3.58 | <0.001 | |
| Location: 1A South - West Corner 2nd Floor | | | | | | | | | | |
| 03 | 03 | 04/23/08 | 1.1 | 310 | 3008 | 100 | 8 | 3.17 | <0.001 | |
| Location: 1A North - West Corner 2nd Floor | | | | | | | | | | |
| 04 | 04 | 04/23/08 | 1.1 | 312 | 3048 | 100 | 8 | 3.82 | <0.001 | |
| Location: 1A Center 2nd Floor | | | | | | | | | | |
| 05 | 05 | 04/23/08 | 1.1 | 308 | 3028 | 100 | 13 | 3.18 | <0.001 | |
| Location: 1A North - East Corner 2nd Floor | | | | | | | | | | |
| 06 | 06 | 04/23/08 | 1.1 | 304 | 3000 | 100 | 3 | 1.82 | <0.001 | |
| Location: 1A South - East Corner 2nd Floor | | | | | | | | | | |
| 07 | 07 | 04/23/08 | 1.1 | 300 | 1800 | 100 | 8 | 3.28 | <0.001 | |
| Location: 1B North Outside Building 2nd Floor | | | | | | | | | | |
| 08 | 08 | 04/23/08 | 1.1 | 300 | 1800 | 100 | 8 | 3.28 | <0.001 | |
| Location: 1A Highway South - West | | | | | | | | | | |
| 09 | 09 | 04/23/08 | 1.1 | 300 | 1800 | 100 | 8 | 3.28 | <0.001 | |
| Location: 1A Highway South - West | | | | | | | | | | |
| 10 | 10 | 04/23/08 | 1.1 | 300 | 1800 | 100 | 2.5 | 3.18 | <0.001 | |
| Location: 1A Top Stairway 2nd Floor | | | | | | | | | | |
| 11 | 11 | 04/23/08 | 1.1 | 300 | 1800 | 100 | 3 | 3.82 | <0.001 | |
| Location: 1A 101 Firm Dr Con Ent East | | | | | | | | | | |
| 12 | 12 | 04/23/08 | 1.1 | 310 | 1800 | 100 | 3 | 3.82 | <0.001 | |
| Location: 1A 101 Firm Dr Con Ent East | | | | | | | | | | |

April 30, 2008

CNS Management Corporation
Attn: Charles Powers
500 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208044851
P.O. #A281048
A281048, Sherman Plaza, 4650 Broadway, 2nd Floor, Prep

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Tuesday, April 29, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15

The 15 samples contained in Air Cassettes were shipped to AmeriSci via Hand-Delivered. These samples were prepared according to PCM methodology as specified in MCHH Method 7400, Issue #2, 8/15/04. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cc mm of fiber area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates the opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,



Marvin E. Rodgers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results

A231046, Sherman Plaza, 4550 Broadway, 2nd Floor, Prop

| Amesol Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | As Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fiber Conc. (Fibers/cc) | TWA |
|--|-----------------|----------------|------------------------|----------------|----------------------|--------|--------|---|-------------------------|-----|
| 01 | 01 | 04/27/08 | 0 | 240 | 1000 | 100 | 3.5 | 4.48 | <0.001 | |
| Location: Personnel Room Clean Room | | | | | | | | | | |
| 02 | 02 | 04/27/08 | 0 | 240 | 1000 | 100 | 0 | 0.18 | 0.002 | |
| Location: 1A South - West Corner 2nd Floor | | | | | | | | | | |
| 03 | 03 | 04/27/08 | 0 | 240 | 1000 | 100 | 0.6 | 44.88 | 0.003 | |
| Location: 1A North - West Corner 2nd Floor | | | | | | | | | | |
| 04 | 04 | 04/27/08 | 0 | 240 | 1000 | 100 | 4 | 0.32 | <0.001 | |
| Location: 1A Corner 2nd Floor | | | | | | | | | | |
| 05 | 05 | 04/27/08 | 0 | 240 | 1000 | 100 | 7 | 0.50 | 0.003 | |
| Location: 1A North - East Corner 2nd Floor | | | | | | | | | | |
| 06 | 06 | 04/27/08 | 0 | 240 | 1000 | 100 | 3 | 3.82 | <0.001 | |
| Location: 1A South - East Corner 2nd Floor | | | | | | | | | | |
| 07 | 07 | 04/27/08 | 0 | 240 | 1000 | 100 | 2 | 2.59 | <0.001 | |
| Location: 0B North Corridor Restroom | | | | | | | | | | |
| 08 | 08 | 04/27/08 | 0 | 240 | 1000 | 100 | 2.5 | 3.18 | <0.001 | |
| Location: 0A Hallway South West | | | | | | | | | | |
| 09 | 09 | 04/27/08 | 0 | 240 | 1000 | 100 | 2 | 2.05 | <0.001 | |
| Location: 0A Hallway North West | | | | | | | | | | |
| 10 | 10 | 04/27/08 | 0 | 238 | 1013 | 100 | 3 | 3.00 | <0.001 | |
| Location: 0A Top Of Elevator Way 2nd Floor | | | | | | | | | | |
| 11 | 11 | 04/27/08 | 0 | 240 | 1000 | 100 | 3 | 2.98 | <0.001 | |
| Location: 0A 10' From B / Cor Elevator | | | | | | | | | | |

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A281048; Sherman Plaza; 4650 Broadway, 2nd Floor; Prep

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 04/29/08 | 8 | 240 | 1920 | 100 | 2 | 2.55 | < 0.001 | |
| Location: OA 6' From Airlock To Work Area | | | | | | | | | | |
| 13 | 13 | 04/29/08 | 8 | 240 | 1920 | 100 | 3 | 3.82 | < 0.001 | |
| Location: HEPA Micro Trap Exhaust B / Way | | | | | | | | | | |
| 14 | 14 | 04/29/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 15 | 15 | 04/29/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94; Using an Olympus, Model CH5 PCM microscope, Serial #0A16076; Analyzed by: Kenneth R. Farrell; Date Analyzed: 03/09/2008; Limit of Detection= 5.5 fibers /100 fields or 7 fibers/mm²; Blank analyzers are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc and not as fibers/m³. Filter size: ND=No fibers observed. NA= Not Analyzed; Walton-Beckett particle field area = 0.00785 m²; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance Test)- Calculated as a one sided LCL to determine 95% certainty of compliance with the 0.01 fibers/cc standard; Estimated RSD: Interlab S=0.405, IntraLab S=0.45, (NY ELAP Lab #1148), AIHA Lab # 102843)

Reviewed By:  _____ END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 2, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208051159
P.O. #A281048
A281048; Sherman Plaza; 4650 Broadway - 2nd Floor (Durings)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Thursday, May 01, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marvin E. Brothers". The signature is stylized and fluid.

Marvin E. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results
 A281048: Sherman Plaza, 4550 Broadway - 2nd Floor (During)

| Amesol Sample # | Client Sample # | Date Collected | Flow Rate (L/min/h) | Duration (min.) | As Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ³) | Fibers Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|---------------------|-----------------|----------------------|--------|--------|---|--------------------------|-----|
| 01 | 01 | 04/03/08 | 6 | 300 | 1620 | 100 | 6 | 0.07 | <0.001 | |
| Location: Personal Drobe Clean Room | | | | | | | | | | |
| 02 | 02 | 04/03/08 | 6 | 300 | 1620 | 100 | 3.5 | 0.48 | <0.001 | |
| Location: OA @ Front Doors Exhaust Fan | | | | | | | | | | |
| 03 | 03 | 04/03/08 | 6 | 300 | 1620 | 100 | 3 | 0.42 | <0.001 | |
| Location: OA @ Front Waste Door Atrium | | | | | | | | | | |
| 04 | 04 | 04/03/08 | 6 | 300 | 1620 | 100 | 4 | 0.52 | <0.001 | |
| Location: OA Southwest Of Work Area By CB | | | | | | | | | | |
| 05 | 05 | 04/03/08 | 6 | 300 | 1620 | 100 | 3 | 0.38 | <0.001 | |
| Location: HEPA Monitoring Exhaust Bank #1 | | | | | | | | | | |
| 06 | 06 | 04/03/08 | 6 | 300 | 1620 | 100 | 4 | 0.50 | <0.001 | |
| Location: HEPA Monitoring Exhaust Bank #2 | | | | | | | | | | |
| 07 | 07 | 04/03/08 | 6 | 300 | 1620 | 100 | 3 | 0.38 | <0.001 | |
| Location: CB North Of Building | | | | | | | | | | |
| 08 | 08 | 04/03/08 | 6 | 312 | 1872 | 100 | 2.5 | 0.31 | <0.001 | |
| Location: Personal Drobe Clean Room | | | | | | | | | | |
| 09 | 09 | 04/03/08 | 6 | 300 | 1644 | 100 | 2 | 0.22 | <0.001 | |
| Location: OA @ Front Doors Exhaust Fan | | | | | | | | | | |
| 10 | 10 | 04/03/08 | 6 | 304 | 1814 | 100 | 4 | 0.50 | <0.001 | |
| Location: OA Southwest Of Work Area By CB | | | | | | | | | | |
| 11 | 11 | 04/03/08 | 6 | 300 | 1600 | 100 | 4 | 0.50 | <0.001 | |
| Location: OA @ Front Waste Door Atrium | | | | | | | | | | |

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results
 A281048; Sherman Plaza; 4650 Broadway - 2nd Floor (Durrings)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 04/30/08 | 6 | 296 | 1776 | 100 | 5 | 6.37 | < 0.002 | |
| Location: HEPA Microtrap Exhaust Bank #1 | | | | | | | | | | |
| 13 | 13 | 04/30/08 | 6 | 292 | 1752 | 100 | 3 | 3.82 | < 0.002 | |
| Location: HEPA Microtrap Exhaust Bank #2 | | | | | | | | | | |
| 14 | 14 | 04/30/08 | 6 | 288 | 1728 | 100 | 2 | 2.55 | < 0.002 | |
| Location: OB North Of Building | | | | | | | | | | |
| 15 | 15 | 04/30/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 16 | 16 | 04/30/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94; Using an Olympus Model CHS PCM microscope, Serial #DA0076; Analyzed by: Kenneth R. Harrel
 Limit of Detection= 5.3 fibers /100 fields or 7 fibers/mm²; Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report states ONLY to the sample analysis expressed as fibers/cc sum of
 Filter area; ND=No fibers observed; NA= Not Analyzed; WB= Blank; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence Limit (Employers Compliance
 Test)- Calculated as 95th Percentile UCL to determine 95% compliance standard; Estimated RSD: Interlab S=0.465, IntraLab S=0.45, (NY ELAP Lab 11489, AIHA Lab # 102843)

Date Analyzed: 5/2/2008

Reviewed By:  _____
 END OF REPORT



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8800 • FAX: (212) 679-9392

May 2, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208051160
P.O. #A281048
A281048; Sherman Plaza; 4650 Broadway - 2nd Floor (Durings)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Thursday, May 01, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
PCM Manager

AmesCo Job #: 208061160

Client Name: CMB Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results
 A281048: Sherman Plaza, 4050 Broadway - 2nd Floor (Dairies)

| AmesCo Sample # | Client Sample # | Date Collected | Fiber Rate (Fibers/min.) | Duration (min.) | As Filtered (Fibers) | Fibers | Fiber Density (Fibers/cm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--|-----------------|----------------|--------------------------|-----------------|----------------------|--------|---|--------------------------|-----|
| 01 | 01 | 00/01/08 | 0 | 300 | 1012 | 100 | 0.14 | <0.001 | |
| Location: Perimeter Glass Clean Room | | | | | | | | | |
| 02 | 02 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: OA # From Dairies Dressing Area | | | | | | | | | |
| 03 | 03 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: OA # From Airlock Visual Decant | | | | | | | | | |
| 04 | 04 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: OA # Southwest By CB | | | | | | | | | |
| 05 | 05 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: OA North Of Building | | | | | | | | | |
| 06 | 06 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: Meeting Room East B1 | | | | | | | | | |
| 07 | 07 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: Meeting Room East B2 | | | | | | | | | |
| 08 | 08 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: Perimeter Dairies Clean Room | | | | | | | | | |
| 09 | 09 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: OA # From Dairies Environmental Cell | | | | | | | | | |
| 10 | 10 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: OA # From North Dairies Airlock | | | | | | | | | |
| 11 | 11 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: OA # Southwest By CB | | | | | | | | | |
| 12 | 12 | 00/01/08 | 0 | 300 | 1812 | 100 | 3.82 | <0.001 | |
| Location: OA North Of Building | | | | | | | | | |

See Summary report on test page

AmeriSci Job #: 208051160

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results
 A281048; Sherman Plaza; 4650 Broadway - 2nd Floor (Durlings)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 13 | 13 | 05/01/08 | 6 | 306 | 1836 | 100 | 3 | 3.62 | < 0.001 | |
| Location: OA Microtrap Exhaust Bank #1 | | | | | | | | | | |
| 14 | 14 | 05/01/08 | 6 | 302 | 1812 | 100 | 2 | 2.55 | < 0.001 | |
| Location: Microtrap Exhaust Bank #2 | | | | | | | | | | |
| 15 | 15 | 05/01/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 16 | 16 | 05/01/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus Model CHS PCM microscopes. Serial #OAM076. Analyzed by: Fred A. Cottrell (pub) Date Analyzed: 5/2/2008.
 Limit of Detection = 5.5 fibers/100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples to this report. This report refers ONLY to the sample analysis expressed as fibers/cc mm of fiber area. ND=No fibers observed. NA= Not Analyzed. When Beckert graticle field area = 0.00785 mm²; TWA = 8 Hb TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence Limit (Employers Compliance Test) - Calculated from the stated LCL to determine 95% certainty of compliance with the 0.01 fiber/cc standard. Estimated BSD: Inhalab S=0.005, Inhalab S=0.45, (NY ELAP Lab # 1488), AIHA Lab # 102843

FC by WB

Reviewed By:  END OF REPORT

May 4, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208051423
P.O. #A281048
4281048: Sherman Plaza, 4500 Broadway, 2nd Floor (Dunlop)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Saturday, May 03, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cm³ of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,



Marvin E. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results
 A231048, Sherman Plaza, 4850 Broadway, 2nd Floor (During)

| AmorSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Ag Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/cm ²) | Fibers Count (Filtered) | TWA |
|--|-----------------|----------------|------------------------|----------------|----------------------|--------|--------|---|-------------------------|-----|
| 01 | 01 | 05/03/08 | 6 | 319 | 1655 | 100 | 10 | 12.76 | 0.000 | |
| Location: Personal Decon Clean Room | | | | | | | | | | |
| 02 | 02 | 05/03/08 | 6 | 319 | 1650 | 400 | 8 | 11.88 | 0.000 | |
| Location: OA #1 From Ocean Entrance | | | | | | | | | | |
| 03 | 03 | 05/03/08 | 6 | 310 | 1650 | 100 | 8 | 7.54 | 0.000 | |
| Location: OA #1 From Waste Decon Area | | | | | | | | | | |
| 04 | 04 | 05/03/08 | 6 | 310 | 1640 | 100 | 33 | 4.48 | 4.0.000 | |
| Location: OA Southwest Highway By CB | | | | | | | | | | |
| 05 | 05 | 05/03/08 | 6 | 310 | 1650 | 100 | 8 | 6.37 | 5.0.000 | |
| Location: CB North Of Building | | | | | | | | | | |
| 06 | 06 | 05/03/08 | 6 | 310 | 1650 | 100 | 7 | 8.82 | 0.000 | |
| Location: HEPA Microvac Barn #1 | | | | | | | | | | |
| 07 | 07 | 05/03/08 | 6 | 310 | 1650 | 100 | 8.8 | 10.83 | 0.000 | |
| Location: HEPA Microvac Tray Barn #2 | | | | | | | | | | |
| 08 | 08 | 05/03/08 | 6 | 312 | 1672 | 100 | 3 | 3.82 | 4.0.000 | |
| Location: Personal Decon Clean Room | | | | | | | | | | |
| 09 | 09 | 05/03/08 | 6 | 308 | 1648 | 100 | 3 | 3.82 | 4.0.000 | |
| Location: OA #1 From Waste Decon | | | | | | | | | | |
| 10 | 10 | 05/03/08 | 6 | 308 | 1628 | 100 | 2 | 3.88 | 4.0.000 | |
| Location: #1 From Personal Decon Exit / Exit | | | | | | | | | | |
| 11 | 11 | 05/03/08 | 6 | 300 | 1600 | 100 | 8 | 10.18 | 0.000 | |
| Location: OA Southwest Highway By CB | | | | | | | | | | |



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-6900 • FAX: (212) 679-6362

May 8, 2008

CNS Management Corporation
Attn: Charles Powers
650 W. Old Country Road
Suite 308
Hicksville, NY 11801

Re: CNS Management Corporation
Job Number 258051845
P.O. 8A281048
A281048; Sherman Plaza, 4800 Broadway - Irving

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Tuesday, May 06, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 6/15/04. The counting rates used are described in previous versions of this method as "A" rates unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cm³ of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci-certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Boffers
PCM Manager

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A281049: Sherman Plaza, 45% Broadway - During

| AmesCo Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (bars) | Fields | Fibers | Fiber Density (Fibers/cm ²) | Fiber Conc. (Fibers/cc) | TYWA |
|---|-----------------|----------------|------------------------|----------------|---------------------|--------|--------|---|-------------------------|------|
| 01 | 01 | 08/04/08 | 0 | 319 | 1850 | 100 | 0 | 7.94 | 0.000 | |
| Location: Personal Decor Clean Room | | | | | | | | | | |
| 02 | 02 | 08/04/08 | 0 | 319 | 1850 | 100 | 0 | 10.18 | 0.000 | |
| Location: 10 First Floor Entrance / Exit | | | | | | | | | | |
| 03 | 03 | 08/04/08 | 0 | 318 | 1850 | 100 | 3 | 3.82 | <0.001 | |
| Location: 04 8 First Waste Decoh. Atrium | | | | | | | | | | |
| 04 | 04 | 08/04/08 | 0 | 318 | 1850 | 100 | 0 | 7.04 | 0.000 | |
| Location: 04 Southwest Work Area By CS | | | | | | | | | | |
| 05 | 05 | 08/04/08 | 0 | 318 | 1850 | 100 | 0 | 7.04 | 0.000 | |
| Location: 08 North Of Building | | | | | | | | | | |
| 06 | 06 | 08/04/08 | 0 | 318 | 1850 | 100 | 0 | 11.48 | 0.000 | |
| Location: 10TH Floor Mirrored Lateral Bank #1 | | | | | | | | | | |
| 07 | 07 | 08/04/08 | 0 | 318 | 1850 | 100 | 0 | 10.18 | 0.000 | |
| Location: 10TH Floor Mirrored Exhaust Bank #2 | | | | | | | | | | |
| 08 | 08 | 08/04/08 | 0 | 320 | 1850 | 100 | 0 | 6.37 | <0.001 | |
| Location: Personal Decor Clean Room | | | | | | | | | | |
| 09 | 09 | 08/04/08 | 0 | 304 | 1844 | 100 | 4 | 8.18 | <0.001 | |
| Location: 10 First Floor Entrance / Exit | | | | | | | | | | |
| 10 | 10 | 08/04/08 | 0 | 300 | 1820 | 100 | 0 | 10.18 | 0.000 | |
| Location: 8 First Waste Decoh Atrium | | | | | | | | | | |
| 11 | 11 | 08/04/08 | 0 | 318 | 1850 | 100 | 14 | 17.83 | 0.004 | |
| Location: Southwest Work Area By CS | | | | | | | | | | |

See Reporting notes on last page.

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A281048; Sherman Plaza, 4650 Broadway - During


| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/05/08 | 6 | 311 | 1866 | 100 | 12.5 | 15.92 | 0.003 | |
| Location: OB North By Bulbing | | | | | | | | | | |
| 13 | 13 | 05/05/08 | 6 | 307 | 1842 | 100 | 4 | 5.10 | < 0.001 | |
| Location: HEPA Microtrap Exhaust Bank #1 | | | | | | | | | | |
| 14 | 14 | 05/05/08 | 6 | 303 | 1818 | 100 | 3 | 3.82 | < 0.001 | |
| Location: HEPA Microtrap Exhaust Bank #2 | | | | | | | | | | |
| 15 | 15 | 05/05/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 16 | 16 | 05/05/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus, Model CEM PCM microscope, Serial #CA00776, Analyzed by: Tatyana Grinichak. Date Analyzed: 5/6/2008.
 Limit of Detection= 5.5 fibers /100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc and of Filter area: ND=No fibers observed; NA= Not Analyzed; Wilson-Beckett graticule field area = 0.00285 mm²; TWA = 8 Hr TWA calculation assumes 8 hr period not sampled; Upper 95% Confidence limit (Employee Compliance Test)- Calculated as a one sided UCL to determine 95% certainty of compliance with the 0.01 fibers/cc standard; Estimated RSD: Intralab S=0.405, Interlab S=0.45, (NY ELAP Lab 11489, AIBIA Lab # 102843)



Reviewed By: 

END OF REPORT



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8000 • FAX: (212) 679-9992

May 7, 2008

CNS Management Corporation
Attn: Charles Powers
800 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208051787
P.O. #A281048
A281048, Sherman Plaza, 4600 Broadway, 2nd Floor (Stamps)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, May 07, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/04. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibering cm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.


AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results
 A231048: Sherman Plaza, 4850 Broadway, 2nd Floor. (During)

| AmorSci Sample # | Client Sample # | Date Collected | Flow Rate (m/min) | Duration (min) | All Filtered (Items) | Fibers | Floors | Fiber Density (Fibers/cm ²) | Floors Conc. (Fibers/cm ²) | TVM |
|---|-----------------|----------------|-------------------|----------------|----------------------|--------|--------|---|--|-----|
| 01 | 01 | 05/05/08 | 6 | 300 | 1813 | 100 | 14 | 17.00 | 0.004 | |
| Location: Personal Room Clean Room | | | | | | | | | | |
| 02 | 02 | 05/05/08 | 6 | 300 | 1813 | 100 | 23 | 38.00 | 0.008 | |
| Location: 10' Free Decan Est / Est | | | | | | | | | | |
| 03 | 03 | 05/05/08 | 6 | 300 | 1813 | 100 | 8 | 10.14 | 0.003 | |
| Location: OAS From Waste Decan Airlock | | | | | | | | | | |
| 04 | 04 | 05/05/08 | 6 | 300 | 1813 | 100 | 8 | 7.94 | 0.003 | |
| Location: OA Southwest Of Wash Area By CB | | | | | | | | | | |
| 05 | 05 | 05/05/08 | 6 | 300 | 1813 | 100 | 8 | 8.37 | 0.003 | |
| Location: OB North Of Building | | | | | | | | | | |
| 06 | 06 | 05/05/08 | 6 | 300 | 1813 | 100 | 4 | 6.19 | 0.001 | |
| Location: HEPA Microscopy Exhaust #1 | | | | | | | | | | |
| 07 | 07 | 05/05/08 | 6 | 300 | 1813 | 100 | 7 | 8.82 | 0.003 | |
| Location: HEPA Microscopy Exhaust Item #2 | | | | | | | | | | |
| 08 | 08 | 05/05/08 | 6 | 300 | 1808 | 100 | 19 | 32.14 | 0.003 | |
| Location: Personal Decan Clean Room | | | | | | | | | | |
| 09 | 09 | 05/05/08 | 6 | 300 | 1803 | 100 | 9 | 7.88 | 0.002 | |
| Location: 10' Free Decan Est / Est | | | | | | | | | | |
| 10 | 10 | 05/05/08 | 6 | 319 | 1808 | 100 | 8 | 8.37 | 0.003 | |
| Location: OA 8' Free Waste Decan Airlock | | | | | | | | | | |
| 11 | 11 | 05/05/08 | 6 | 314 | 1804 | 100 | 12 | 16.26 | 0.003 | |
| Location: OA Southwest Of Wash Area By CB | | | | | | | | | | |

The logo for AmeriSci, featuring the company name in a serif font with a stylized swoosh above and below the letters.

AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10018

TEL: (212) 879-8800 • FAX: (212) 879-8382

May 8, 2008

CNS Management Corporation
Attn: Charles Powers
890 W. Old Country Road
Suite 300
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208052085
P.O. #A281048
A281048, Sherman Plaza, 4650 Broadway 2nd Floor (Daring)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Friday, May 08, 2008, for a 24 hour turnaround:


01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/04. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the filter count results.

This report relates ONLY to the sample analysis expressed as fibers/cc mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "MK Brothers".

Marvin C. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results
 A20104B, Sherman Plaza, 4850 Broadway 2nd Floor (During)

| AmesCo Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (Board) | Fibers | Fiber Density (Fibers/cm ²) | Fibers Count (Fibers/cm ²) | TWA |
|---|-----------------|----------------|------------------------|----------------|----------------------|--------|---|--|-----|
| 01 | 01 | 06/07/08 | 4 | 313 | 1800 | 100 | 3.36 | 4.0.001 | |
| Location: Personal Clean Change Room | | | | | | | | | |
| 02 | 02 | 06/07/08 | 4 | 314 | 1800 | 100 | 3.62 | 4.0.001 | |
| Location: 1st Floor Elevator Entrance / Exit | | | | | | | | | |
| 03 | 03 | 06/07/08 | 4 | 315 | 1875 | 100 | 3.89 | 4.0.001 | |
| Location: 8 th Floor Waste Disposal Area | | | | | | | | | |
| 04 | 04 | 06/07/08 | 4 | 315 | 1872 | 100 | 3.18 | 4.0.001 | |
| Location: OA Southwest Of Work Area By CB | | | | | | | | | |
| 05 | 05 | 06/07/08 | 4 | 313 | 1802 | 100 | 3.63 | 4.0.001 | |
| Location: 08 North Of Building | | | | | | | | | |
| 06 | 06 | 06/07/08 | 4 | 313 | 1872 | 100 | 3.59 | 4.0.001 | |
| Location: HEPA Microbial Exhaust Fans #1 | | | | | | | | | |
| 07 | 07 | 06/07/08 | 4 | 315 | 1802 | 100 | 3.90 | 4.0.001 | |
| Location: HEPA Microbial Exhaust Fans #2 | | | | | | | | | |
| 08 | 08 | 06/07/08 | 4 | 314 | 1800 | 100 | 3.62 | 4.0.001 | |
| Location: Personal Clean Change Room | | | | | | | | | |
| 09 | 09 | 06/07/08 | 4 | 313 | 1872 | 100 | 3.96 | 4.0.001 | |
| Location: 1st Floor Elevator Entrance / Exit | | | | | | | | | |
| 10 | 10 | 06/07/08 | 4 | 309 | 1804 | 100 | 3.96 | 4.0.001 | |
| Location: 8 th Floor Waste Disposal Area | | | | | | | | | |
| 11 | 11 | 06/07/08 | 4 | 308 | 1800 | 100 | 4.57 | 4.0.001 | |
| Location: OA Southwest Of Work Area By CB | | | | | | | | | |
| 12 | 12 | 06/07/08 | 4 | 303 | 1872 | 100 | 3.83 | 4.0.001 | |
| Location: 08 North Of Building | | | | | | | | | |



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 9, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208052082
P.O. #A281048
A281048; Sherman Plaza, 4650 Broadway - 2nd Floor - During

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Friday, May 09, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink that reads "JK for MB".

Marvin E. Brothers
PCM Manager

Client Name: CNIS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results
 A281048: Sherman Plaza, 4850 Broadway - 2nd Floor - During

| Analysis Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (hours) | Faults | Fibers | Fiber Density (Fibers/cm ²) | Fibers Count (Fibers/lot) | TWA |
|---|-----------------|----------------|-------------------------|-----------------|----------------------|--------|--------|---|---------------------------|-----|
| 01 | 01 | 6/26/08 | 9 | 300 | 1812 | 100 | 2.4 | 4.48 | < 0.001 | |
| Location: Perimeter Door Clean Room | | | | | | | | | | |
| 02 | 02 | 6/26/08 | 9 | 300 | 1812 | 100 | 9 | 8.10 | < 0.001 | |
| Location: 10' From Door Ent. 1 East | | | | | | | | | | |
| 03 | 03 | 6/26/08 | 9 | 300 | 1812 | 100 | 9 | 3.48 | < 0.001 | |
| Location: 8' From Vehicle Drive Atrium | | | | | | | | | | |
| 04 | 04 | 6/26/08 | 9 | 300 | 1812 | 100 | 9 | 6.30 | < 0.001 | |
| Location: 0A Southwest Of Work Area By CB | | | | | | | | | | |
| 05 | 05 | 6/26/08 | 9 | 300 | 1812 | 100 | 9 | 3.80 | < 0.001 | |
| Location: CB north of Building | | | | | | | | | | |
| 06 | 06 | 6/26/08 | 9 | 300 | 1812 | 100 | 2.4 | 4.48 | < 0.001 | |
| Location: 187A Moving Exhaust Hoods at | | | | | | | | | | |
| 07 | 07 | 6/26/08 | 9 | 300 | 1812 | 100 | 9 | 3.80 | < 0.001 | |
| Location: 187A Microchip Exhaust Hoods at | | | | | | | | | | |
| 08 | 08 | 6/26/08 | 9 | 300 | 1802 | 100 | 9 | 2.58 | < 0.001 | |
| Location: Perimeter Door Clean Room | | | | | | | | | | |
| 09 | 09 | 6/26/08 | 4 | 318 | 1808 | 100 | 9 | 3.60 | < 0.001 | |
| Location: 10' From Door Entry / Exit | | | | | | | | | | |
| 10 | 10 | 6/26/08 | 9 | 318 | 1808 | 100 | 2.4 | 3.18 | < 0.001 | |
| Location: 8' From Perimeter Exhaust | | | | | | | | | | |
| 11 | 11 | 6/26/08 | 9 | 310 | 1800 | 100 | 1 | 3.80 | < 0.001 | |
| Location: 0A Southwest Of Work Area CB | | | | | | | | | | |
| 12 | 12 | 6/26/08 | 4 | 308 | 1808 | 100 | 48 | 81.18 | 0.013 | |
| Location: 0B South Of Building | | | | | | | | | | |

See Reporting notes on last page

Phase Contrast Microscopy (PCM) Fiber Results
 A281048, Sherman Plaza, 4650 Broadway - 2nd Floor - During

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 13 | 13 | 05/08/08 | 6 | 302 | 1812 | 100 | 3 | 3.82 | < 0.001 | |
| Location: HEPA Microtrap Exhaust #1 | | | | | | | | | | |
| 14 | 14 | 05/08/08 | 6 | 298 | 1788 | 100 | 16 | 20.38 | 0.004 | |
| Location: Microtrap Exhaust #2 | | | | | | | | | | |
| 15 | 15 | 05/08/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 16 | 15 | 05/08/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus, Model CHS PCM microscope, Serial #0A0076. Analyzed by: Kenneth R. Harrell (kj) *SK for KH* Date Analyzed: 5/9/2008.
 Limit of Detection = 5.5 fibers /100 fields or 7 fibers/cm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers by area of filter area. ND=No fibers observed; NA= Not Analyzed; Walton-Beckett graticle field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence limit (Employers Compliance Test)- Calculated as a one sided TWA, to determine 95% certainty of compliance with the 0.01 fiber/cc standard; Estimated RSD: IntraLab Sp=0.465, InterLab Sp=0.45, (NY ELAP Lab 11480, AIBIA Lab n 102943)

Reviewed by: *Kassin* _____ END OF REPORT _____



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 14, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208052083
P.O. #A281048
A281048; Sherman Plaza, 4650 Broadway 2nd Floor Phase #1 - Clearance (Report Amended
5/14/2008)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Friday, May 09, 2008, for a 12 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13

The 13 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink that reads "JK for MB".

Marvin E. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results

Address: Sherman Plaza, 4650 Broadway 2nd Floor Phase #1 - Clearance (Report Amended 3/14/2016)

| AmberSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (ft³) | Fibers | Fibers / Fibersm ³ | Fiber Density (Fibersm ⁻³) | Fiber Count (Fibers) | RMA |
|--|-----------------|----------------|------------------------|----------------|--------------------|--------|-------------------------------|--|----------------------|-----|
| 01 | 01 | 000000 | 15 | 122 | 1830 | 100 | 3 | 3.82 | 4.0.001 | |
| Location: 1A Northeast Corner | | | | | | | | | | |
| 02 | 02 | 000000 | 15 | 122 | 1830 | 100 | 2 | 3.99 | 4.0.001 | |
| Location: 1A Southwest Corner | | | | | | | | | | |
| 03 | 03 | 000000 | 15 | 122 | 1830 | 100 | 2.5 | 3.18 | 4.0.001 | |
| Location: 1A Corner Inside West Area | | | | | | | | | | |
| 04 | 04 | 000000 | 15 | 122 | 1830 | 100 | 0 | 2.50 | 4.0.001 | |
| Location: 1A Southwest Inside West Area | | | | | | | | | | |
| 05 | 05 | 000000 | 15 | 122 | 1830 | 100 | 0 | 3.58 | 4.0.001 | |
| Location: 1A Northeast Corner from West Area | | | | | | | | | | |
| 06 | 06 | 000000 | 15 | 122 | 1830 | 100 | 3 | 3.82 | 4.0.001 | |
| Location: 02 North Of Building | | | | | | | | | | |
| 07 | 07 | 000000 | 15 | 122 | 1830 | 100 | 0 | 2.58 | 4.0.001 | |
| Location: 0A Southwest Of West Area By-23 | | | | | | | | | | |
| 08 | 08 | 000000 | 15 | 122 | 1830 | 100 | 0 | 2.58 | 4.0.001 | |
| Location: 0A Southwest Entry | | | | | | | | | | |
| 09 | 09 | 000000 | 15 | 122 | 1830 | 100 | 0 | 2.58 | 4.0.001 | |
| Location: 0A Entry 2 From Above To WA | | | | | | | | | | |
| 10 | 10 | 000000 | 15 | 122 | 1830 | 100 | 0 | 2.82 | 4.0.001 | |
| Location: 0A Moving External Bank #1 | | | | | | | | | | |
| 11 | 11 | 000000 | 15 | 122 | 1830 | 100 | 0 | 3.82 | 4.0.001 | |
| Location: 0A Moving External Bank #2 | | | | | | | | | | |
| 12 | 12 | 000000 | 0 | 0 | 0 | 100 | 0.8 | 0.08 | | |
| Location: First Bank | | | | | | | | | | |

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A281048; Sherman Plaza, 4650 Broadway 2nd Floor Phase #1 - Clearance (Report Amended 5/14/2008)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|-----|
| 13 | 13 | 05/09/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |

Location: Field Blank

Footnotes: 1

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus, Model CH5 PCM microscope, Serial #0A9076. Analyzed by Kenneth R. Harrell (g)
 Limit of Detection 3.5 fibers/100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis requested as fibers/cc units of fiber area. ND=No fibers observed; NA= Not Analyzed; Walton-Bockels gradeable field area = 0.60785 mm²; TWA = 8 hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence Limit (Employers Compliance Test); Calculated as a one sided UCL to approximate 95% certainty of compliance with the 0.01 fiber/cc standard. Ethmoid RSD: IntraLab 5=0.405, InterLab 5=0.45, (NY ELAP Lab-11480, AIHA Lab # 102843)

Reviewed By: *KASHW*

END OF REPORT

JK bOKH

Date Analyzed: 5/9/2008;



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 9, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208052084
P.O. #A281048
A281048; Sherman Plaza; 4650 Broadway - 2nd Floor Phase #1 (Clearance)

Dear Charles Powers:

Enclosed are the results for TEM fiber analysis of the following CNS Management Corporation samples received at AmeriSci on Friday, May 09, 2008, for a 12 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13

The 13 air samples were sent to AmeriSci via Hand Delivered. These samples were prepared according to AHERA Protocol.

Table I represents a summary of all pertinent information used for the structure (fiber) density and concentration calculations. Included are the size of each structure counted, the structure density and concentration, type of fibrous material detected and the analytical sensitivity, which represents the concentration by the detection of one structure in the TEM structure count. Copies of the Fiber Count Sheets are included. These data sheets contain information for structure length/width, structure type, structure morphology and pertinent information on EDS, SAED and photography.

This report relates ONLY to the sample analysis expressed as structure density. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci, NVLAP or any agency of the U. S. Government. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the written approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Paul J. Mucha
Laboratory Director

Table 1
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
 A281048, Sherman Place, 4650 Broadway - 2nd Floor Phase #1 (Clearance)

| AmorSci Sample # | Client Sample # | Location | Air Filtered (ft ³) | Area Analyzed (ft ²) | Analytical Sensitivity (fibrils/ft ³) | Asbestos Structures Detected (Microves) | | Structural Density (fibrils/cm ³) | | Structure Concentration (fibrils/ft ³) | | Type of Asbestos |
|------------------|-----------------|---|---------------------------------|----------------------------------|---|---|-------|---|-------|--|-------|------------------|
| | | | | | | 0.0-0.0 | >>0.0 | Total | <=0.0 | >0.0 | Total | |
| 01 | 01 | Location: 1A Northeast Inside Work Area | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 02 | 02 | Location: 1A Southeast Inside Work Area | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 03 | 03 | Location: 1A Carpet Inside Work Area | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 04 | 04 | Location: 1A Southeast Inside Work Area | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 05 | 05 | Location: 1A Northeast Inside Work Area | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 06 | 06 | Location: 03 North of Building | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 07 | 07 | Location: 0A Southwest of Work Area By CB | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 08 | 08 | Location: 0A Northside Highway | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 09 | 09 | Location: 0A Highway 2 From Aerial | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 10 | 10 | Location: 0A Murray Building (Park #1) | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 11 | 11 | Location: 0A Murray Building #2 | 1200 | 37 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 12 | 12 | Location: Field Blank | 0 | 0 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |
| 13 | 13 | Location: Field Blank | 0 | 0 | 0.0044 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | MSD |

AmorSci Job #: 200502084
 Client Name: CNS Management Corporation
 A281048, Sherman Place, 4650 Broadway - 2nd Floor Phase #1 (Clearance)
 Analyzed By: 
 Date: 3/20/08

TEM Asbestos (air) Count Sheet

Sample Area Analyzed



| | |
|--|--|
| Client Name: CNS Management Corporation Job #: 208052084 Lab Sample #: 01 Client Sample #: 01 Received: 05/09/08 01:07:43 Date Analyzed: 05/09/08 Scope #: 7 | Volume (liters): 1,260.0 Filter Type / Filter Area: MCE 385 mm ² Grid Opening Size: 0.01000 mm ² Area Examined: 0.07000 mm ² Magnification: 20,000 Accelerating Voltage: 100 KeV |
|--|--|

Analysis Performed by: VS
Victor Slopac

| Location | Grid Opening | Fiber | Length μm | Width μm | Fiber Type | Morphology | EDS | Orient. | SAED | Photo |
|----------|--------------|-------|----------------------|---------------------|------------|------------|-----|---------|------|-------|
| B4-4/1C | 1 | NSD | | | | | | | | |
| B4-4/1E | 2 | NSD | | | | | | | | |
| B4-4/1F | 3 | NSD | | | | | | | | |
| B4-4/1G | 4 | NSD | | | | | | | | |
| B5-4/1C | 5 | NSD | | | | | | | | |
| B5-4/1E | 6 | NSD | | | | | | | | |
| B6-4/1F | 7 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density | Concentration | Grid Evaluation |
|----------------------------------|----------------------|---------------|---|
| | (#/mm ²) | (#/cc air) | |
| Total Grid Openings: | 7 | | |
| Chrysotile Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures >= 5 microm: | 0 | <0.0044 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 14.3 | 0.0044 | <input checked="" type="checkbox"/> Particulate Event |

TEM Asbestos (air) Count Sheet

sample and analyzed



| | | |
|---|----------|--|
| Client Name: CNS Management Corporation | | Volume (liters): 1 260.0 |
| Job #: 208052084 | | Filter Type / Filter Area: MCE 385 mm ² |
| Lab Sample #: 02 | | Grid Opening Size: 0.01000 mm ² |
| Client Sample #: 02 | | Area Examined: 0.07000 mm ² |
| Received: 05/09/08 | 01:07:43 | Magnification: 20,000 |
| Date Analyzed: 05/09/08 | | Accelerating Voltage: 100 KeV |
| Scope #: 7 | | |

Analysis Performed by: Victor Slopac

| Location | Grid Opening | Fiber | Length (µm) | Width (µm) | Fiber Type | Morphology | EDS | Other | SAED | Photo |
|----------|--------------|-------|-------------|------------|------------|------------|-----|-------|------|-------|
| C1-44C | 1 | NSD | | | | | | | | |
| C1-44E | 2 | NSD | | | | | | | | |
| C1-44F | 3 | NSD | | | | | | | | |
| C1-44G | 4 | NSD | | | | | | | | |
| C2-31C | 5 | NSD | | | | | | | | |
| C2-31E | 6 | NSD | | | | | | | | |
| C2-31F | 7 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (µm/mm ²) | Concentration (fibrils/cc air) | Grid Evaluation |
|-----------------------------------|---|--------------------------------|---|
| Total Grid Openings: | 7 | | |
| Chrysotile Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Grid Openings Covered = 50% |
| Amphibole Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures >= 5 microns: | 0 | <0.0044 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 14.3 | 0.0044 | <input checked="" type="checkbox"/> Particulate Even |

TEM Asbestos (air) Count Sheet

Sample Area
analyzed



| | |
|---|--|
| Client Name: CNS Management Corporation Job #: 208052084 Lab Sample #: 03 Client Sample #: 03 Received: 05/09/08 Date Analyzed: 05/09/08 Slips #: 7 | Volume (liters): 1 260.0 Filter Type / Filter Area: MCE 385 mm ² Grid Opening Size: 0.01000 mm ² Area Examined: 0.07000 mm ² Magnification: 20,000 Accelerating Voltage: 100 KeV |
|---|--|

Analysis Performed by: VS
 Victor Slovic

| Location | Grid Opening | Fiber | Length μ m | Width μ m | Fiber Type | Morphology | EDS | Count | SAED | Photo |
|----------|--------------|-------|----------------|---------------|------------|------------|-----|-------|------|-------|
| C3-44C | 1 | NSD | | | | | | | | |
| C3-44E | 2 | NSD | | | | | | | | |
| C3-44F | 3 | NSD | | | | | | | | |
| C3-44G | 4 | NSD | | | | | | | | |
| C4-44C | 5 | NSD | | | | | | | | |
| C4-44E | 6 | NSD | | | | | | | | |
| C4-44F | 7 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments:

| | Structure Density (sto/mm ²) | Concentration (sto/cc air) | Grid Evaluation |
|-----------------------------------|---|-------------------------------|---|
| Total Grid Openings: | 7 | | |
| Chrysotile Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures >= 5 microns: | 0 | <0.0044 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 14.3 | 0.0044 | <input checked="" type="checkbox"/> Particulate Even |

TEM Asbestos (air) Count Sheet

sample used
analyzed



| | |
|---|--|
| Client Name: CNS Management Corporation Job #: 208052084 Lab Sample #: 04 Client Sample #: 04 Received: 05/09/08 Date Analyzed: 05/09/08 Scope #: 7 | Volume Filtered: 1.260.0 Filter Type / Filter Area: MCE 385 mm ² Grid Opening Size: 0.01000 mm ² Area Examined: 0.07000 mm ² Magnification: 20,000 Accelerating Voltage: 100 KeV |
|---|--|

Analysis Performed by: JS
Victor Slopac

| Location | Grid Opening | Filter | Length: μ m | Width: μ m | Fiber Type | Morphology | EDS | Orient. | SAED | Photo |
|----------|--------------|--------|-----------------|----------------|------------|------------|-----|---------|------|-------|
| C6-40C | 1 | NSD | | | | | | | | |
| C6-40E | 2 | NSD | | | | | | | | |
| C6-40F | 3 | NSD | | | | | | | | |
| C6-40G | 4 | NSD | | | | | | | | |
| D1-54C | 5 | NSD | | | | | | | | |
| D1-54E | 6 | NSD | | | | | | | | |
| D1-54F | 7 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (#/mm ²) | Concentration (#/cc air) | Grid Evaluation |
|-----------------------------------|---|-----------------------------|---|
| Total Grid Openings: | 7 | | |
| Chrysotile Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures >= 3 microns: | 0 | <0.0044 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 14.3 | 0.0044 | <input checked="" type="checkbox"/> Particulate Even |

TEM Asbestos (air) Count Sheet

sample used
analyzed



| | |
|---|---|
| Client Name: CNS Management Corporation Job #: 208052084 Lab Sample #: 05 Client Sample #: 05 Received: 05/09/08 Date Analyzed: 05/09/08 Scope #: 7 | Volume Filtered: 1260.0 Filter Type / Filter Area: MCE 388 mm ² Grid Opening Size: 0.01000 mm ² Area Examined: 0.07000 mm ² Magnification: 20,000 Accelerating Voltage: 100 KeV |
|---|---|

Analysis Performed by: VS
Victor Slopac

| Location | Grid Opening | Filter | Length μ m | Width μ m | Filter Type | Morphology | EDS | Orient. | SAED | Photo |
|----------|--------------|--------|----------------|---------------|-------------|------------|-----|---------|------|-------|
| D2-S4C | 1 | NSD | | | | | | | | |
| D2-S4E | 2 | NSD | | | | | | | | |
| D2-S4F | 3 | NSD | | | | | | | | |
| D2-S4G | 4 | NSD | | | | | | | | |
| D3-S4C | 5 | NSD | | | | | | | | |
| D3-S4E | 6 | NSD | | | | | | | | |
| D3-S4F | 7 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|-----------------------------------|---|-------------------------------|--|
| Total Grid Openings: | 7 | | |
| Chrysotile Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Grid Openings Covered \geq 50% |
| Amphibole Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures >= 5 microns: | 0 | <0.0044 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: | 0 | <0.0044 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 14.3 | 0.0044 | <input checked="" type="checkbox"/> Particulate Even |



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 13, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208052566
P.O. #A281048
A281048; Sherman Plaza; 4550 Broadway; 2nd Floor Phase #2; Prep

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Tuesday, May 13, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18

The 18 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink that reads "MEB" with a stylized flourish.

Marvin E. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results

A281048: Sherman Plaza - 4850 Broadway 2nd Floor Phase #2, Prep

| Ameslci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (Foot) | Fails | Fibers | Fiber Density (Fibers/cm ²) (Filtered) | Fibers Count (Filtered) | TWA |
|---|-----------------|----------------|------------------------|----------------|---------------------|-------|--------|--|-------------------------|-----|
| 01 | 01 | 08/12/08 | 6 | 270 | 1620 | 100 | 0 | 0.00 | < 0.001 | |
| Location: Personal DCoC Clean Room | | | | | | | | | | |
| 02 | 02 | 08/12/08 | 6 | 270 | 1620 | 100 | 0 | 0.00 | < 0.001 | |
| Location: 6' From DCoC (in. 2nd) | | | | | | | | | | |
| 03 | 03 | 08/12/08 | 6 | 270 | 1620 | 100 | 1 | 0.05 | < 0.001 | |
| Location: 3' From Window DCoC 4th floor | | | | | | | | | | |
| 04 | 04 | 08/12/08 | 6 | 270 | 1620 | 100 | 4 | 0.19 | < 0.001 | |
| Location: Near - East of Work Area | | | | | | | | | | |
| 05 | 05 | 08/12/08 | 6 | 270 | 1620 | 100 | 0 | 0.00 | < 0.001 | |
| Location: 0ft South of Building | | | | | | | | | | |
| 06 | 06 | 08/12/08 | 6 | 270 | 1620 | 100 | 0 | 0.00 | < 0.001 | |
| Location: Machine Exhaust Bank #1 | | | | | | | | | | |
| 07 | 07 | 08/12/08 | 6 | 270 | 1620 | 100 | 2 | 0.09 | < 0.001 | |
| Location: Moving Exhaust Bank #1 | | | | | | | | | | |
| 08 | 08 | 08/12/08 | 6 | 270 | 1620 | 100 | 4 | 0.19 | < 0.001 | |
| Location: Moving Exhaust Bank #1 | | | | | | | | | | |
| 09 | 09 | 08/12/08 | 6 | 304 | 1844 | 100 | 0 | 0.00 | < 0.001 | |
| Location: Moving Exhaust Bank #1 | | | | | | | | | | |
| 10 | 10 | 08/12/08 | 6 | 500 | 1800 | 100 | 0 | 0.00 | < 0.001 | |
| Location: Personal DCoC Clean Room | | | | | | | | | | |
| 11 | 11 | 08/12/08 | 6 | 318 | 1898 | 100 | 0 | 0.00 | < 0.001 | |
| Location: 3' From Window DCoC 4th floor | | | | | | | | | | |

Phase Contrast Microscopy (PCM) Fiber Results

A281048, Sherman Plaza, 4650 Broadway, 2nd Floor Phase #2, Prep

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/12/08 | 6 | 312 | 1872 | 100 | 4 | 5.10 | < 0.001 | |
| Location: North - East Of Work Area | | | | | | | | | | |
| 13 | 13 | 05/12/08 | 6 | 308 | 1848 | 100 | 3 | 3.82 | < 0.001 | |
| Location: OB South Of Building | | | | | | | | | | |
| 14 | 14 | 05/12/08 | 6 | 304 | 1824 | 100 | 2 | 2.55 | < 0.001 | |
| Location: Microtrap Exhaust Bank #1 | | | | | | | | | | |
| 15 | 15 | 05/12/08 | 6 | 300 | 1800 | 100 | 3 | 3.82 | < 0.001 | |
| Location: Microtrap Exhaust Bank #2 | | | | | | | | | | |
| 16 | 16 | 05/12/08 | 6 | 296 | 1776 | 100 | 2 | 2.55 | < 0.002 | |
| Location: Microtrap Exhaust Bank #3 | | | | | | | | | | |
| 17 | 17 | 05/12/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 18 | 18 | 05/12/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 5400(A) Method, Issue #2, 8/15/94. Using an Olympus Model CB5 PCM microscope, Serial #0A0076, Analyzed by: Devin M. Ahye. Date Analyzed: 5/13/2008.
 Limit of Detection= 3.5 fibers /100 Fields or 7 fibers/cent; Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc mm of filter area. ND=No fibers observed; NA= Not Analyzed; Wilson-Beecher's graticle field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence limit (Employers Compliance Test)- Calculated as a one sided UCL to determine 95% certainty of compliance with the 0.01 fibers/cc standard; Estimated RSD: IntraLab 5%-0.40%, InterLab 5%-0.45% (NY ULAP Lab 11480, A10A, Lab # 102843)

Reviewed By: *[Signature]* END OF REPORT



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 14, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208052715
P.O. #A281048
A281048; Sherman Plaza, 4650 Broadway; 2nd Floor 2nd Phase (Prp, Dur)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, May 14, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20

The 20 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results

A281048 - Sherman Plaza, 4880 Broadway, 2nd Floor 2nd Phase (Prp, Dor)

| Amn:Sci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (Hours) | Fibers | Fiber Density (Fibers/cm ²) | Fiber Conc. (Fibers/cc) | FWAA |
|---|-----------------|----------------|-------------------------|-----------------|----------------------|--------|---|-------------------------|------|
| 01 | 01 | 20/12/08 | 0 | 270 | 1800 | 100 | 1.00 | < 0.002 | |
| Location: Elevator Lobby Clean Room (Prp) | | | | | | | | | |
| 02 | 02 | 20/12/08 | 0 | 270 | 1800 | 100 | 1.00 | < 0.002 | |
| Location: 8' From Deco Entrance / East (Prp) | | | | | | | | | |
| 03 | 03 | 20/12/08 | 0 | 270 | 1800 | 100 | 1.00 | < 0.002 | |
| Location: 8' From Waste Deco Atrium (Prp) | | | | | | | | | |
| 04 | 04 | 20/12/08 | 0 | 270 | 1800 | 100 | 1.10 | < 0.002 | |
| Location: CB-Southwest Of Building (Prp) | | | | | | | | | |
| 05 | 05 | 20/12/08 | 0 | 270 | 1800 | 100 | 1.13 | < 0.002 | |
| Location: OA-Northwest Of Work Area By CB (Prp) | | | | | | | | | |
| 06 | 06 | 20/12/08 | 0 | 270 | 1800 | 100 | 1.18 | < 0.002 | |
| Location: OA-East Of Work Area By CB (Prp) | | | | | | | | | |
| 07 | 07 | 20/12/08 | 0 | 270 | 1800 | 100 | 1.00 | < 0.002 | |
| Location: HEPA-Mainway Exhaust Bank #1 (Prp) | | | | | | | | | |
| 08 | 08 | 20/12/08 | 0 | 270 | 1800 | 100 | 1.00 | < 0.002 | |
| Location: HEPA-Mainway Exhaust Bank #2 (Prp) | | | | | | | | | |
| 09 | 09 | 20/12/08 | 0 | 270 | 1800 | 100 | 1.16 | < 0.002 | |
| Location: HEPA-Mainway Exhaust Bank #3 (Prp) | | | | | | | | | |
| 10 | 10 | 20/12/08 | 0 | 310 | 1800 | 100 | 1.70 | < 0.001 | |
| Location: Primary Down Clean Room (Prp) | | | | | | | | | |
| 11 | 11 | 20/12/08 | 0 | 310 | 1800 | 100 | 1.18 | < 0.001 | |
| Location: 8' From Deco Entrance / East (Dor) | | | | | | | | | |

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results


A281048: Sherman Plaza, 4650 Broadway, 2nd Floor 2nd Phase (Prp, Dur)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/13/08 | 6 | 306 | 1848 | 100 | 3 | 3.82 | < 0.001 | |
| Location: 6' From Waste Decon Airlock (Dur) | | | | | | | | | | |
| 13 | 13 | 05/13/08 | 6 | 304 | 1824 | 100 | 5 | 7.64 | 0.002 | |
| Location: OB Southwest Of Building (Dur) | | | | | | | | | | |
| 14 | 14 | 05/13/08 | 6 | 300 | 1800 | 100 | 4 | 5.10 | < 0.001 | |
| Location: OA Northwest Of Work Area By CB (Dur) | | | | | | | | | | |
| 15 | 15 | 05/13/08 | 6 | 295 | 1776 | 100 | 4 | 5.10 | < 0.002 | |
| Location: OA East Of Work Area By CB (Dur) | | | | | | | | | | |
| 16 | 16 | 05/13/08 | 6 | 292 | 1752 | 100 | 5 | 6.37 | < 0.002 | |
| Location: HEPA Microtrap Exhaust Bank #1 (Dur) | | | | | | | | | | |
| 17 | 17 | 05/13/08 | 6 | 288 | 1728 | 100 | 3 | 3.82 | < 0.002 | |
| Location: HEPA Microtrap Exhaust Bank #2 (Dur) | | | | | | | | | | |
| 18 | 18 | 05/13/08 | 6 | 284 | 1704 | 100 | 4 | 5.10 | < 0.002 | |
| Location: HEPA Microtrap Exhaust Bank #3 (Dur) | | | | | | | | | | |
| 19 | 19 | 05/13/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 20 | 20 | 05/13/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94 Using an Olympus Model CH3 PCM microscope, Serial #DA0076, Analyzed by: Patrick D. Toomey. Date Analyzed: 5/14/2008.
 Limit of Detection = 5.5 fibers /100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report reports ONLY to the sample analysis expressed as Fibers/cc per of filter area. ND=No fibers observed. NA=Not Analyzed; Volume-Reclett grossie field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of shift; not sampled; Upper 95% Confidence limit (Employers Compliance Test)- Calculated as a one sided UCL to determine 95% certainty of compliance with the 0.01 fibers/cc standard. Estimated RSD: Interlab Se=0.40, IntraLab Se=0.40, IntraLab Se=0.40, (NY ELAP Lab 11480, AIBIA Lab # 102843)



Reviewed By: *[Signature]*
 END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 15, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208052853
P.O. #A281048
A281048; Sherman Plaza, 4650 Broadway / 2nd Floor Phase #2 (Dur)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Thursday, May 15, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18

The 18 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in black ink that reads "JK for MB". The signature is written in a cursive, somewhat stylized font.

Marvin E. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results
 A281048: Sherman Plaza, 4600 Broadway / 2nd Floor Phase #2 (Dur)

| AmproSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (mins) | Air Filtered (liters) | Fibers | Fibers Density (Maximum #) | Fibers Count (Planned) |
|--|-----------------|----------------|------------------------|-----------------|-----------------------|--------|----------------------------|------------------------|
| 21 | 01 | 05/14/08 | 8 | 310 | 1800 | 100 | 19.11 | 0.004 |
| Location: Personal Decos Clean Room | | | | | | | | |
| 22 | 02 | 05/14/08 | 8 | 310 | 1800 | 100 | 19.05 | 0.003 |
| Location: #7 from Decos Entry / Exit | | | | | | | | |
| 23 | 03 | 05/14/08 | 8 | 310 | 1800 | 100 | 12.74 | 0.003 |
| Location: OA T From Waste Direct Pitcock | | | | | | | | |
| 24 | 04 | 05/14/08 | 8 | 310 | 1800 | 100 | 7.64 | 0.003 |
| Location: OA Exit Of Wash Area CB | | | | | | | | |
| 25 | 05 | 05/14/08 | 8 | 310 | 1800 | 100 | 20.28 | 0.004 |
| Location: O9 South Of Building | | | | | | | | |
| 26 | 06 | 05/14/08 | 8 | 310 | 1800 | 100 | 11.40 | 0.003 |
| Location: H21A Microcos Exhaust Bank #1 | | | | | | | | |
| 27 | 07 | 05/14/08 | 8 | 310 | 1800 | 100 | 10.79 | 0.003 |
| Location: H21A Microcos Bank #2 | | | | | | | | |
| 28 | 08 | 05/14/08 | 8 | 310 | 1800 | 100 | 8.30 | 0.003 |
| Location: Microcos Exhaust Bank #3 | | | | | | | | |
| 29 | 09 | 05/14/08 | 8 | 334 | 2004 | 100 | 7.44 | 0.001 |
| Location: Personal Decos Clean Room | | | | | | | | |
| 10 | 10 | 05/14/08 | 8 | 303 | 1848 | 100 | 15.17 | 0.004 |
| Location: #7 From Decos Exit / Exit | | | | | | | | |
| 11 | 11 | 05/14/08 | 8 | 305 | 1868 | 100 | 21.80 | 0.004 |
| Location: OA T From Waste Decos Pitcock | | | | | | | | |

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A281048: Sherman Plaza, 4650 Broadway / 2nd Floor Phase #2 (Dur)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/14/08 | 6 | 322 | 1932 | 100 | 18.5 | 23.57 | 0.005 | |
| Location: OA East Of Work Area By CB | | | | | | | | | | |
| 13 | 13 | 05/14/08 | 6 | 318 | 1908 | 100 | 5 | 6.37 | < 0.001 | |
| Location: OB South Of Building | | | | | | | | | | |
| 14 | 14 | 05/14/08 | 6 | 314 | 1884 | 100 | 2 | 2.55 | < 0.001 | |
| Location: HEPA Microtrap Exhaust Bank #1 | | | | | | | | | | |
| 15 | 15 | 05/14/08 | 6 | 310 | 1860 | 100 | 3 | 3.82 | < 0.001 | |
| Location: HEPA Microtrap Exhaust Bank #2 | | | | | | | | | | |
| 16 | 16 | 05/14/08 | 6 | 306 | 1836 | 100 | 5 | 6.37 | < 0.001 | |
| Location: HEPA Microtrap Exhaust Bank #3 | | | | | | | | | | |
| 17 | 17 | 05/14/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 18 | 18 | 05/14/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus, Model CH5 PCM microscope, Serial #0A0076; Analyzed by Tatyana Grinichak (g8)

Limit of Detection = 5.5 fibers /100 fields or 7 fibers/cm². Blank analyses are reported when available, however are not used to adjust results of associated samples from report. This report releases OHS 19 to the sample analysts expressed as fibers/cc and of fiber area. ND=No Fibers observed. NA= Not Analyzed. Walton-Beckett particle field area = 0.00785 mm². TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance Test). Calculated as a one sided 95% to determine 95% certainty of compliance with the 0.01 fibers/cc standard. Estimated BSD: Interlab Se=0.43, IntraLab Se=0.43, (NY ELAP Lab 11480, AIIA Lab # 10383)

Reviewed By:  END OF REPORT

Date Analyzed: 5/15/2008.



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8800 • FAX: (212) 679-9392

May 17, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208053100
P.O. #A281048
A281048; Sherman Plaza, 4650 Broadway; 2nd Floor, Phase #2; During

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Friday, May 16, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18

The 18 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results

4281548: Sherman Plaza, 4850 Broadway, 2nd Floor, Phase #2, During

| AmesSol Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtrated (Fibers) | Fibers | Fiber Density (Fibers/cm ²) | Fibers Count (Fibers/cm ²) | TWA |
|---|-----------------|----------------|-------------------------|-----------------|------------------------|--------|---|--|-----|
| 01 | 01 | 06/15/08 | 0 | 325 | 1863 | 100 | 1.64 | 0.000 | |
| Location: Personal Distro Clean Room | | | | | | | | | |
| 02 | 02 | 06/15/08 | 0 | 325 | 1850 | 100 | 10.18 | 0.000 | |
| Location: 0 From Distro Entry Room | | | | | | | | | |
| 03 | 03 | 06/15/08 | 0 | 325 | 1865 | 100 | 8.31 | < 0.001 | |
| Location: 3 From Waste Distro Area/02 | | | | | | | | | |
| 04 | 04 | 06/15/08 | 0 | 324 | 1844 | 100 | 11.46 | 0.000 | |
| Location: 0A East of Work Area By 02 | | | | | | | | | |
| 05 | 05 | 06/15/08 | 0 | 324 | 1844 | 100 | 11.46 | 0.001 | |
| Location: 0B South of Building | | | | | | | | | |
| 06 | 06 | 06/15/08 | 0 | 324 | 1848 | 100 | 20.28 | 0.004 | |
| Location: HEPA Microarray Exhaust Bank #1 | | | | | | | | | |
| 07 | 07 | 06/15/08 | 0 | 324 | 1844 | 100 | 1.79 | < 0.001 | |
| Location: HEPA Microarray Exhaust Bank #1 | | | | | | | | | |
| 08 | 08 | 06/15/08 | 0 | 324 | 1844 | 100 | 8.73 | < 0.001 | |
| Location: Microarray Exhaust Bank #2 | | | | | | | | | |
| 09 | 09 | 06/15/08 | 0 | 178 | 2214 | 100 | 2.52 | 1.000 | |
| Location: Personal Distro Clean Room | | | | | | | | | |
| 10 | 10 | 06/16/08 | 0 | 178 | 2228 | 100 | 8.27 | < 0.000 | |
| Location: 0 From Distro Entry Room | | | | | | | | | |
| 11 | 11 | 06/15/08 | 0 | 171 | 1028 | 100 | 6.40 | < 0.000 | |
| Location: 3 From Waste Distro Area/02 | | | | | | | | | |

Phase Contrast Microscopy (PCM) Fiber Results

A261048; Sherman Plaza, 4550 Broadway, 2nd Floor, Phase #2; During

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (filters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--------------------------------------|-----------------|----------------|-------------------------|-----------------|------------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/15/08 | 6 | 168 | 1008 | 100 | 6 | 7.64 | 0.003 | |
| Location: OA East Of Work Area By CB | | | | | | | | | | |
| 13 | 13 | 05/15/08 | 6 | 164 | 984 | 100 | 2 | 2.55 | < 0.003 | |
| Location: OB South Of Building | | | | | | | | | | |
| 14 | 14 | 05/15/08 | 6 | 160 | 960 | 100 | 1 | 1.27 | < 0.003 | |
| Location: HEPA Microtrap Exhaust #1 | | | | | | | | | | |
| 15 | 15 | 05/15/08 | 6 | 156 | 936 | 100 | 2 | 2.55 | < 0.003 | |
| Location: HEPA Microtrap Exhaust #2 | | | | | | | | | | |
| 16 | 16 | 05/15/08 | 6 | 152 | 912 | 100 | 3 | 3.82 | < 0.003 | |
| Location: HEPA Microtrap Exhaust #2 | | | | | | | | | | |
| 17 | 17 | 05/15/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 18 | 18 | 05/15/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/13/04: Using an Olympus Model CTS PCM microscope, Serial P0A0076, Analyzed by Karen Moran
 Limit of Detection = 5.5 fibers/100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc units of fiber area. ND = No fibers observed; N/A = Not Analyzed; W/B = Blanket particle field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance Test) - Calculated and divided UCL to determine 95% certainty of compliance with the OSHA fiber/cc standard. Enumated RSD: Internal SR-0.45, (NY ELAP Lab 11480, ARHA Lab # 102843)

Date Analyzed: 5/17/2008

Reviewed By: _____
 END OF REPORT



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 20, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208053472
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza 2nd Floor Phase #2 (During)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Tuesday, May 20, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18

The 18 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
PCM Manager

Phase Contrast Microscopy (PCM) Fiber Results

A2281040, 4850 Broadway, Sherman Plaza 2nd Floor (Phase #2) (During)

| Analysis Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min.) | As Filament (liters) | Fibers | Filament | Fiber Density (Fibers/cm ³) | Fiber Count (Fibers/cm ³) | TYVA |
|-------------------------------------|-----------------|----------------|------------------------|-----------------|----------------------|--------|----------|---|---------------------------------------|------|
| 01 | 01 | 08/15/08 | 0 | 240 | 1440 | 100 | 0 | 0.00 | 0.000 | |
| Location: Personal Decor Clean Room | | | | | | | | | | |
| 02 | 02 | 08/15/08 | 0 | 240 | 1440 | 100 | 0 | 0.00 | 0.000 | |
| Location: #1 From Decor Exit (E4) | | | | | | | | | | |
| 03 | 03 | 08/15/08 | 0 | 240 | 1440 | 100 | 0 | 0.00 | 0.000 | |
| Location: #2 From Waste Decor Aisle | | | | | | | | | | |
| 04 | 04 | 08/15/08 | 0 | 240 | 1440 | 100 | 0 | 0.00 | 0.000 | |
| Location: 04 End Of Walk Area By CB | | | | | | | | | | |
| 05 | 05 | 08/15/08 | 0 | 240 | 1440 | 100 | 0 | 0.00 | 0.000 | |
| Location: 05 South Of Building | | | | | | | | | | |
| 06 | 06 | 08/15/08 | 0 | 240 | 1440 | 100 | 0 | 0.00 | 0.000 | |
| Location: 06VA Meeting Entrance #1 | | | | | | | | | | |
| 07 | 07 | 08/15/08 | 0 | 240 | 1440 | 100 | 0 | 0.00 | 0.000 | |
| Location: 07VA Meeting Entrance #2 | | | | | | | | | | |
| 08 | 08 | 08/15/08 | 0 | 240 | 1440 | 100 | 0 | 0.00 | 0.000 | |
| Location: 08VA Meeting Entrance #3 | | | | | | | | | | |
| 09 | 09 | 08/15/08 | 0 | 204 | 1020 | 100 | 0 | 0.00 | 0.000 | |
| Location: Personal Decor Clean Room | | | | | | | | | | |
| 10 | 10 | 08/15/08 | 0 | 200 | 1000 | 100 | 0 | 0.00 | 0.000 | |
| Location: #1 From Decor Exit (E4) | | | | | | | | | | |
| 11 | 11 | 08/15/08 | 0 | 240 | 1440 | 100 | 0 | 0.00 | 0.000 | |
| Location: #2 From Waste Decor Aisle | | | | | | | | | | |

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A281048: 4650 Broadway, Sherman Plaza 2nd Floor Phase #2 (During)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--------------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/19/08 | 6 | 242 | 1452 | 100 | 2 | 2.55 | < 0.002 | |
| Location: OA East Of Work Area By CB | | | | | | | | | | |
| 13 | 13 | 05/19/08 | 6 | 238 | 1428 | 100 | 10 | 12.74 | 0.003 | |
| Location: OB South Of Building | | | | | | | | | | |
| 14 | 14 | 05/19/08 | 6 | 234 | 1404 | 100 | 17 | 21.66 | 0.006 | |
| Location: HEPA Microtrap Exhaust #1 | | | | | | | | | | |
| 15 | 15 | 05/19/08 | 6 | 230 | 1380 | 100 | 4 | 5.10 | < 0.002 | |
| Location: Microtrap Exhaust #2 | | | | | | | | | | |
| 16 | 16 | 05/19/08 | 6 | 226 | 1356 | 100 | 14 | 17.83 | 0.005 | |
| Location: Microtrap Exhaust #3 | | | | | | | | | | |
| 17 | 17 | 05/19/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 18 | 18 | 05/19/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue 07, 8/15/94; Using an Olympus Model CH5 PCM microscope, Serial #0A0076, Analyzed by: Tatyana Grinchak, Date Analyzed: 5/20/2008.
 Limit of Detection= 5.5 (fibers /100 fields or 7 fibers/mm²). Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc mm of filter area. ND=No fibers observed. NA= Not Analyzed. Wilson-Bedden particle field area = 0.00785 mm². TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance Test)- Calculated as a one sided UCL to determine 95% certainty of compliance with the 0.01 fibers/cc standard. Estimated RSD: (method S=0.405, Interlab S=0.45, (NY ELAP Lab 11480, AIBIA Lab # 102843).



Reviewed By:  END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 22, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208053756
P.O. #A281048
A281048; 4850 Broadway, Sherman Plaza - 2nd Floor, Phase #2 (DUR)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, May 21, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18

The 18 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marvin E. Brothers". The signature is stylized and fluid, with a long, sweeping tail that loops back to the right.

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A281048: 4550 Broadway, Sturman Plaza - 2nd Floor, Phase #2 (DUR)

| AmesCol Sample # | Client Sample # | Date Collected | Flow Rate (m/min) | Duration (min) | As Filtered (Hrs) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/μl) |
|---|-----------------|----------------|-------------------|----------------|-------------------|--------|--------|---|--------------------------|
| 01 | 01 | 05/02/08 | 6 | 200 | 1000 | 100 | 8 | 0.37 | < 0.000 |
| Location: Personal D/Cen Clean Room | | | | | | | | | |
| 02 | 02 | 05/02/08 | 6 | 200 | 1000 | 100 | 3 | 3.43 | < 0.000 |
| Location: OA # From D/Cen Entry Hall | | | | | | | | | |
| 03 | 03 | 05/02/08 | 6 | 200 | 1000 | 100 | 4 | 5.79 | < 0.000 |
| Location: OA # From Nearby D/Cen Area | | | | | | | | | |
| 04 | 04 | 05/02/08 | 6 | 200 | 1000 | 100 | 2 | 3.83 | < 0.000 |
| Location: OA East Of Work Area By O2 | | | | | | | | | |
| 05 | 05 | 05/02/08 | 6 | 200 | 1000 | 100 | 0 | 0.37 | < 0.000 |
| Location: OA South Of Building | | | | | | | | | |
| 06 | 06 | 05/02/08 | 6 | 200 | 1000 | 100 | 4.8 | 0.79 | < 0.000 |
| Location: Hiss Mass Top Exhaust Duct #1 | | | | | | | | | |
| 07 | 07 | 06/02/08 | 6 | 200 | 1000 | 100 | 1 | 3.83 | < 0.000 |
| Location: Hiss Mass Top Exhaust #2 | | | | | | | | | |
| 08 | 08 | 05/02/08 | 6 | 200 | 1000 | 100 | 1 | 3.83 | < 0.000 |
| Location: Hiss Mass Exhaust #3 | | | | | | | | | |
| 09 | 09 | 05/02/08 | 6 | 200 | 1000 | 100 | 1 | 2.36 | < 0.000 |
| Location: Personal D/Cen Clean Room | | | | | | | | | |
| 10 | 10 | 05/02/08 | 6 | 244 | 1000 | 100 | 4 | 0.79 | < 0.000 |
| Location: OA # From D/Cen Entry / Exit | | | | | | | | | |
| 11 | 11 | 05/02/08 | 6 | 200 | 1000 | 100 | 1 | 3.83 | < 0.000 |
| Location: OA # From Waste D/Cen Area | | | | | | | | | |



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 22, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208053755
P.O. #A281048
A281048; 4650 Broadway Sherman Plaza, 2nd Floor Phase 2 (CLR)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, May 21, 2008, for a 12 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14

The 14 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marvin E. Brothers". The signature is stylized with a large, sweeping flourish at the end.

Marvin E. Brothers
Operations Supervisor

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results
 A281048: 4500 Broadway Sherman Plaza, 2nd Floor Phase 2 (CLR)

| AmeriSol Sample # | Client Sample # | Date Collected | Flow Rate (m3/min) | Duration (min) | Air Filtered (Blank) | Fibers | Filament | Fiber Density (Fibers/cm ²) | Fibers Conc (Fibers/cc) | TWA |
|--|-----------------|----------------|--------------------|----------------|----------------------|--------|----------|---|-------------------------|-----|
| 01 | 01 | 05/21/08 | 13 | 150 | 1600 | 100 | 84 | 107.01 | 0.023 | |
| Location: 1A South - East from Work Area | | | | | | | | | | |
| 02 | 02 | 05/21/08 | 13 | 150 | 1600 | 100 | 90 | 121.29 | 0.028 | |
| Location: 1B South - West from Work Area | | | | | | | | | | |
| 03 | 03 | 05/21/08 | 13 | 150 | 1600 | 100 | 50 | 176.11 | 0.007 | |
| Location: 1C North - West from Work Area | | | | | | | | | | |
| 04 | 04 | 05/21/08 | 12 | 150 | 1600 | 100 | 77 | 86.09 | 0.001 | |
| Location: 1A South By Building E1 (1st Fl) | | | | | | | | | | |
| 05 | 05 | 05/21/08 | 12 | 150 | 1600 | 100 | 88 | 123.89 | 0.028 | |
| Location: 1A West By Window 2nd Fl | | | | | | | | | | |
| 06 | 06 | 05/21/08 | 12 | 150 | 1600 | 100 | 86 | 124.84 | 0.007 | |
| Location: 0B South Of Building Sherman E2 | | | | | | | | | | |
| 07 | 07 | 05/21/08 | 13 | 150 | 1600 | 100 | 70 | 100.84 | 0.003 | |
| Location: 0A East Of Work By CH | | | | | | | | | | |
| 08 | 08 | 05/21/08 | 12 | 150 | 1600 | 100 | 67 | 66.26 | 0.018 | |
| Location: 0A North Of Work Area | | | | | | | | | | |
| 09 | 09 | 05/21/08 | 12 | 150 | 1600 | 100 | 79 | 38.54 | 0.006 | |
| Location: 0A E' from Work Area | | | | | | | | | | |
| 10 | 10 | 05/21/08 | 13 | 150 | 1600 | 100 | 81 | 100.18 | 0.000 | |
| Location: 0A West from Trip Exhaust #1 | | | | | | | | | | |
| 11 | 11 | 05/21/08 | 12 | 100 | 1600 | 100 | 60 | 114.03 | 0.000 | |
| Location: 0A Micro-Trip Exhaust from #2 | | | | | | | | | | |

See following pages on test page

Phase Contrast Microscopy (PCM) Fiber Results
 A281048; 4650 Broadway Sherman Plaza, 2nd Floor Phase 2 (CLR)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/21/08 | 12 | 150 | 1800 | 100 | 88 | 112.10 | 0.024 | |
| Location: OA Micro Trap Exhaust Bank #3 | | | | | | | | | | |
| 13 | 13 | 05/21/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |
| Location: Field Blank | | | | | | | | | | |
| 14 | 14 | 05/21/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |
| Location: Field Blank | | | | | | | | | | |
| | | | | | | | | | | Footnotes: 1 |
| | | | | | | | | | | Footnotes: 1 |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94; Using an Olympus, Model CH5 PCM microscope, Serial #0A0076, Analyzed by: Kenneth R. Harrell
 Limit of Detection= 3.3 fibers/100 fields or 7 fibers/mm²; Blank analyzers are reported when available, however are not used to adjust results of associated samples in this report. This report releases ONLY to the sample analysis expressed as fibers/cc unless of
 filter area: ND--No fibers observed; NA-- Not Analyzed; WA--Blank; W--particle field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence limit (Employers Compliance
 Test)- Calculated from one sided UCL to determine 95% compliance of compliance with the 0.01 fiber/cc standard; Estimated RSD: IntraLab Ss-0.45, InterLab Ss-0.45, (NY ELAP Lab 11480, ABHA Lab # 102843)
 Date Analyzed: 5/22/2008.

Reviewed By:  _____ END OF REPORT _____



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 22, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208053754
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza - 2nd Floor Phase #2 (CLR)

Dear Charles Powers:

Enclosed are the results for TEM fiber analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, May 21, 2008, for a 12 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14

The 14 air samples were sent to AmeriSci via Hand Delivered. These samples were prepared according to AHERA Protocol.

Table I represents a summary of all pertinent information used for the structure (fiber) density and concentration calculations. Included are the size of each structure counted, the structure density and concentration, type of fibrous material detected and the analytical sensitivity, which represents the concentration by the detection of one structure in the TEM structure count. Copies of the Fiber Count Sheets are included. These data sheets contain information for structure length/width, structure type, structure morphology and pertinent information on EDS, SAED and photography.

This report relates ONLY to the sample analysis expressed as structure density. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci, NVLAP or any agency of the U. S. Government. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the written approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Paul Mucha". The signature is fluid and cursive, written over a horizontal line.

Paul J. Mucha
Laboratory Director

Table I
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
 A281048; 4650 Broadway, Sherman Plaza - 2nd Floor Phase #2 (CLR)

| AmeriSci Sample # | Client Sample # | Location | Dilution Factor | Air Filtered (liters) | Area Analyzed (sq. mm.) | Analytical Sensitivity (struc/cc air) | Asbestos Structures Detected (Microns) | | Structure Density (struc/sq mm) | Structure Concentration (sinuc/cc air) | | Type of Asbestos |
|-------------------|-----------------|--|-----------------|-----------------------|-------------------------|---------------------------------------|--|-------|---------------------------------|--|---------|------------------|
| | | | | | | | 0.5-5.0 | >=5.0 | | >=5.0 | Total | |
| 01 inside | 01 | Location: IA South - East Inside Work Area | | 1350 | .06 | 0.0048 | 0.0 | 0.0 | <16.7 | <16.7 | <0.0048 | NSD |
| 02 inside | 02 | Location: IA South - West Inside Work Area | | 1350 | .06 | 0.0048 | 0.0 | 0.0 | <16.7 | <16.7 | <0.0048 | NSD |
| 03 inside | 03 | Location: IA North - West Inside Work Area | | 1350 | .06 | 0.0048 | 2.0 | 2.0 | <16.7 | 33.3 | 0.0095 | chrysotile |
| 04 inside | 04 | Location: IA North By Stairway To 1st Fl | | 1350 | .06 | 0.0048 | 0.0 | 0.0 | <16.7 | <16.7 | <0.0048 | NSD |
| 05 inside | 05 | Location: IA West Inside Work Area By Window | | 1350 | .06 | 0.0048 | 0.0 | 0.0 | <16.7 | <16.7 | <0.0048 | NSD |
| 06** | 06 | Location: OB South Of Building Sherman St | | 1350 | | | | | | | | |
| 07** | 07 | Location: OA East Of Work Area By CB | | 1350 | | | | | | | | |
| 08** | 08 | Location: OA North Of Work Area | | 1350 | | | | | | | | |
| 09** | 09 | Location: OA 6' From Waste D/Con By Airlock | | 1350 | | | | | | | | |
| 10** | 10 | Location: OA Micro Trap Exhaust Bank #1 | | 1350 | | | | | | | | |
| 11** | 11 | Location: OA Micro Trap Exhaust Bank 2 | | 1350 | | | | | | | | |
| 12** | 12 | Location: OA Micro Trap Exhaust Bank 3 | | 1350 | | | | | | | | |
| 13** | 13 | Location: Field Blank | | 0 | | | | | | | | |

* concentration represented by the detection of 1 structure
 ** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By:  ; Analyzed By:  Date: 5/22/08
 Victor Slopac

Table I

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

A281048; 4650 Broadway, Sherman Plaza - 2nd Floor Phase #2 (CLR)

| AmeriSci Sample # | Client Sample # | Dilution Factor | Air Filtered (liters) | Area Analyzed (sq. mm.) | Analytical Sensitivity (struc/cc air) | Asbestos Structures Detected (Microns) | Structure Density (struc/sq mm) | Structure Concentration (struc/cc air) | Type of Asbestos |
|-------------------|-----------------|-----------------|-----------------------|-------------------------|---------------------------------------|--|---------------------------------|--|------------------|
| 14** | 14 | | 0 | | | 0.5-5.0 | Total >=5.0 | Total >=5.0 | |

Location: Field Blank

* concentration represented by the detection of 1 structure

** not analyzed

NSD: No Asbestos Structures Detected

Signature

Reviewed By:

Analyzed By:

Signature
Victor Slepac

Mean Total Structure Density For Inside Samples: 6.6 structures/sq. mm.

Date: 5/22/08

TEM Asbestos (air) Count Sheet

sample area analyzed



| | | |
|--|----------|---|
| <u>Client Name:</u> CNS Management Corporation | | <u>Volume (liters):</u> 1 350.0 |
| <u>Job #:</u> 208053754 | | <u>Filter Type / Filter Area:</u> MCE 385 mm ² |
| <u>Lab Sample #:</u> 01 | | <u>Grid Opening Size:</u> 0.01000 mm ² |
| <u>Client Sample #:</u> 01 | | <u>Area Examined:</u> 0.06000 mm ² |
| <u>Received:</u> 05/21/08 | 22:36:00 | <u>Magnification:</u> 20,000 |
| <u>Date Analyzed:</u> 05/22/08 | | <u>Accelerating Voltage:</u> 100 KeV |
| <u>Scope #:</u> 7 | | |

Analysis Performed by: VS
Victor Slopac

| Location | Grid Opening | Fiber | Length μM | Width μM | Fiber Type | Morphology | EDS | Orient. | SAED | Photo |
|----------|--------------|-------|----------------------|---------------------|------------|------------|-----|---------|------|-------|
| A7-4/1C | 1 | NSD | | | | | | | ┌ | |
| A7-4/1E | 2 | NSD | | | | | | | ┌ | |
| A7-4/1F | 3 | NSD | | | | | | | ┌ | |
| A8-5/1C | 4 | NSD | | | | | | | ┌ | |
| A8-5/1E | 5 | NSD | | | | | | | ┌ | |
| A8-5/1F | 6 | NSD | | | | | | | ┌ | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|------------------------------------|--|----------------------------|---|
| Total Grid Openings: 6 | | | |
| Chrysotile Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures >=5 microns: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 16.7 | 0.0048 | <input checked="" type="checkbox"/> Particulate Even |

TEM Asbestos (air) Count Sheet

sample area analyzed



| | | |
|--|----------|---|
| <u>Client Name:</u> CNS Management Corporation | | <u>Volume (liters):</u> 1 350.0 |
| <u>Job #:</u> 208053754 | | <u>Filter Type / Filter Area:</u> MCE 385 mm ² |
| <u>Lab Sample #:</u> 02 | | <u>Grid Opening Size:</u> 0.01000 mm ² |
| <u>Client Sample #:</u> 02 | | <u>Area Examined:</u> 0.06000 mm ² |
| <u>Received:</u> 05/21/08 | 22:36:00 | <u>Magnification:</u> 20,000 |
| <u>Date Analyzed:</u> 05/22/08 | | <u>Accelerating Voltage:</u> 100 KeV |
| <u>Scope #:</u> 7 | | |

Analysis Performed by: *VS*
Victor Slopac

| Location | Grid Opening | Fiber | Length μm | Width μm | Fiber Type | Morphology | EDS | Orient. | SAED | Photo |
|----------|--------------|-------|----------------------|---------------------|------------|------------|-----|---------|------|-------|
| A9-4/1C | 1 | NSD | | | | | | | | |
| A9-4/1E | 2 | NSD | | | | | | | | |
| A9-4/1F | 3 | NSD | | | | | | | | |
| A10-3/1C | 4 | NSD | | | | | | | | |
| A10-3/1E | 5 | NSD | | | | | | | | |
| A10-3/1F | 6 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|---|---|-------------------------------|---|
| Total Grid Openings: 6 | | | |
| Chrysotile Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures \geq 5 microns: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 16.7 | 0.0048 | <input checked="" type="checkbox"/> Particulate Even |

TEM Asbestos (air) Count Sheet

sample area analyzed



| | | |
|--|----------|---|
| <u>Client Name:</u> CNS Management Corporation | | <u>Volume (liters):</u> 1 350.0 |
| <u>Job #:</u> 208053754 | | <u>Filter Type / Filter Area:</u> MCE 385 mm ² |
| <u>Lab Sample #:</u> 03 | | <u>Grid Opening Size:</u> 0.01000 mm ² |
| <u>Client Sample #:</u> 03 | | <u>Area Examined:</u> 0.06000 mm ² |
| <u>Received:</u> 05/21/08 | 22:36:00 | <u>Magnification:</u> 20,000 |
| <u>Date Analyzed:</u> 05/22/08 | | <u>Accelerating Voltage:</u> 100 KeV |
| <u>Scope #:</u> 7 | | |

Analysis Performed by: *VS*
 Victor Slopac

| Location | Grid Opening | Fiber | Length μm | Width μm | Fiber Type | Morphology | EDS | Orient. | SAED | Photo |
|----------|--------------|-------|----------------------|---------------------|------------|------------|--------------|---------|------|-------|
| B6-4/1C | 1 | NSD | | | | | | | | |
| B6-4/1E | 2 | NSD | | | | | | | | |
| B6-4/1F | 3 | 1 | 3.5 | 0.05 | Chrysotile | Fiber | "Mg, Si, Fe" | \ | \ | |
| B6-4/1F | 3 | 2 | 3.0 | 0.25 | Chrysotile | Bundle | "Mg, Si, Fe" | \ | \ | |
| B7-4/1C | 4 | NSD | | | | | | | | |
| B7-4/1E | 5 | NSD | | | | | | | | |
| B7-4/1F | 6 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|---|---|-------------------------------|---|
| Total Grid Openings: 6 | | | |
| Chrysotile Asbestos Structures: 2 | 33.3 | 0.0095 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures \geq 5 microns: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: 2 | 33.3 | 0.0095 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 16.7 | 0.0048 | <input checked="" type="checkbox"/> Particulate Even |

TEM Asbestos (air) Count Sheet

sample area analyzed



| | | |
|--|----------|---|
| <u>Client Name:</u> CNS Management Corporation | | <u>Volume (liters):</u> 1 350.0 |
| <u>Job #:</u> 208053754 | | <u>Filter Type / Filter Area:</u> MCE 385 mm ² |
| <u>Lab Sample #:</u> 04 | | <u>Grid Opening Size:</u> 0.01000 mm ² |
| <u>Client Sample #:</u> 04 | | <u>Area Examined:</u> 0.06000 mm ² |
| <u>Received:</u> 05/21/08 | 22:36:00 | <u>Magnification:</u> 20,000 |
| <u>Date Analyzed:</u> 05/22/08 | | <u>Accelerating Voltage:</u> 100 KeV |
| <u>Scope #:</u> 7 | | |

Analysis Performed by: *VS*
 Victor Slopac

| Location | Grid Opening | Fiber | Length μm | Width μm | Fiber Type | Morphology | EDS | Orient. | SAED | Photo |
|----------|--------------|-------|----------------------|---------------------|------------|------------|-----|---------|------|-------|
| B8-4/1B | 1 | NSD | | | | | | | | |
| B8-4/1C | 2 | NSD | | | | | | | | |
| B8-4/1E | 3 | NSD | | | | | | | | |
| B9-4/4C | 4 | NSD | | | | | | | | |
| B9-4/4E | 5 | NSD | | | | | | | | |
| B9-4/4F | 6 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|---|--|----------------------------|---|
| Total Grid Openings: 6 | | | |
| Chrysotile Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures \geq 5 microns: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 16.7 | 0.0048 | <input checked="" type="checkbox"/> Particulate Even |

TEM Asbestos (air) Count Sheet

sample area analyzed



| | | |
|--|----------|---|
| <u>Client Name:</u> CNS Management Corporation | | <u>Volume (liters):</u> 1 350.0 |
| <u>Job #:</u> 208053754 | | <u>Filter Type / Filter Area:</u> MCE 385 mm ² |
| <u>Lab Sample #:</u> 05 | | <u>Grid Opening Size:</u> 0.01000 mm ² |
| <u>Client Sample #:</u> 05 | | <u>Area Examined:</u> 0.06000 mm ² |
| <u>Received:</u> 05/21/08 | 22:36:00 | <u>Magnification:</u> 20,000 |
| <u>Date Analyzed:</u> 05/22/08 | | <u>Accelerating Voltage:</u> 100 KeV |
| <u>Scope #:</u> 7 | | |

Analysis Performed by: VS
Victor Slopac

| Location | Grid Opening | Fiber | Length μm | Width μm | Fiber Type | Morphology | EDS | Orient. | SAED | Photo |
|----------|--------------|-------|----------------------|---------------------|------------|------------|-----|---------|------|-------|
| B10-4/4C | 1 | NSD | | | | | | | ┌ | |
| B10-4/4E | 2 | NSD | | | | | | | ┌ | |
| B10-4/4F | 3 | NSD | | | | | | | ┌ | |
| C6-2/4E | 4 | NSD | | | | | | | ┌ | |
| C6-2/4F | 5 | NSD | | | | | | | ┌ | |
| C6-3/4F | 6 | NSD | | | | | | | ┌ | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|---|---|-------------------------------|---|
| Total Grid Openings: 6 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Chrysotile Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Amphibole Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Asbestos Structures \geq 5 microns: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Total Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Particulate Even |
| Analytical Sensitivity: | 16.7 | 0.0048 | |



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8800 • FAX: (212) 679-9392

May 22, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208053854
P.O. #A281048
A281048; 4650 Broadway; Sherman Plaza; 2nd Floor; Phase #2/Clearance

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Thursday, May 22, 2008, for an immediate turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12

The 12 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

AmeriSci Job #: 208053854

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A281048: 4650 Broadway, Sherman Plaza, 2nd Floor, Phase #2/Clearance

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|-----|
| 12 | 12 | 05/22/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |

Location: Field Blank

Footnotes: 1

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By: NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus, Model CH5 PCM microscope, Serial #QA0076, Analyzed by: Devita M. Alyce, Date Analyzed: 5/22/2008.
 Limit of Detection= 5.5 fibers /100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples unless they report. This report contains ONLY the sample analysis expressed as fibers/cc, mm of
 Fiber area: ND=No fibers observed; NA= Not Analyzed; W=When Beckett graticule field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence limit (Employers Compliance
 Text): Calculated at 1.0x Above UCL, so determines 95% probability of compliance with the 0.01 fiber/cc standard. Estimated RSD: Inmate Sp-0.405, Interlab Sp-0.55, (NY ELAP Lab 11480, ADMA Lab # 102843)

Reviewed By: 

END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016
TEL: (212) 679-8600 • FAX: (212) 679-9392

May 29, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208054448
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza; 1st Floor; Prep

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, May 28, 2008, for a 24 hour turnaround:

1, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14

The 14 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results
 A281040, 4650 Broadway, Sherman Plaza, 1st Floor, Proj

| AmesGA Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (Items) | Fibers | Fiber Density (Fibers/cm ²) | Fibers Count (Fibers/Spot) | TMA |
|--------------------------------------|-----------------|----------------|------------------------|----------------|----------------------|--------|---|----------------------------|-----|
| 01 | 1 | 05/27/08 | 8 | 253 | 1835 | 100 | 3.38 | 4,000 | |
| Location: Pumping Outlet Clean Room | | | | | | | | | |
| 02 | 02 | 05/27/08 | 8 | 254 | 1824 | 100 | 2.58 | 4,000 | |
| Location: OA W Firm Waste Down Aisle | | | | | | | | | |
| 03 | 03 | 05/27/08 | 8 | 254 | 1854 | 100 | 3.19 | 4,000 | |
| Location: East Of Work Area By CB | | | | | | | | | |
| 04 | 04 | 05/27/08 | 8 | 254 | 1824 | 100 | 4.48 | 4,000 | |
| Location: West Of Work Area By CB | | | | | | | | | |
| 05 | 05 | 05/27/08 | 8 | 254 | 1824 | 100 | 3.62 | 4,000 | |
| Location: CB South End Of Building | | | | | | | | | |
| 06 | 06 | 05/27/08 | 8 | 254 | 1824 | 100 | 5.37 | 4,000 | |
| Location: HEPA Make Up Room | | | | | | | | | |
| 07 | 07 | 05/27/08 | 8 | 249 | 1878 | 100 | 8.18 | 4,000 | |
| Location: Personal Clean Room | | | | | | | | | |
| 08 | 08 | 05/27/08 | 8 | 232 | 1868 | 100 | 3.82 | 4,000 | |
| Location: OA W Firm Waste Down Aisle | | | | | | | | | |
| 09 | 09 | 05/27/08 | 8 | 258 | 1828 | 100 | 3.59 | 4,000 | |
| Location: East Of Work Area By CB | | | | | | | | | |
| 10 | 10 | 05/27/08 | 8 | 278 | 1844 | 100 | 2.28 | 4,000 | |
| Location: West Of Work Area By CB | | | | | | | | | |
| 11 | 11 | 05/27/08 | 8 | 258 | 1828 | 100 | 3.62 | 4,000 | |
| Location: CB South End Of Building | | | | | | | | | |

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A281048: 4650 Broadway, Sherman Plaza, 1st Floor, Prep

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/27/08 | 6 | 216 | 1296 | 100 | 2.5 | 3.18 | < 0.002 | |
| Location: HEPA Vack Micro Trap Exhaust | | | | | | | | | | |
| 13 | 13 | 05/27/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |
| Location: Field Blank | | | | | | | | | | |
| 14 | 14 | 05/27/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| Footnotes: 1 | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/13/94; Using an Olympus, Model CHS PCM microscope, Serial #0A0076; Analyzed by: Kenneth R. Herxli

Limit of Detection - 1.5 fibers /100 fields or 7 fibers/ml; Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc or

filter area; ND=No fibers observed; N/A=Not analyzed; Within-Beckon particle field area = 0.00785 mm²; TWA = 8 hr TWA calculations assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence limit (Employer Compliance

Test)- Calculated as 1.66 x field area x fiber density; Estimated BSD: Estimated BSD: Interlab Sr-0.45, Interlab Sr-0.45, (NY ELAP Lab # 102843), (NY ELAP Lab # 102843)

Reviewed By:  END OF REPORT

Date Analyzed: 5/29/2008



AmeriSci N

117 EAST 30th

NEW YORK

TEL: (212) 679-8600 • FAX: (212)

May 24, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208054079
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza - 1st Floor - Prep

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples rec AmeriSci on Saturday, May 24, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12

The 12 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules user in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached rep summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived an upon written request. The National Institute of Standards and Technology Accreditation requirements, mandater report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

AmeriSci Job #: 208054079

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results
A281048; 4650 Broadway, Sherman Plaza - 1st Floor - Prep

Phase Contrast Microscopy (PCM) Fiber Results

A2B1048, 4650 Broadway, Sherman Plaza - 1st Floor - Prep

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|-----|
| 12 | 12 | 05/23/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |

Location: Field Blank

Footnotes: 1

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By MGS&H 7400(A) Method, Issue #2, 8/1/99; Using an Olympus, Model CHS PCM microscope, Serial #0A0076; Analyzed by: Devin M. Alyce *[Signature]*; Date Analyzed: 5/24/2008.
 Limit of Detection = 5.3 fibers /100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report retains ONLY to the sample analysis expressed as Fibers/cc sum of filter area. ND = No fibers observed. NA = Not Analyzed. ~~Blank~~ field area = 0.00785 mm². TWA = 8 hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance Test) - Calculated by ~~AM~~ *[Signature]* at 95% confidence of compliance with the 0.01 Fibers/cc standard. Estimated RSD: Intralab Sv=0.45, Interlab Sv=0.45, (NY ELAP Lab 11480, ARIIA Lab # 102843)

Reviewed By: *[Signature]* END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 29, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208054445
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza; 1st Floor; During

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, May 28, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/16/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marvin E. Brothers".

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A281048: 4800 Broadway, Sherman Plaza, 1st Floor, During

| AmorSol Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (liters) | Fibers | Fiber Density (Fibers/cm ²) | Fibers Cons. (Fibers/cm ³) | TWA |
|--|-----------------|----------------|------------------------|----------------|-----------------------|--------|---|--|-----|
| 01 | 01 | 05/20/08 | 0 | 210 | 1700 | 100 | 2.50 | < 0.002 | |
| Location: Personal DC/Jan Clean Room | | | | | | | | | |
| 02 | 02 | 05/20/08 | 0 | 210 | 1200 | 100 | 2.50 | < 0.002 | |
| Location: OA #7 From East To West Deck | | | | | | | | | |
| 03 | 03 | 05/20/08 | 0 | 210 | 1000 | 100 | 2.18 | < 0.002 | |
| Location: OA East Of Work Area By CB | | | | | | | | | |
| 04 | 04 | 05/20/08 | 0 | 210 | 1200 | 100 | 2.50 | < 0.002 | |
| Location: OA West Of Work Area By CB | | | | | | | | | |
| 05 | 05 | 05/20/08 | 0 | 210 | 1000 | 100 | 2.50 | < 0.002 | |
| Location: CB South Of Building | | | | | | | | | |
| 06 | 06 | 05/20/08 | 0 | 210 | 1000 | 100 | 2.50 | < 0.002 | |
| Location: Mechanical Exhaust Stack #1 | | | | | | | | | |
| 07 | 07 | 05/20/08 | 0 | 210 | 1000 | 100 | 2.50 | < 0.002 | |
| Location: Airway Exhaust #7 | | | | | | | | | |
| 08 | 08 | 05/20/08 | 0 | 214 | 1344 | 100 | 2.50 | < 0.002 | |
| Location: Personal DC/Jan Clean Room | | | | | | | | | |
| 09 | 09 | 05/20/08 | 0 | 205 | 1220 | 100 | 5.87 | < 0.002 | |
| Location: OA From West West Atrium | | | | | | | | | |
| 10 | 10 | 05/20/08 | 0 | 210 | 1200 | 100 | 2.50 | < 0.002 | |
| Location: OA East Of Work Area CB | | | | | | | | | |
| 11 | 11 | 05/20/08 | 0 | 213 | 1272 | 100 | 2.60 | < 0.002 | |
| Location: OA West Of Work Area By CB | | | | | | | | | |

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results
 A281048: 4650 Broadway, Sherman Plaza, 1st Floor, During

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/28/08 | 6 | 208 | 1248 | 100 | 3 | 3.82 | < 0.002 | |
| Location: OB South Of Building | | | | | | | | | | |
| 13 | 13 | 05/28/08 | 6 | 204 | 1224 | 100 | 2.5 | 3.18 | < 0.002 | |
| Location: Microtrap Exhaust Bank #1 | | | | | | | | | | |
| 14 | 14 | 05/28/08 | 6 | 200 | 1200 | 100 | 3 | 3.82 | < 0.002 | |
| Location: Microtrap Exhaust Bank #2 | | | | | | | | | | |
| 15 | 15 | 05/28/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 16 | 16 | 05/28/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

by MGSH 7400(A) Method, Issue #2, #13594. Using an Olympus, Model CH5 PCM microscope, Serial #0A0076; Analyzed by Kenneth R. Jarek
 Limit of Detection= 5.5 fibers /100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relies ONLY on the sample analysis expressed as fibers/cc (mm of filter area). ND=No fibers observed. NA=Not Analyzed. Method=Beckett particle field area = 0.00785 mm². TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance Test). Calculated by provided UCL spreadsheet. Estimated RSD: Interlab S=0.45, IntraLab S=0.485, Interlab S=0.45, (NY ELAP Lab 11480, ABIA Lab # 102843)

Revised By:  END OF REPORT

Date Analyzed: 5/29/2008



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 30, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208054643
P.O. #A281048
A281048; 4650 Broadway., Sherman Plaza - 1st Floor (Durings)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Friday, May 30, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 6/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Marvin E. Brothers". The signature is fluid and cursive, written over a light blue horizontal line.

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results
 A23104E - 4850 Broadway - Sherman Plaza - 1st Floor (Durling)

| Amesol Sample # | Client Sample # | Date Collected | Flow Rate (L/min) | Duration (min) | Air Filtered (liters) | Fraction | Fibers | Fiber Density (Fibers/cm ³) | Fiber Core (Fibers/cc) | TWA |
|--|-----------------|----------------|-------------------|----------------|-----------------------|----------|--------|---|------------------------|-----|
| 01 | 01 | 05/20/08 | 8 | 310 | 1828 | 100 | 2 | 2.59 | < 0.002 | |
| Location: Personal Decor Clean Room | | | | | | | | | | |
| 02 | 02 | 05/20/08 | 8 | 310 | 1828 | 100 | 4 | 5.18 | < 0.002 | |
| Location: CA # From Waste Decom Airtouch | | | | | | | | | | |
| 03 | 03 | 05/20/08 | 8 | 310 | 1828 | 100 | 8 | 7.64 | 0.002 | |
| Location: CA East Of Work Area By CB | | | | | | | | | | |
| 04 | 04 | 05/20/08 | 8 | 310 | 1828 | 100 | 5 | 6.37 | < 0.002 | |
| Location: CA West Of Work Area By CB | | | | | | | | | | |
| 05 | 05 | 05/20/08 | 8 | 310 | 1828 | 100 | 4 | 5.18 | < 0.002 | |
| Location: 40 South Of Building | | | | | | | | | | |
| 06 | 06 | 05/20/08 | 8 | 310 | 1828 | 100 | 4 | 7.64 | 0.002 | |
| Location: HEPA Mantle Exhaust 1 | | | | | | | | | | |
| 07 | 07 | 05/20/08 | 8 | 310 | 1828 | 100 | 5 | 6.37 | < 0.002 | |
| Location: HEPA Mantle Exhaust #2 | | | | | | | | | | |
| 08 | 08 | 05/20/08 | 8 | 310 | 1828 | 100 | 2 | 2.59 | < 0.002 | |
| Location: Personal System Clean Room | | | | | | | | | | |
| 09 | 09 | 05/20/08 | 8 | 320 | 1832 | 100 | 4 | 5.18 | < 0.002 | |
| Location: CA # From Waste Decom Airtouch | | | | | | | | | | |
| 10 | 10 | 05/20/08 | 8 | 310 | 1828 | 100 | 8 | 3.82 | < 0.002 | |
| Location: CA West Of Work Area By CB | | | | | | | | | | |
| 11 | 11 | 05/20/08 | 8 | 310 | 1828 | 100 | 4 | 5.18 | < 0.002 | |
| Location: CA East Of Work Area By CB | | | | | | | | | | |
| 12 | 12 | 05/20/08 | 8 | 310 | 1828 | 100 | 3 | 2.59 | < 0.002 | |
| Location: CB South Of Building | | | | | | | | | | |

Phase Contrast Microscopy (PCM) Fiber Results
 A281048; 4650 Broadway., Sherman Plaza - 1st Floor (Dairings)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 13 | 13 | 05/29/08 | 6 | 206 | 1236 | 100 | 3 | 3.82 | < 0.002 | |
| Location: HEPA Microtrap Exhaust #1 | | | | | | | | | | |
| 14 | 14 | 05/29/08 | 6 | 202 | 1212 | 100 | 5 | 6.37 | < 0.002 | |
| Location: HEPA Microtrap Exhaust #2 | | | | | | | | | | |
| 15 | 15 | 05/29/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 16 | 16 | 05/29/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/1/94. Using an Olympus, Model CH5 PCM microscope, Serial #0A0076. Analyzed by: Devin M. Ahyer, Date Analyzed: 5/29/2008.
 Limit of Detection= 3.5 fibers /100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc mm of fiber area. ND=No fibers observed. NA= Not Analyzed; Walton-Beecham particle field area = 0.00785 mm². TWA = 8 hr-TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance Test)- Calculated as a one sided UCL to determine 95% certainty of compliance with the 0.01 fibers/cc standard. Estimated RSD: Intralab Sr=0.405, Intralab Sr=0.45, (NY ELAP Lab 11480, ARIIA Lab # 102543)

Reviewed By:  END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

May 31, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208054860
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza; 1st Floor; During

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Saturday, May 31, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18

The 18 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marvin E. Brothers".

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A38104B, 4550 Broadway, Sherman Plaza, 1st Floor, During

| America's Sample # | Client Sample # | Date Collected | Flow Rate (ft/min) | Duration (min) | Air Filtered (ft ³) | Fields | Fibers | Fiber Density (Fibers/cm ²) | Fibers Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|--------------------|----------------|---------------------------------|--------|--------|---|--------------------------|-----|
| 01 | 01 | 05/20/08 | 8 | 300 | 1200 | 100 | 1 | 1.27 | < 0.001 | |
| Location: Personal D/Con Clean Room | | | | | | | | | | |
| 02 | 02 | 05/20/08 | 8 | 300 | 1200 | 100 | 3 | 3.80 | < 0.001 | |
| Location: OA W/ From Waste D/Con Airstock | | | | | | | | | | |
| 03 | 03 | 05/20/08 | 8 | 300 | 1200 | 100 | 1 | 1.27 | < 0.001 | |
| Location: OA East Of Work Area By CB | | | | | | | | | | |
| 04 | 04 | 05/20/08 | 8 | 300 | 1200 | 100 | 0 | 0.00 | 0.000 | |
| Location: OA West Of Work Area By CB | | | | | | | | | | |
| 05 | 05 | 05/20/08 | 8 | 300 | 1200 | 100 | 3 | 3.80 | < 0.001 | |
| Location: OA North Of Work Area | | | | | | | | | | |
| 06 | 06 | 05/20/08 | 8 | 300 | 1200 | 100 | 5.8 | 7.21 | 0.001 | |
| Location: CB South Of Building | | | | | | | | | | |
| 07 | 07 | 05/20/08 | 8 | 300 | 1200 | 100 | 4 | 5.12 | < 0.001 | |
| Location: HEPA Monitoring Exhaust #1 | | | | | | | | | | |
| 08 | 08 | 05/20/08 | 8 | 300 | 1200 | 100 | 3 | 3.80 | < 0.001 | |
| Location: HEPA Monitoring Exhaust #7 | | | | | | | | | | |
| 09 | 09 | 05/20/08 | 8 | 300 | 1200 | 100 | 4 | 5.12 | < 0.001 | |
| Location: Personal D/Con Clean Room | | | | | | | | | | |
| 10 | 10 | 05/20/08 | 8 | 300 | 1200 | 100 | 3 | 3.80 | < 0.001 | |
| Location: OA W/ From Waste D/Con Airstock | | | | | | | | | | |
| 11 | 11 | 05/20/08 | 8 | 300 | 1200 | 100 | 6.8 | 8.38 | 0.003 | |
| Location: OA East Of Work Area By CB | | | | | | | | | | |

Phase Contrast Microscopy (PCM) Fiber Results
 A281048, 4650 Broadway, Sherman Plaza, 1st Floor, During

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--------------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/30/08 | 6 | 196 | 1176 | 100 | 5 | 6.37 | < 0.002 | |
| Location: OA West Of Work Area By CB | | | | | | | | | | |
| 13 | 13 | 05/30/08 | 6 | 192 | 1152 | 100 | 3 | 3.82 | < 0.002 | |
| Location: OB South Of Building | | | | | | | | | | |
| 14 | 14 | 05/30/08 | 6 | 188 | 1128 | 100 | 1 | 1.27 | < 0.002 | |
| Location: OA North Of Work Area | | | | | | | | | | |
| 15 | 15 | 05/30/08 | 6 | 184 | 1104 | 100 | 2 | 2.55 | < 0.002 | |
| Location: HEPA Microtrap Exhaust #1 | | | | | | | | | | |
| 16 | 16 | 05/30/08 | 6 | 180 | 1080 | 100 | 4 | 5.10 | < 0.002 | |
| Location: HEPA Microtrap Exhaust #2 | | | | | | | | | | |
| 17 | 17 | 05/30/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 18 | 18 | 05/30/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #1, 8/15/94; Using an Olympus, Model CH15 PCM microscope, Serial #0A0076; Analyzed by: Kareem Moradei. Date Analyzed: 5/31/2008.
 Limit of Detection= 3.5 Fibers /100 folds or 7 fibers/mm²; Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates (ONLY) to the sample analysis expressed as fibers by mm of fiber area; ND=No Fibers observed; NA= Not Analyzed; Within-Blocker gradeable field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence limit (Employers Compliance Test)- Calculated as a one sided UCL to determine 95% certainty of compliance with the OEL Fibercyte standard: Estimated RSD: Intralab Sv=0.45, Interlab Sv=0.49, Interlab Sv=0.45, (NY ELAP Lab H1480, AIBHA Lab # 102843)

Reviewed By:  _____ END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

June 3, 2008

CNS Management Corporation
Attn: Charles Powers
560 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208061153
P.O. #A281048
A281048; 4650 Broadway Sherman Plaza 1st Floor (During)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Tuesday, June 03, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results
 A281048: 4650 Broadway Sherman Plaza 1st Floor (During)

| AmeriSol Sample # | Client Sample # | Date Collected | Flow Rate (m ³ /min.) | Duration (min.) | Air Filtered (Meters) | Fields | Fibers | Fiber Density (Fibers/cm ²) | Fibers Count (Standard) | TWA |
|--------------------------------------|-----------------|----------------|----------------------------------|-----------------|-----------------------|--------|--------|---|-------------------------|-----|
| 01 | 01 | 05/05/08 | 0 | 300 | 1000 | 100 | 4 | 0.10 | < 0.001 | |
| Location: Pumping Station Clean Room | | | | | | | | | | |
| 02 | 02 | 05/05/08 | 0 | 300 | 1000 | 100 | 3 | 0.37 | < 0.001 | |
| Location: OA @ From Waste Decon Area | | | | | | | | | | |
| 03 | 03 | 05/05/08 | 0 | 300 | 1000 | 100 | 3 | 3.58 | < 0.001 | |
| Location: OA East of Work Area | | | | | | | | | | |
| 04 | 04 | 05/05/08 | 0 | 300 | 1000 | 100 | 3 | 3.63 | < 0.001 | |
| Location: OA West of Work Area | | | | | | | | | | |
| 05 | 05 | 03/05/08 | 0 | 300 | 1000 | 100 | 4 | 2.10 | < 0.001 | |
| Location: OB South of Building | | | | | | | | | | |
| 06 | 06 | 03/05/08 | 0 | 300 | 1000 | 100 | 3 | 2.55 | < 0.001 | |
| Location: HCHM Monitors Exhaust #1 | | | | | | | | | | |
| 07 | 07 | 04/05/08 | 0 | 300 | 1000 | 100 | 3 | 3.82 | < 0.001 | |
| Location: HCHM Monitors Exhaust #2 | | | | | | | | | | |
| 08 | 08 | 05/05/08 | 0 | 300 | 1000 | 300 | 3 | 0.37 | < 0.001 | |
| Location: Personal Decon Clean Room | | | | | | | | | | |
| 09 | 09 | 05/05/08 | 0 | 300 | 1212 | 100 | 4 | 0.10 | < 0.001 | |
| Location: OA @ From Waste Decon Area | | | | | | | | | | |
| 10 | 10 | 05/05/08 | 0 | 180 | 1188 | 100 | 3 | 2.55 | < 0.001 | |
| Location: OA East of Work Area | | | | | | | | | | |
| 11 | 11 | 05/05/08 | 0 | 180 | 1104 | 100 | 3 | 0.82 | < 0.001 | |
| Location: OA West of Work Area | | | | | | | | | | |

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results
 A281048: 4650 Broadway Sherman Plaza 1st Floor (During)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 05/06/08 | 6 | 180 | 1140 | 100 | 2 | 2.55 | < 0.002 | |
| Location: OB South Of Building | | | | | | | | | | |
| 13 | 13 | 05/06/08 | 6 | 186 | 1116 | 100 | 4 | 5.10 | < 0.002 | |
| Location: HEPA Microtrap Exhaust #1 | | | | | | | | | | |
| 14 | 14 | 05/06/08 | 6 | 182 | 1092 | 100 | 5 | 6.37 | < 0.002 | |
| Location: HEPA Microtrap Exhaust #2 | | | | | | | | | | |
| 15 | 15 | 05/06/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 16 | 16 | 05/06/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus, Model CHS PCM microscope, Serial #DA0076, Analyzed by: Devin M. Alyee. Date Analyzed: 6/3/2008.
 Limit of Detection= 5.5 fibers /100 fields or 7 fibers/field. Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates OAG, Y to the sample analysis expressed as fibers/cc mm of fiber area. ND= No fibers observed. NA= Not Analyzed. Validation= no particle field area = 0.00785 mm². TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance Test)- Calculated as 1.67x the UCL to determine 95% compliance of compliance with the 0.01 fibers/cc standard. Estimated RSD: IntraLab S=0.603, InterLab S=0.45, (NY EL/AP Lab 11480, AIHA Lab # 102843)

Reviewed By:  END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

June 4, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208061311
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza - 1st Floor - During

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, June 04, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marvin E. Brothers". The signature is fluid and cursive, with a long, sweeping tail that extends to the right.

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results
 A281048 - 4650 Broadway, Sherman Plaza - 1st Floor - During

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (Liters) | Faults | Fibers | Fiber Density (Fibers/Liter) | Fibers Count (Fibers/100L) | TWA |
|---------------------------------------|-----------------|----------------|------------------------|----------------|-----------------------|--------|--------|------------------------------|----------------------------|-----|
| 01 | 01 | 06/03/08 | 0 | 300 | 1000 | 100 | 3 | 3.00 | < 0.001 | |
| Location: Perimeter Down Clean Room | | | | | | | | | | |
| 02 | 02 | 06/03/08 | 0 | 300 | 1000 | 100 | 3 | 3.00 | < 0.001 | |
| Location: OA 0' From Waste Down Aisle | | | | | | | | | | |
| 03 | 03 | 06/03/08 | 0 | 300 | 1000 | 100 | 3 | 3.00 | < 0.001 | |
| Location: OA East Of Work Area | | | | | | | | | | |
| 04 | 04 | 06/03/08 | 0 | 300 | 1000 | 100 | 1.81 | 1.81 | < 0.001 | |
| Location: OA West Of Vest Area | | | | | | | | | | |
| 05 | 05 | 06/03/08 | 0 | 300 | 1000 | 100 | 3 | 3.00 | < 0.001 | |
| Location: CR South Of Building | | | | | | | | | | |
| 06 | 06 | 06/03/08 | 0 | 300 | 1000 | 100 | 3 | 3.00 | < 0.001 | |
| Location: HEPA Monitoring Exhaust #1 | | | | | | | | | | |
| 07 | 07 | 06/03/08 | 0 | 300 | 1000 | 100 | 3 | 3.00 | < 0.001 | |
| Location: HEPA Monitoring Exhaust #2 | | | | | | | | | | |
| 08 | 08 | 06/03/08 | 0 | 328 | 1418 | 100 | 3 | 3.00 | < 0.001 | |
| Location: Perimeter Down Clean Room | | | | | | | | | | |
| 09 | 09 | 06/03/08 | 0 | 328 | 1418 | 100 | 4 | 4.00 | < 0.001 | |
| Location: OA 0' From Waste Down Aisle | | | | | | | | | | |
| 10 | 10 | 06/03/08 | 0 | 328 | 1418 | 100 | 7 | 8.00 | 0.003 | |
| Location: OA East Of Work Area | | | | | | | | | | |
| 11 | 11 | 06/03/08 | 0 | 324 | 1344 | 100 | 8 | 7.84 | 0.003 | |
| Location: OA West Of Work Area | | | | | | | | | | |

Phase Contrast Microscopy (PCM) Fiber Results
 A281048; 4650 Broadway, Sherman Plaza - 1st Floor - During

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 06/03/08 | 6 | 220 | 1320 | 100 | 3 | 3.82 | < 0.002 | |
| Location: OB South Of Building | | | | | | | | | | |
| 13 | 13 | 06/03/08 | 6 | 216 | 1286 | 100 | 3 | 3.82 | < 0.002 | |
| Location: HEPA Microtrap Exhaust #1 | | | | | | | | | | |
| 14 | 14 | 06/03/08 | 6 | 212 | 1272 | 100 | 4 | 5.10 | < 0.002 | |
| Location: HEPA Microtrap Exhaust #2 | | | | | | | | | | |
| 15 | 15 | 06/03/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 16 | 16 | 06/03/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus, Model CB8 PCM microscope, Serial #0A10076, Analyzed by: Tatyana Grinshuk. Date Analyzed: 6/4/2008.
 Limit of Detection- 5.5 fibers /100 fields or 7 fibers/mm². Blank analysis are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc mm of filter area: ND=No fibers observed; NA= Not Analyzed; Value in checkmark indicates zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employee Compliance Test)- Calculated as a one-sided UCL to determine 95% probability of compliance with the 0.01 fiber/cc standard. Estimated RSD: Inertab SR-0.405, Inertab SR-0.45, (NY ELAP Lab 11489, AIHA Lab # 102843)

Reviewed By:  _____ END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-8392

June 5, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208061483
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza 1st Floor (During)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Thursday, June 05, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marvin E. Brothers". The signature is fluid and cursive, with the first name being the most prominent.

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results
 A251048: 4550 Broadway, Sherman Plaza 1st Floor (Damp)

| AmesSol Sample # | Client Sample # | Date Collected | Fiber Rate (Fibers/min.) | Duration (min.) | Air Filtered (ft/min) | Fuels | Fibers | Fiber Density (Fibers/mm ²) | Fiber Conc. (Fibers/cc) | TWA |
|---------------------------------------|-----------------|----------------|--------------------------|-----------------|-----------------------|-------|--------|---|-------------------------|-----|
| 01 | 01 | 06/04/08 | 8 | 302 | 1813 | 100 | 3 | 2.88 | < 0.001 | |
| Location: Personnel Design Clean Room | | | | | | | | | | |
| 02 | 02 | 06/04/08 | 8 | 305 | 1813 | 100 | 3 | 3.82 | < 0.001 | |
| Location: OA # From Waste Decan Area | | | | | | | | | | |
| 03 | 03 | 06/04/08 | 8 | 303 | 1812 | 100 | 3 | 2.99 | < 0.001 | |
| Location: OA East Of Wash Area | | | | | | | | | | |
| 04 | 04 | 06/04/08 | 8 | 302 | 1812 | 100 | 3.8 | 3.18 | < 0.001 | |
| Location: OA West Of Wash Area | | | | | | | | | | |
| 05 | 05 | 06/04/08 | 8 | 302 | 1812 | 100 | 3.8 | 1.91 | 0.001 | |
| Location: CR South Of Building | | | | | | | | | | |
| 06 | 06 | 06/04/08 | 8 | 302 | 1812 | 100 | 3 | 3.83 | < 0.001 | |
| Location: HEPA Makeup Exhaust #1 | | | | | | | | | | |
| 07 | 07 | 06/04/08 | 8 | 303 | 1812 | 100 | 3 | 3.83 | < 0.001 | |
| Location: HEPA Makeup Exhaust #2 | | | | | | | | | | |
| 08 | 08 | 06/04/08 | 8 | 304 | 1454 | 100 | 3.8 | 4.45 | < 0.002 | |
| Location: Personnel Decan Clean Room | | | | | | | | | | |
| 09 | 09 | 06/04/08 | 8 | 325 | 1550 | 100 | 4 | 8.70 | < 0.002 | |
| Location: OA # From Waste Decan Area | | | | | | | | | | |
| 10 | 10 | 06/04/08 | 8 | 328 | 1555 | 100 | 3 | 3.82 | < 0.002 | |
| Location: OA East Of Wash Area | | | | | | | | | | |
| 11 | 11 | 06/04/08 | 8 | 322 | 1300 | 100 | 4 | 8.19 | < 0.002 | |
| Location: OA West Of Wash Area | | | | | | | | | | |

Phase Contrast Microscopy (PCM) Fiber Results
 A281048; 4650 Broadway, Sherman Plaza 1st Floor (During)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 06/04/08 | 6 | 218 | 1306 | 100 | 4 | 5.10 | < 0.002 | |
| Location: OB South Of Building | | | | | | | | | | |
| 13 | 13 | 06/04/08 | 6 | 214 | 1284 | 100 | 3 | 3.82 | < 0.002 | |
| Location: HEPA Microtrap Exhaust #1 | | | | | | | | | | |
| 14 | 14 | 06/04/08 | 6 | 210 | 1260 | 100 | 3 | 3.82 | < 0.002 | |
| Location: HEPA Microtrap Exhaust #2 | | | | | | | | | | |
| 15 | 15 | 06/04/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: † |
| Location: Field Blank | | | | | | | | | | |
| 16 | 16 | 06/04/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: † |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue B2, 8/15/94. Using an Olympus, Model CHS PCM microscope, Serial #DA0976; Analyzed by: Patrick D. Toomey (uj). Date Analyzed: 6/9/2008.
 Limit of Detection= 5.1 fibers./100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc mm of filter area. ND=No fibers observed; N/A= Not Analyzed; Walton-Rockett gravimetric field area = 0.00785 mm². TWA = 8 hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence limit (Employee Compliance Test)- Calculated as a one sided UCL to determine 95% certainty of compliance with the 0.01 fiber/cc standard; Estimated RSD: Intraday Sp=0.405, Interday Sp=0.45, (NY ELAP Lab 11489, AIIIA Lab # 102813)



END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

June 6, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208061669
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza - 1st Floor (Durings)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Friday, June 06, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15

The 15 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marvin E. Brothers".

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results
 A281048: 4850 Broadway, Sherman Plaza - 1st Floor (Durings)

| AmesSol Sample # | Client Sample # | Date Collected | Fiber Type (Remaining) | Quantity (mm) | Air Filtered (Hours) | Fields | Fibers | Fiber Density (Fibers/mm ³) | Fibers Conc. (Fibers/cc) | TWA |
|---------------------------------------|-----------------|----------------|------------------------|---------------|----------------------|--------|--------|---|--------------------------|-----|
| 01 | 01 | 06/05/08 | 0 | 300 | 1800 | 100 | 3 | 3.00 | < 0.001 | |
| Location: Pumped Down Clean Room | | | | | | | | | | |
| 02 | 02 | 06/05/08 | 0 | 300 | 1800 | 100 | 3 | 3.00 | < 0.001 | |
| Location: OA # From Waste Doors Aisle | | | | | | | | | | |
| 03 | 03 | 06/05/08 | 0 | 300 | 1800 | 100 | 3.8 | 3.18 | < 0.001 | |
| Location: OA East Of Work Area | | | | | | | | | | |
| 04 | 04 | 06/05/08 | 0 | 300 | 1800 | 100 | 3 | 3.00 | < 0.001 | |
| Location: OA West Of Work Area | | | | | | | | | | |
| 05 | 05 | 06/05/08 | 0 | 300 | 1800 | 100 | 3 | 3.00 | < 0.001 | |
| Location: CB South Of Building | | | | | | | | | | |
| 06 | 06 | 06/05/08 | 0 | 300 | 1800 | 100 | 3 | 3.00 | < 0.001 | |
| Location: Microstrip Enclosed #1 | | | | | | | | | | |
| 07 | 07 | 06/05/08 | 0 | 300 | 1800 | 100 | 3 | 3.00 | < 0.001 | |
| Location: Microstrip Enclosed #2 | | | | | | | | | | |
| 08 | 08 | 06/05/08 | 0 | 300 | 1200 | 600 | 3 | 3.00 | < 0.001 | |
| Location: Pumped Down Clean Room | | | | | | | | | | |
| 09 | 09 | 06/05/08 | 0 | 200 | 1200 | 100 | 3.8 | 4.48 | < 0.001 | |
| Location: OA # From Waste Doors Aisle | | | | | | | | | | |
| 10 | 10 | 06/05/08 | 0 | 100 | 1100 | 100 | 3 | 3.00 | < 0.001 | |
| Location: OA East Of Work Area | | | | | | | | | | |
| 11 | 11 | 06/05/08 | 0 | 100 | 1100 | 100 | 4 | 6.18 | < 0.001 | |
| Location: OA West Of Work Area | | | | | | | | | | |

Phase Contrast Microscopy (PCM) Fiber Results
 A281048; 4650 Broadway, Sherman Plaza - 1st Floor (Durlings)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|-----|
| 12 | 12 | 06/05/08 | 6 | 190 | 1140 | 100 | 3 | 3.82 | < 0.002 | |
| Location: Microtrap Exhaust #1 | | | | | | | | | | |
| 13 | 13 | 06/05/08 | 6 | 185 | 1116 | 100 | 2 | 2.55 | < 0.002 | |
| Location: Microtrap Exhaust #2 | | | | | | | | | | |
| 14 | 14 | 06/05/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |
| Location: Field Blank | | | | | | | | | | |
| 15 | 15 | 06/05/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |
| Location: Field Blank | | | | | | | | | | |
| | | | | | | | | | Footnotes: 1 | |
| | | | | | | | | | Footnotes: 1 | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94: Using an Olyscop, Model CHS PCM microscope, Serial #0A8076, Analyzed by: Patrick D. Toomey
 Limit of Detection - 5.5 fibers/100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report yields ONLY in the sample analysis expressed as fibers/cc mm of
 filter area. ND=No fibers observed; NA= Not Analyzed; Walton-Beckett graticule field area = 0.00785 mm². TWA = 8 hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance
 Test) - Calculated as a one sided UCL to determine 95% certainty of compliance with the 0.01 fiber/cc standard. Estimated RSD: Interlab Sp=0.45, Interlab Sp=0.45, (NY ELAP Lab 11480, AITIA Lab # 102843)



Date Analyzed: 6/6/2008

Reviewed By: 

END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

June 10, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208061987
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza 1st Floor; 1st Floor; During

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Monday, June 09, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16

The 16 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marvin E. Brothers". The signature is fluid and stylized, with a long horizontal stroke at the end.

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A231048, 4550 Broadway, Sherman Plaza 1st Floor, 1st Floor, During

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (L/min) | Duration (min.) | Air Filtered (Filter) | Fibers | Fiber Density (Fibers/cm ²) | Fibers Conc. (Fibers/cc) | FWA |
|---|-----------------|----------------|-------------------|-----------------|-----------------------|--------|---|--------------------------|-----|
| 01 | 01 | 06/06/08 | 0 | 300 | 1000 | 100 | 1.27 | < 0.002 | |
| Location: Perimeter Drop Ceiling Room | | | | | | | | | |
| 02 | 02 | 06/06/08 | 0 | 200 | 1000 | 100 | 3.50 | < 0.002 | |
| Location: OA #1 From Waste Drop Ceiling | | | | | | | | | |
| 03 | 03 | 06/06/08 | 0 | 200 | 1000 | 100 | 3.50 | < 0.002 | |
| Location: OA West Of Wash Area | | | | | | | | | |
| 04 | 04 | 06/06/08 | 0 | 200 | 1000 | 100 | 3.50 | < 0.002 | |
| Location: OA East Of Wash Area | | | | | | | | | |
| 05 | 05 | 06/06/08 | 0 | 200 | 1000 | 100 | 3.50 | < 0.002 | |
| Location: OA South Of Building | | | | | | | | | |
| 06 | 06 | 06/06/08 | 0 | 200 | 1000 | 100 | 3.50 | < 0.002 | |
| Location: ISMA Miss Trap Exhaust # 1 | | | | | | | | | |
| 07 | 07 | 06/06/08 | 0 | 200 | 1000 | 100 | 3.50 | < 0.002 | |
| Location: ISMA Miss Trap Exhaust # 2 | | | | | | | | | |
| 08 | 08 | 06/06/08 | 0 | 220 | 1000 | 100 | 3.50 | < 0.002 | |
| Location: Perimeter Drop Ceiling Room | | | | | | | | | |
| 09 | 09 | 06/06/08 | 0 | 300 | 1000 | 100 | 3.50 | < 0.002 | |
| Location: OA #1 From Waste Drop Ceiling | | | | | | | | | |
| 10 | 10 | 06/06/08 | 0 | 200 | 1000 | 100 | 1.27 | < 0.002 | |
| Location: OA West Of Wash Area | | | | | | | | | |
| 11 | 11 | 06/06/08 | 0 | 200 | 1000 | 100 | 3.50 | < 0.002 | |
| Location: OA East Of Wash Area | | | | | | | | | |

Phase Contrast Microscopy (PCM) Fiber Results
 A281048; 4650 Broadway, Sherman Plaza 1st Floor, 1st Floor, During

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|---------------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 06/06/08 | 6 | 222 | 1332 | 100 | 2 | 2.55 | < 0.002 | |
| Location: OA South Of Building | | | | | | | | | | |
| 13 | 13 | 06/06/08 | 6 | 218 | 1308 | 100 | 3 | 3.82 | < 0.002 | |
| Location: HEPA Micro Trap Exhaust # 1 | | | | | | | | | | |
| 14 | 14 | 06/06/08 | 6 | 214 | 1284 | 100 | 3 | 3.82 | < 0.002 | |
| Location: HEPA Micro Trap Exhaust # 2 | | | | | | | | | | |
| 15 | 15 | 06/06/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 16 | 16 | 06/06/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94: Using an Olympus, Model CH5 PCM microscope, Serial #0A0076; Analyzed by: Kenneth R. Hurrell
 Limit of Detection = 5.5 fibers /100 fields or 2 fibers/field. Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc min of
 filter area: ND=No fibers observed; NA=Not Analyzed; W=Williams-Brekeitt particle field area = 0.00785 mm². TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance
 Test) - Calculated in the field Log. To determine the probability of compliance with the 0.01 fiber/cc standard: Estimated RSD: Interlab S=0.405, Interlab S=0.45, (NY ELAP Lab 11488), AMIA Lab # 103843

Reviewed By: 

END OF REPORT

Date Analyzed: 6/10/2008



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

June 10, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208062070
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza 1st Floor (During)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Monday, June 09, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09

The 9 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results
 A281048: 4650 Broadway, Sherman Plaza 1st Floor (During)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|-----|
| 01 | 01 | 06/09/08 | 5.5 | 372 | 2046 | 100 | 4 | 5.10 | < 0.001 | |
| Location: Personal Decon Clean Room | | | | | | | | | | |
| 02 | 02 | 06/09/08 | 5.5 | 368 | 2024 | 100 | 2 | 2.55 | < 0.001 | |
| Location: OA 6' From Waste Decon Airlock | | | | | | | | | | |
| 03 | 03 | 06/09/08 | 5.5 | 364 | 2002 | 100 | 3 | 3.82 | < 0.001 | |
| Location: OA West Of Work Area | | | | | | | | | | |
| 04 | 04 | 06/09/08 | 5.5 | 360 | 1980 | 100 | 4 | 5.10 | < 0.001 | |
| Location: OA East Of Work Area | | | | | | | | | | |
| 05 | 05 | 06/09/08 | 5.5 | 356 | 1958 | 100 | 2 | 2.55 | < 0.001 | |
| Location: OB South Of Building | | | | | | | | | | |
| 06 | 06 | 06/09/08 | 5.5 | 352 | 1936 | 100 | 3 | 3.82 | < 0.001 | |
| Location: HEPA Microtrap Exhaust #1 | | | | | | | | | | |
| 07 | 07 | 06/09/08 | 5.5 | 348 | 1914 | 100 | 3 | 3.82 | < 0.001 | |
| Location: HEPA Microtrap Exhaust #2 | | | | | | | | | | |
| 08 | 08 | 06/09/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | Footnotes: 1 | |
| Location: Field Blank | | | | | | | | | | |
| 09 | 09 | 06/09/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | Footnotes: 1 | |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/13/04. Using an Olympus Model CH5 PCM microscope, Serial #0408076; Analyzed by: Tatyana Grinetskaya; Date Analyzed: 6/10/2008.

Limit of Detection: 5.5 fibers /100 fields or 7 fibers/cm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc (mm of fiber area) (NIOSH fibers observed; NA= Not Analyzed; W= from Wackert particle field area = 0.00785 mm²; TWA = 8 HP TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence Limit (Employers Compliance Test); Calculated as a rounded UCL to determine 95% compliance of compliance with the OSHA Service standard. Estimated RSD: Inhalable Sp=0.405, Interlab Sp=0.45, (NY ELAP Lab 11480), AHERA Lab # 102843)

Reviewed By: 

END OF REPORT

TGA by WB



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016
TEL: (212) 679-8600 • FAX: (212) 679-9392

June 10, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208062071
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza 1st Floor

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Monday, June 09, 2008, for a 12 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12

The 12 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results
 A281045: 4650 Broadway, Sturman Plaza 1st Floor

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (Bar/min) | Duration (min) | Air Filtered (Bars) | Flats | Fibers | Fiber Density (Fibers/cm ²) | Fibers Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|---------------------|----------------|---------------------|-------|--------|---|--------------------------|-----|
| 01 | 01 | 06/06/08 | 14 | 140 | 1000 | 100 | 3 | 3.00 | < 0.001 | |
| Location: 1A Apartment Inside Work Area | | | | | | | | | | |
| 02 | 02 | 06/06/08 | 14 | 140 | 1000 | 100 | 1 | 1.00 | < 0.001 | |
| Location: 1B Southeast Inside Work Area | | | | | | | | | | |
| 03 | 03 | 06/06/08 | 14 | 140 | 1000 | 100 | 4 | 3.80 | < 0.001 | |
| Location: 1A Corner Inside Work Area | | | | | | | | | | |
| 04 | 04 | 06/06/08 | 14 | 140 | 1000 | 100 | 3 | 3.00 | < 0.001 | |
| Location: 1A Northwest Inside Work Area | | | | | | | | | | |
| 05 | 05 | 06/06/08 | 14 | 140 | 1000 | 100 | 2.8 | 3.18 | < 0.001 | |
| Location: 1A Southwest Inside Work Area | | | | | | | | | | |
| 06 | 06 | 06/06/08 | 14 | 140 | 1000 | 100 | 2 | 3.00 | < 0.001 | |
| Location: 1A Front Waste Carton Area | | | | | | | | | | |
| 07 | 07 | 06/06/08 | 14 | 140 | 1000 | 100 | 1 | 1.00 | < 0.001 | |
| Location: 1A East Of Work Area By CB | | | | | | | | | | |
| 08 | 08 | 06/06/08 | 14 | 140 | 1000 | 100 | 3 | 3.00 | < 0.001 | |
| Location: 1A West Of Work Area | | | | | | | | | | |
| 09 | 09 | 06/06/08 | 14 | 140 | 1000 | 100 | 2 | 3.00 | < 0.001 | |
| Location: 1A 2 Entrance To Work Area | | | | | | | | | | |
| 10 | 10 | 06/06/08 | 14 | 140 | 1000 | 100 | 2 | 3.00 | < 0.001 | |
| Location: 1A Hallway To Apartment Area | | | | | | | | | | |
| 11 | 11 | 06/06/08 | 0 | 0 | 0 | 0 | 0.0 | 0.00 | < 0.001 | |
| Location: Field Blank | | | | | | | | | | |

See Reporting notes on last page

AmeriSci Job #: 208062071

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A281048, 4650 Broadway, Sherman Plaza 1st Floor

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|-----|
| 12 | 12 | 06/09/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |

Location: Field Blank

Footnotes: 1

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94 Using an Olympus, Model CHS PCM microscope, Serial #0A0076, Analyzed by: Kenneth R. Harrell (rl)
 Limit of Detection= 3.5 fibers /100 fields or 7 Fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report reflects ONLY to the sample analysis expressed as fibers/cc mm of
 filter area: NS-No fibers observed; NA=Not Analyzed; WD=Beckitt granitic field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence limit (Employers Compliance
 Test)- Calculated as per 30 CFR 115.101 to determine 95% certainty of compliance with the 0.01 fiber/cc standard; Estimated RSD: Interlab S_r=0.45, Intra-lab S_r=0.465, Interlab S_y=0.45, (NY ELAP Lab # 11489, AIIHA Lab # 102843)

Reviewed By:




Date Analyzed: 6/10/2008

END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016
TEL: (212) 679-8600 • FAX: (212) 679-9392

June 12, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208062072
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza - 1st Floor (Clearance)

Dear Charles Powers:

Enclosed are the results for TEM fiber analysis of the following CNS Management Corporation samples received at AmeriSci on Monday, June 09, 2008, for a 12 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12

The 12 air samples were sent to AmeriSci via Hand Delivered. These samples were prepared according to AHERA Protocol.

Table I represents a summary of all pertinent information used for the structure (fiber) density and concentration calculations. Included are the size of each structure counted, the structure density and concentration, type of fibrous material detected and the analytical sensitivity, which represents the concentration by the detection of one structure in the TEM structure count. Copies of the Fiber Count Sheets are included. These data sheets contain information for structure length/width, structure type, structure morphology and pertinent information on EDS, SAED and photography.

This report relates ONLY to the sample analysis expressed as structure density. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci, NVLAP or any agency of the U. S. Government. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the written approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Paul J. Mucha".

Paul J. Mucha
Laboratory Director

Table 1

Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)

A281048; 4650 Broadway, Sherman Plaza - 1st Floor (Clearance)

| AmeriSci Sample # | Client Sample # | Dilution Factor | Air Filtered (liters) | Area Analyzed (sq. mm.) | Analytical Sensitivity (struc/cc air) | Asbestos Structures Detected (Microns) | | Structure Density (struc/sq mm) | Structure Concentration (struc/cc air) | | Type of Asbestos |
|--|-----------------|-----------------|-----------------------|-------------------------|---------------------------------------|--|-------|---------------------------------|--|---------|------------------|
| | | | | | | 0.5-5.0 | >=5.0 | | >=5.0 | Total | |
| 01 inside Location: 1A Northeast Inside Work Area | 01 | | 1330 | .06 | 0.0048 | 0.0 | 0.0 | <16.7 | <0.0048 | <0.0048 | NSD |
| 02 inside Location: 1A Southeast Inside Work Area | 02 | | 1330 | .06 | 0.0048 | 0.0 | 0.0 | <16.7 | <0.0048 | <0.0048 | NSD |
| 03 inside Location: 1A Center Inside Work Area | 03 | | 1330 | .06 | 0.0048 | 0.0 | 0.0 | <16.7 | <0.0048 | <0.0048 | NSD |
| 04 inside Location: 1A Northwest Inside Work Area | 04 | | 1330 | .06 | 0.0048 | 0.0 | 0.0 | <16.7 | <0.0048 | <0.0048 | NSD |
| 05 inside Location: 1A Southwest Inside Work Area | 05 | | 1330 | .06 | 0.0048 | 0.0 | 0.0 | <16.7 | <0.0048 | <0.0048 | NSD |
| 06** Location: 0A 6' From Waste Decon Airlock | 06 | | 1330 | | | | | | | | |
| 07** Location: 0A East Of Work Area By CB | 07 | | 1330 | | | | | | | | |
| 08** Location: 0A West Of Work Area | 08 | | 1330 | | | | | | | | |
| 09** Location: 0A From Ent. To Work Area | 09 | | 1330 | | | | | | | | |
| 10** Location: 0A Halfway To Abatement Area | 10 | | 1330 | | | | | | | | |
| 11** Location: Field Blank | 11 | | 0 | | | | | | | | |
| 12** Location: Field Blank | 12 | | 0 | | | | | | | | |

* concentration reprinted by the detection of 1 structure
 ** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By: _____

[Signature]

Analyzed By: _____

Mean Total Structure Density For Inside Samples: 0 structures/sq. mm.
 Date: 6/10/2008
 Victor Hopac

TEM Asbestos (air) Count Sheet

Sample and
analyzed



| | |
|--|---|
| Client Name: CNS Management Corporation | Volume (liters): 1.330.0 |
| Job #: 208062072 | Filter Type / Filter Area: MCE 385 mm ² |
| Lab Sample #: 01 | Grid Opening Size: 0.01000 mm ² |
| Client Sample #: 01 | Area Examined: 0.06000 mm ² |
| Received: 06/09/08 22:07:42 | Magnification: 20,000 |
| Date Analyzed: 06/10/08 | Accelerating Voltage: 100 KeV |
| Scope #: 6 | |

Analysis Performed by:
Victor Slopas

| Location | Grid Openings | Fiber | Length μ m | Width μ m | Fiber Type | Microbiology | EDS | Count | SAED | Photo |
|----------|---------------|-------|----------------|---------------|------------|--------------|-----|-------|------|-------|
| A5-S4E | 1 | NSD | | | | | | | | |
| A5-S4F | 2 | NSD | | | | | | | | |
| A5-S4G | 3 | NSD | | | | | | | | |
| B1-S4C | 4 | NSD | | | | | | | | |
| B1-S4E | 5 | NSD | | | | | | | | |
| B1-S4F | 6 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|------------------------------------|---|-------------------------------|---|
| Total Grid Openings: 6 | | | |
| Chrysotile Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures >=5 microns: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 16.7 | 0.0048 | <input checked="" type="checkbox"/> Particulate Even |

TEM Asbestos (air) Count Sheet

sample area analyzed



| | |
|--|---|
| Client Name: CNS Management Corporation | Volume (liters): 1.310.0 |
| Job #: 208062072 | Filter Type / Filter Area: MCE 385 mm ² |
| Lab Sample #: 02 | Grid Opening Size: 0.01000 mm ² |
| Client Sample #: 02 | Area Examined: 0.06000 mm ² |
| Received: 06/09/08 | Magnification: 20,000 |
| Date Analyzed: 06/10/08 | Accelerating Voltage: 100 KeV |
| Specimen #: 6 | |

Analysis Performed by: Victor Slovic

| Location | Grid Opening | Fiber | Length μm | Width μm | Fiber Type | Morphology | EDS | Other | SAED | Photo |
|----------|--------------|-------|----------------------|---------------------|------------|------------|-----|-------|------|-------|
| B2-4/1C | 1 | NSD | | | | | | | | |
| B2-4/1E | 2 | NSD | | | | | | | | |
| B2-4/1F | 3 | NSD | | | | | | | | |
| B3-3/1C | 4 | NSD | | | | | | | | |
| B3-3/1E | 5 | NSD | | | | | | | | |
| B3-3/1F | 6 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|-------------------------------------|---|-------------------------------|---|
| Total Grid Openings: 6 | | | |
| Chrysotile Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures >= 5 microns: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Undrained Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Foiled Replica < 50% |
| Total Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 16.7 | 0.0048 | <input checked="" type="checkbox"/> Particulate Even |

TEM Asbestos (air) Count Sheet

Sample Area
analyzed



| | | |
|--|-----------------|---|
| Client Name: CNS Management Corporation | | Volume (liters): 1.330.0 |
| Job #: 208062072 | | Filter Type / Filter Area: MCE 385 mm ² |
| Lab Sample #: 03 | | Grid Opening Size: 0.01000 mm ² |
| Client Sample #: 03 | | Area Examined: 0.00000 mm ² |
| Received: 06/09/08 | 22-07-02 | Magnification: 20,000 |
| Date Analyzed: 06/10/08 | | Accelerating Voltage: 100 KeV |
| Scope #: 0 | | |

Analysis Performed by: VS
Victor Slopas

| Location | Grid Opening | Fiber | Length μm | Width μm | Fiber Type | Morphology | EDS | Chart | SAD | Photo |
|----------|--------------|-------|----------------------|---------------------|------------|------------|-----|-------|-----|-------|
| B4-3/1C | 1 | NSD | | | | | | | | |
| B4-3/1E | 2 | NSD | | | | | | | | |
| B4-3/1F | 3 | NSD | | | | | | | | |
| B5-3/1C | 4 | NSD | | | | | | | | |
| B5-3/1E | 5 | NSD | | | | | | | | |
| B5-3/1F | 6 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|------------------------------------|---|-------------------------------|---|
| Total Grid Openings: 6 | | | |
| Chrysotile Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures >=5 microns: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 16.7 | 0.0048 | <input checked="" type="checkbox"/> Particulate Even |

TEM Asbestos (air) Count Sheet

sample area
analyzed



| | |
|--|--|
| Client Name: CNS Management Corporation Job #: 208062072 Lab Sample #: 04 Client Sample #: 04 Received: 06/09/08 Date Analyzed: 06/10/08 Scope #: 6 | Volume (liters): 1.130.0 Filter Type / Filter Area: MCE 185 mm ² Grid Opening Size: 0.01000 mm ² Area Examined: 0.06000 mm ² Magnification: 20,000 Accelerating Voltage: 100 KeV |
|--|--|

Analysis Performed by: Victor Stojac

| Location | Grid Opening | Filter | Length μ m | Width μ m | Fiber Type | Morphology | EDS | Orient. | SAED | Photo |
|----------|--------------|--------|----------------|---------------|------------|------------|-----|---------|------|-------|
| C1-3/10 | 1 | NSD | | | | | | | | |
| C1-3/1E | 2 | NSD | | | | | | | | |
| C1-3/1F | 3 | NSD | | | | | | | | |
| C2-4/10 | 4 | NSD | | | | | | | | |
| C2-4/1E | 5 | NSD | | | | | | | | |
| C2-4/1F | 6 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|-------------------------------------|---|-------------------------------|--|
| Total Grid Openings: 6 | | | <input checked="" type="checkbox"/> Grid Openings Covered > 50% <input checked="" type="checkbox"/> Intact Grid Opening > 50% <input checked="" type="checkbox"/> Undissolved Filter < 10% <input checked="" type="checkbox"/> Folded Replica < 50% <input checked="" type="checkbox"/> Filter Loading < 10% <input checked="" type="checkbox"/> Particulate Even |
| Chrysotile Asbestos Structures: 0 | <16.7 | <0.0048 | |
| Amphibole Asbestos Structures: 0 | <16.7 | <0.0048 | |
| Asbestos Structures >= 5 microns: 0 | <16.7 | <0.0048 | |
| Total Non-Asbestos Structures: | | | |
| Total Asbestos Structures: 0 | <16.7 | <0.0048 | |
| Analytical Sensitivity: | 16.7 | 0.0048 | |

TEM Asbestos (air) Count Sheet



| | | | |
|--|--|---|--|
| Client Name: CNS Management Corporation | | Volume (liters): 1.330.0 | |
| Job #: 208062072 | | Filter Type / Filter Area: MCE 385 mm ² | |
| Lab Sample #: 05 | | Grid Opening Size: 0.01000 mm ² | |
| Client Sample #: 05 | | Area Examined: 0.06000 mm ² | |
| Received: 06/09/08 | | Magnification: 20,000 | |
| Date Analyzed: 06/10/08 | | Accelerating Voltage: 100 KeV | |
| Scope #: 6 | | | |

Analysis Performed by:
 Victor Slogar

| Location | Grid Opening | Fiber | Length μm | Width μm | Fiber Type | Morphology | EDS | Count | SASD | Phase |
|----------|--------------|-------|----------------------|---------------------|------------|------------|-----|-------|------|-------|
| C3-41C | 1 | NSD | | | | | | | | |
| C3-41E | 2 | NSD | | | | | | | | |
| C3-41F | 3 | NSD | | | | | | | | |
| C4-41C | 4 | NSD | | | | | | | | |
| C4-41E | 5 | NSD | | | | | | | | |
| C4-41F | 6 | NSD | | | | | | | | |

NSD: No Asbestos Structures Detected

Comments

| | Structure Density (str/mm ²) | Concentration (str/cc air) | Grid Evaluation |
|------------------------------------|---|-------------------------------|---|
| Total Grid Openings: 6 | | | |
| Chrysotile Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Grid Openings Covered > 50% |
| Amphibole Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Intact Grid Opening > 50% |
| Asbestos Structures >=5 microns: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Undissolved Filter < 10% |
| Total Non-Asbestos Structures: | | | <input checked="" type="checkbox"/> Folded Replica < 50% |
| Total Asbestos Structures: 0 | <16.7 | <0.0048 | <input checked="" type="checkbox"/> Filter Loading < 10% |
| Analytical Sensitivity: | 16.7 | 0.0048 | <input checked="" type="checkbox"/> Particulate Even |



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8300 • FAX: (212) 679-8302

June 13, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 208
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208062418
P.O. #A281048
A281048, 4050 Broadway, Sherman Plaza, Boiler Room (Background)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Thursday, June 12, 2008, for a 24 hour turnaround.

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12

The 12 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as Results/mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

| Amesol Sample # | Client Sample # | Date Collected | Flow Rate (m ³ /min) | Duration (min) | Air Filtered (grams) | Fibers | Fibers / Mass | Fiber Density (Fibers/mm ³) | Fibers Corr. (Fibers/cc) | TWA |
|---|-----------------|----------------|---------------------------------|----------------|----------------------|--------|---------------|---|--------------------------|---------------|
| 01 | 01 | 00/11/08 | 14 | 60 | 1000 | 108 | 8 | 0.58 | < 0.002 | |
| Location: VA Southeast Corner Baffle Box | | | | | | | | | | |
| 02 | 02 | 00/11/08 | 14 | 60 | 1000 | 100 | 4 | 0.10 | < 0.002 | |
| Location: VA Northwest Corral Box | | | | | | | | | | |
| 03 | 03 | 00/11/08 | 14 | 60 | 1000 | 106 | 3.8 | 0.46 | < 0.002 | |
| Location: VA Corner Baffle Room | | | | | | | | | | |
| 04 | 04 | 00/11/08 | 14 | 60 | 1000 | 102 | 4 | 0.10 | < 0.002 | |
| Location: VA Southwest Corral Baffle Room | | | | | | | | | | |
| 05 | 05 | 00/11/08 | 14 | 60 | 1000 | 106 | 2 | 2.55 | < 0.002 | |
| Location: VA Northwest Corner Baffle Room | | | | | | | | | | |
| 06 | 06 | 00/11/08 | 14 | 60 | 1000 | 108 | 3 | 3.62 | < 0.002 | |
| Location: GA W From Elev To Baffle Room | | | | | | | | | | |
| 07 | 07 | 00/11/08 | 18 | 60 | 1000 | 608 | 7 | 2.90 | < 0.002 | |
| Location: GA East Of Baffle Room | | | | | | | | | | |
| 08 | 08 | 00/11/08 | 18 | 60 | 1000 | 500 | 3 | 2.50 | < 0.002 | |
| Location: GA North Of Baffle Room | | | | | | | | | | |
| 09 | 09 | 00/11/08 | 14 | 60 | 1000 | 606 | 3.8 | 3.18 | < 0.002 | |
| Location: GA West Of Baffle Room | | | | | | | | | | |
| 10 | 10 | 00/11/08 | 18 | 60 | 1000 | 609 | 7 | 3.63 | < 0.002 | |
| Location: GA South Of Baffle Room | | | | | | | | | | |
| 11 | 11 | 00/11/08 | 0 | 0 | 0 | 100 | 0.8 | 0.84 | | Footcandle: 1 |
| Location: Field Blank | | | | | | | | | | |

See Tripodding notes on next page



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8800 • FAX: (212) 679-8892

June 13, 2008

CNS Management Corporation
Attn: Charles Powers
500 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208002581
P.O. #A231548
4281048: 4550 Broadway, Sherman Plaza - Boiler Room / FRP

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Friday, June 13, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14

The 14 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/04. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cc mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Martin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A261048: 4650 Broadway, Sherman Plaza - Boiler Room / RRP

| Analysis Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (liters) | Facts | Fibers | Fiber Density (Fibers/mm ²) | Fibers Count (Fibers/cc) | TWA |
|--|-----------------|----------------|------------------------|----------------|-----------------------|-------|--------|---|--------------------------|-----|
| 01 | 01 | 06/12/08 | 8 | 343 | 1038 | 100 | 7 | 2.35 | < 0.001 | |
| Location: Personal DeCont / Clean Room | | | | | | | | | | |
| 02 | 02 | 06/12/08 | 8 | 338 | 1004 | 100 | 4 | 8.10 | < 0.001 | |
| Location: CA Y From Work Area (Boiler Room & East) | | | | | | | | | | |
| 03 | 03 | 06/12/08 | 8 | 348 | 1000 | 100 | 3 | 3.82 | < 0.001 | |
| Location: CA Top Of Stairway To RM | | | | | | | | | | |
| 04 | 04 | 06/12/08 | 8 | 340 | 1030 | 100 | 3 | 2.88 | < 0.001 | |
| Location: CA South Of Work Area | | | | | | | | | | |
| 05 | 05 | 06/12/08 | 8 | 340 | 1000 | 100 | 3 | 2.93 | < 0.001 | |
| Location: CA East Of Work Area Boiler Room | | | | | | | | | | |
| 06 | 06 | 06/12/08 | 8 | 340 | 1000 | 100 | 3 | 8.33 | < 0.001 | |
| Location: Ministry Exhaust | | | | | | | | | | |
| 07 | 07 | 06/12/08 | 8 | 348 | 1000 | 100 | 3 | 1.83 | < 0.002 | |
| Location: Personal DeCont / Clean Room | | | | | | | | | | |
| 08 | 08 | 06/12/08 | 8 | 348 | 1418 | 100 | 4 | 3.16 | < 0.002 | |
| Location: CA Y From Work Area DeCont Minors | | | | | | | | | | |
| 09 | 09 | 06/12/08 | 8 | 343 | 1433 | 100 | 3 | 3.65 | < 0.002 | |
| Location: CA East Of Work Area (Boiler Room) | | | | | | | | | | |
| 10 | 10 | 06/12/08 | 8 | 338 | 1429 | 100 | 8 | 8.27 | < 0.002 | |
| Location: CA South Of Work Area Boiler Room | | | | | | | | | | |
| 11 | 11 | 06/12/08 | 8 | 324 | 1404 | 100 | 3 | 3.85 | < 0.002 | |
| Location: CA Top Of Stairway To Basement | | | | | | | | | | |

Phase Contrast Microscopy (PCM) Fiber Results
 A281048; 4650 Broadway, Sherman Plaza - Boiler Room / PRP

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--------------------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 12 | 12 | 06/12/08 | 6 | 230 | 1380 | 100 | 2 | 2.55 | < 0.002 | |
| Location: OA Microtrap Exhaust | | | | | | | | | | |
| 13 | 13 | 06/12/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |
| Location: Field Blank | | | | | | | | | | |
| 14 | 14 | 06/12/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |
| Location: Field Blank | | | | | | | | | | |
| | | | | | | | | | | Footnotes: 1 |
| | | | | | | | | | | Footnotes: 1 |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94; Using an Olympus, Model CEM PCM microscope, Serial #DA0076; Analyzed by Devin M. Alyce, Date Analyzed: 6/13/2008.
 Limit of Detection= 5.5 fibers/100 fields or 7 fibers/cm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc and filter area. ND=No fibers observed; NA=Not Analyzed. When check sheet graphic field area = 0.00785 mm², TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence Limit (Employer Compliance Test) - Calculated as a 95% upper confidence limit to determine 95% certainty of compliance with the 0.01 fiber/cc standard. Estimated RSD: Inertlab S-0.405, Inertlab S-0.45, (NY ELAP Lab 11480, AIIIA Lab # 102443).

Reviewed By:  _____
 END OF REPORT

June 17, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208063075
P.O. #A281048
A281048; 4650 Broadway, Sherman Plaza - Boiler Room

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Monday, June 16, 2008, for a 24 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08

The 8 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,



Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A281048; 4650 Broadway, Sherman Plaza - Boiler Room

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 01 | 01 | 06/13/08 | 5.5 | 420 | 2310 | 100 | 2 | 2.55 | < 0.001 | |
| Location: Personal Decon Clean Room | | | | | | | | | | |
| 02 | 02 | 06/13/08 | 5.5 | 416 | 2286 | 100 | 3 | 3.82 | < 0.001 | |
| Location: OA B' From Waste Decon Airlock | | | | | | | | | | |
| 03 | 03 | 06/13/08 | 5.5 | 412 | 2266 | 100 | 2 | 2.55 | < 0.001 | |
| Location: OA East Of Work Area Boiler Room | | | | | | | | | | |
| 04 | 04 | 06/13/08 | 5.5 | 408 | 2244 | 100 | 3 | 3.82 | < 0.001 | |
| Location: OA West Of Work Area Boiler Room | | | | | | | | | | |
| 05 | 05 | 06/13/08 | 5.5 | 404 | 2222 | 100 | 2 | 2.55 | < 0.001 | |
| Location: OA South Of Work Area Boiler Room | | | | | | | | | | |
| 06 | 06 | 06/13/08 | 5.5 | 400 | 2200 | 100 | 4 | 5.10 | < 0.001 | |
| Location: OA Microtrap Exhaust | | | | | | | | | | |
| 07 | 07 | 06/13/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 08 | 08 | 06/13/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus, Model CH5 PCM microscope. Serial #DA0076. Analyzed by: Toyana Grimesha; Date Analyzed: 6/17/2008.
 Limit of Detection= 5.5 fibers /100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc or mm³ of filter area. ND=No fibers observed; NA= Not Analyzed; Walton-Beckett graticule field area = 0.00785 mm². TWA = 8 Hr TWA calculation assumes an 8 hr period not sampled. Upper 95% Confidence Limit (Employers Compliance Test)- Calculated as a one sided UCL to determine 95% certainty of compliance with the 0.01 fiber/cc standard. Estimated RSD: IntraLab S=0.405, InterLab S=0.45, (NY ILAP Lab 11880, AIHA Lab # 102843)

Reviewed By:  END OF REPORT

June 17, 2008

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 208063074
P.O. #A281048
A281048: 4650 Broadway, Sherman Plaza - Boiler Room (Clearance)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Monday, June 16, 2008, for a 12 hour turnaround:

01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12

The 12 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,



Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results
 A281048; 4650 Broadway, Sherman Plaza - Boiler Room (Clearance)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 01 | 01 | 06/16/08 | 12 | 150 | 1800 | 100 | 3 | 3.82 | < 0.001 | |
| Location: 1A Southeast Inside Room | | | | | | | | | | |
| 02 | 02 | 06/16/08 | 12 | 150 | 1800 | 100 | 4 | 5.10 | < 0.001 | |
| Location: 1A Southwest Inside Boiler Room | | | | | | | | | | |
| 03 | 03 | 06/16/08 | 12 | 150 | 1800 | 100 | 2 | 2.55 | < 0.001 | |
| Location: 1A Center Inside Boiler Room | | | | | | | | | | |
| 04 | 04 | 06/16/08 | 12 | 150 | 1800 | 100 | 3 | 3.82 | < 0.001 | |
| Location: 1A Northeast Inside Boiler Room | | | | | | | | | | |
| 05 | 05 | 06/16/08 | 12 | 150 | 1800 | 100 | 2.5 | 3.18 | < 0.001 | |
| Location: 1A Northwest Inside Boiler Room | | | | | | | | | | |
| 06 | 06 | 06/16/08 | 12 | 150 | 1800 | 100 | 3 | 3.82 | < 0.001 | |
| Location: 0A Top Of Stairway To Boiler Room | | | | | | | | | | |
| 07 | 07 | 06/16/08 | 12 | 150 | 1800 | 100 | 3 | 3.82 | < 0.001 | |
| Location: 0A West Of Boiler Room | | | | | | | | | | |
| 08 | 08 | 06/16/08 | 12 | 150 | 1800 | 100 | 2 | 2.55 | < 0.001 | |
| Location: 0A East Of Boiler Room | | | | | | | | | | |
| 09 | 09 | 06/16/08 | 12 | 150 | 1800 | 100 | 2 | 2.55 | < 0.001 | |
| Location: 0A 3' From Decon Entrance/ Exit | | | | | | | | | | |
| 10 | 10 | 06/16/08 | 12 | 150 | 1800 | 100 | 4 | 5.10 | < 0.001 | |
| Location: 0A 6' From Waste Decon Airlock | | | | | | | | | | |
| 11 | 11 | 06/16/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 12 | 12 | 06/16/08 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/1/94; Using an Olympus Model CHS PCM microscope, Serial #GA0076; Analyzed by: Kenneth R. Harrell
 Limit of Detection= 5.5 fibers/100 fields or 7 fibers/mm²; Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report reports ONLY to the sample analysis expressed as fibers/cc min of filter area. ND=No fibers observed; NA= Not Analyzed; Wilson-Beckett gravimetric field area = 0.00783 mm²; TWA = 8 Hr TWA calculation assumes 8 hr period for sampling. Upper 95% Confidence limit (Employers Compliance Test) - Calculated as a one sided UCL to determine 95% certainty of compliance with the 0.01 fibers/cc standard. Estimated RSD: Intraday Sp=0.405, Interday Sp=0.415, (NY ELAP Lab 11489, NEN Lab # 102843)
 Date Analyzed: 6/17/2008.

Reviewed By:  END OF REPORT



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

March 11, 2009

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 209031902
P.O. #A281048
A281048: 4650 Broadway, Sherman Ave.; Garage Pipe Insulation; Prep

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, March 11, 2009, for a 24 hour turnaround:

1, 2, 3, 4, 5, 6, 7, 8, 9, 10

The 10 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read "Marvin E. Brothers".

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A281048; 4650 Broadway, Sherman Ave.; Garage Pipe Insulation; Prep

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|-----|
| 01 | 1 | 03/11/09 | 7 | 180 | 1260 | 100 | 6 | 7.64 | 0.002 | |
| Location: Garage End Of Camp At The Critical Barrier | | | | | | | | | | |
| 02 | 2 | 03/11/09 | 7 | 179 | 1253 | 100 | 4 | 5.10 | < 0.002 | |
| Location: Garage, Next To Entrance Personal Decon | | | | | | | | | | |
| 03 | 3 | 03/11/09 | 7 | 178 | 1246 | 100 | 8 | 10.19 | 0.003 | |
| Location: Garage, Next To Entrance Waste Decon | | | | | | | | | | |
| 04 | 4 | 03/11/09 | 7 | 177 | 1239 | 100 | 4 | 5.10 | < 0.002 | |
| Location: Garage, Opposite To Decon Near Critical Barrier | | | | | | | | | | |
| 05 | 5 | 03/11/09 | 7 | 176 | 1232 | 100 | 10 | 12.74 | 0.004 | |
| Location: Garage, Near By Parking Number 102 | | | | | | | | | | |
| 06 | 6 | 03/11/09 | 7 | 180 | 1260 | 100 | 6 | 7.64 | 0.002 | |
| Location: Garage, End Of Ramp At The Critical Barrier | | | | | | | | | | |
| 07 | 7 | 03/11/09 | 7 | 180 | 1260 | 100 | 8 | 10.19 | 0.003 | |
| Location: Garage, Next To Entrance Personal Decon | | | | | | | | | | |
| 08 | 8 | 03/11/09 | 7 | 180 | 1260 | 100 | 12 | 15.29 | 0.005 | |
| Location: Garage, Next To Entrance Waste Decon | | | | | | | | | | |
| 09 | 9 | 03/11/09 | 7 | 180 | 1260 | 100 | 6 | 7.64 | 0.002 | |
| Location: Garage, Opposite To Decon Near Critical Barrier | | | | | | | | | | |
| 10 | 10 | 03/11/09 | 7 | 180 | 1260 | 100 | 4 | 5.10 | < 0.002 | |
| Location: Garage, Near By Parking Number 102 | | | | | | | | | | |

Reporting Notes:

By NIOSH 7400(A) Method, Issue #2, 8/15/94: Using an Olympus, Model CHS PCM microscope, Serial #0480076; Analyzed by: Denis M. Ahyee [dc]; Date Analyzed: 3/11/2009.
 Limit of Detection: 5.5 fibers /100 fields or 7 fibers/mm²; Blank analysis are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc mm of filter area: ND=No Fibers observed; N/A= Not Analyzed; Wadlin-Beckett particle field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes an exposure for remainder of 8 hr period not sampled; Upper 95% Confidence Limit (Employers Compliance Test)- Calculated as a 95% UCL to determine 95% certainty of compliance with the 0.01 fiber/cc standard; Estimated RSD: Interlab S=0.405, IntraLab S=0.45. (NY ELAP Lab 11490, ARIHA Lab # 102843)

DA by WS

END OF REPORT

Reviewed By: 



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

March 12, 2009

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 209032022
P.O. #A281048
A281048; 4650 Broadway, Sherman Ave.; Garage; Prp

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Thursday, March 12, 2009, for a 24 hour turnaround:

13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24

The 12 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in blue ink that reads "JK60MB".

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A281048: 4850 Broadway, Sherman Ave : Garage, Pgn

| Analysis Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fibers | Fiber Density (Fibers/mm ²) | Fiber Conc. (Fibers/cc) | NWA |
|---|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|---|-------------------------|--------------|
| 01 | 13 | 03/12/09 | 7 | 370 | 1880 | 100 | 1.84 | 0.002 | |
| Location: Garage, End Of Ramp At The Critical Mass | | | | | | | | | |
| 02 | 14 | 03/12/09 | 7 | 280 | 1000 | 100 | 11.46 | 0.002 | |
| Location: Garage, Next To Entrance Personnel Doors | | | | | | | | | |
| 03 | 15 | 03/12/09 | 7 | 308 | 1020 | 100 | 1.84 | 0.002 | |
| Location: Garage, Next To Entrance Waste Doors | | | | | | | | | |
| 04 | 16 | 03/12/09 | 7 | 307 | 1000 | 7 | 8.92 | 0.002 | |
| Location: Garage, Opposite Waste Doors At The Critical Mass | | | | | | | | | |
| 05 | 17 | 03/12/09 | 7 | 288 | 1000 | 8 | 10.18 | 0.002 | |
| Location: Garage, At The Parking Ramp 102 | | | | | | | | | |
| 06 | 18 | 03/12/09 | 8 | 228 | 1040 | 8 | 1.84 | 0.002 | |
| Location: Garage, End Of Ramp At The Critical Mass | | | | | | | | | |
| 07 | 19 | 03/12/09 | 7 | 294 | 1020 | 8 | 8.10 | 0.002 | |
| Location: Garage, Next To Entrance Personnel Doors | | | | | | | | | |
| 08 | 20 | 03/12/09 | 7 | 238 | 1000 | 8 | 10.18 | 0.002 | |
| Location: Garage, Next To Entrance Waste Doors | | | | | | | | | |
| 09 | 21 | 03/12/09 | 7 | 232 | 1004 | 6 | 1.84 | 0.002 | |
| Location: Garage, Opposite Waste Doors At The Critical Mass | | | | | | | | | |
| 10 | 22 | 03/12/09 | 7 | 291 | 1017 | 7 | 8.92 | 0.002 | |
| Location: Garage, At The Parking Ramp 102 | | | | | | | | | |
| 11 | 23 | 03/12/09 | 8 | 9 | 8 | 100 | 0.04 | | |
| Location: Four Bins | | | | | | | | | |
| | | | | | | | | | Processed: 3 |

Phase Contrast Microscopy (PCM) Fiber Results

A281048; 4650 Broadway, Sherman Ave.; Garage; Prp

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (filters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------|-----------------|----------------|-------------------------|-----------------|------------------------|--------|--------|---|--------------------------|-----|
| 12 | 24 | 03/12/09 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |

Location: Field Blank

Footnotes: †

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94; Using an Olympus, Model CH5 PCM microscope, Serial #0A0076; Analyzed by: Devin M. Myre [sic] *DM Myre*; Date Analyzed: 3/12/2009.
 Limit of Detection = 5.5 fibers/100 fields or 7 fibers/mm²; Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc and filter area. ND = No fibers observed; NA = Not Analyzed; Walton-Beckett graticle field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled; Upper 95% Confidence Limit (Employer Compliance Test) - Calculated as a one sided UCL, to determine 95% certainty of compliance with the 0.01 fibers/cc standard; Estimated RSD: Interlab S_e = 0.40%, Intra-lab S_e = 0.45, (NY ELAP Lab #1480, AIEA Lab # 102843)

Reviewed By: *[Signature]* _____ END OF REPORT _____



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

March 14, 2009

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 209032148
P.O. #A281048
A281048; 4650 Broadway, Sherman Ave. - Garage Pipe Insulation / Prp.

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Friday, March 13, 2009, for a 24 hour turnaround:

25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36

The 12 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization, Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A281048: 4650 Broadway, Sherman Ave. - Garage Pipe Insulation (Pkg)

| Analysis Sample # | Client Sample # | Date Collected | Flow Rate (Bar/min) | Duration (min) | Air Filtered (gals) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fiber Conc (Fibers/cc) | FWA |
|---|-----------------|----------------|---------------------|----------------|---------------------|--------|--------|---|------------------------|--------------|
| 01 | 25 | 09/13/09 | F | 200 | 1600 | 100 | 8 | 1.04 | 0.003 | |
| Location: Garage, End Of Camp At The Critical Barrier | | | | | | | | | | |
| 02 | 26 | 09/13/09 | F | 279 | 1650 | 100 | 8 | 8.37 | < 0.001 | |
| Location: Garage, Next To Personnel Entry | | | | | | | | | | |
| 03 | 27 | 09/13/09 | F | 278 | 1649 | 100 | 9.3 | 4.46 | < 0.001 | |
| Location: Garage, Next To Waste Deco | | | | | | | | | | |
| 04 | 28 | 09/13/09 | F | 277 | 1600 | 100 | 7 | 8.92 | 0.002 | |
| Location: Garage, Opposite Waste Deco At The Critical Barrier | | | | | | | | | | |
| 05 | 29 | 09/13/09 | F | 278 | 1600 | 200 | 8.8 | 8.28 | 0.002 | |
| Location: Garage At The Parking #1112 | | | | | | | | | | |
| 06 | 30 | 09/13/09 | F | 203 | 1601 | 100 | 3 | 3.02 | < 0.002 | |
| Location: Garage, End Of Camp At The Critical Barrier | | | | | | | | | | |
| 07 | 31 | 09/13/09 | F | 203 | 1601 | 100 | 8 | 7.84 | 0.002 | |
| Location: Garage, Next To Personnel Deco | | | | | | | | | | |
| 08 | 32 | 09/13/09 | F | 203 | 1601 | 100 | 4.9 | 8.73 | < 0.002 | |
| Location: Garage, Next To Waste Deco | | | | | | | | | | |
| 09 | 33 | 09/13/09 | F | 203 | 1601 | 100 | 3 | 8.82 | < 0.002 | |
| Location: Garage, Opposite Waste Deco Of The Critical Barrier | | | | | | | | | | |
| 10 | 34 | 09/13/09 | F | 203 | 1601 | 100 | 7 | 8.92 | 0.002 | |
| Location: Garage At The Parking #1122 | | | | | | | | | | |
| 11 | 35 | 09/13/09 | F | 11 | 0 | 100 | 0.6 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

See Reporting notes at last page

Phase Contrast Microscopy (PCM) Fiber Results

A281048; 4650 Broadway, Sherman Ave. - Garage Pipe Insulation / Prp.

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|-----|
| 12 | 36 | 03/13/09 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |

Location: Field Blank

Footnotes: 1

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By: NIOSH 7400(A) Method, Issue #2, 8/15/94; Using an Olympus, Model CHS PCM microscope, Serial #0A0076; Analyzed by: Kareem Merain

Limit of Detection= 5.3 fibers /100 fields or 7 fibers/mm²; Blank analysis are reported when available, however are not used to adjust results of associated samples in this report. This report reflects ONI, Y to the sample analysis expressed as fibers/cc out of

Filter area: ND=No fibers observed; NA= Not Analyzed; Wilson-Blickert particle field area = 0.00785 mm²; TWA = 8 hr; TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance

Test)- Calculated as a type II/ed UCL to determine 95% certainty of compliance with the 0.01 fibers/cc standard; Estimated RSD: Inertlab S=0.605, Inertlab S=0.45, (NY ELAP Lab 1486), ABHA Lab # 102843)

Reviewed By:  _____

END OF REPORT



Date Analyzed: 3/14/2009



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

March 15, 2009

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 209032207
P.O. #A281048
A281048: 4650 Broadway, Sherman Ave.; Garage Pipe Insulation; Prep

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Saturday, March 14, 2009, for a 24 hour turnaround:

37, 38, 39, 40, 41, 42, 43

The 7 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A261048; 4650 Broadway, Sherman Ave.; Garage Pipe Insulation; Prep

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|--|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 01 | 37 | 03/14/09 | 7 | 170 | 1190 | 100 | 6.5 | 8.26 | 0.003 | |
| Location: Garage, End Of Ramp At The Critical Barrier | | | | | | | | | | |
| 02 | 38 | 03/14/09 | 7 | 169 | 1183 | 100 | 5 | 6.37 | < 0.002 | |
| Location: Garage, Next To Personal Decon | | | | | | | | | | |
| 03 | 39 | 03/14/09 | 7 | 168 | 1176 | 100 | 3 | 3.82 | < 0.002 | |
| Location: Garage, Next To The Waste Decon | | | | | | | | | | |
| 04 | 40 | 03/14/09 | 7 | 167 | 1169 | 100 | 3 | 3.82 | < 0.002 | |
| Location: Garage, Opposite Waste Decon Of Critical Barrier | | | | | | | | | | |
| 05 | 41 | 03/14/09 | 7 | 166 | 1162 | 100 | 4 | 5.10 | < 0.002 | |
| Location: Garage, At The Parking Number 102 | | | | | | | | | | |
| 06 | 42 | 03/14/09 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |
| 07 | 43 | 03/14/09 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: 1 |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus, Model CH5 PCM microscope, Serial #0A0076; Analyzed by: Kareem Morales
 Limit of Detection= 3.5 fibers /100 fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of generated samples in this report. This report reflects ONLY to the sample analysis expressed as fibers/cc and not fiber area. ND=No fibers observed; NA= Not Analyzed; Walton-Beckett graticule field area = 0.00785 mm². TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance Test)- Calculated at a one sided UCL to determine 95% certainty of compliance with the 0.01 fiber/cc standard. Estimated RSD: IntraLab Sr=0.45, InterLab Sr=0.45, (NY ELAP Lab 1480, AIHA Lab # 102843) Date Analyzed: 3/15/2009.

Reviewed By:  _____

END OF REPORT



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

March 16, 2009

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 209032208
P.O. #A281048
A281048; 4650 Broadway, Sherman Ave., Garage Pipe Insulation (During) (Report Amended
3/16/2009)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Saturday, March 14, 2009, for a 24 hour turnaround:

1, 2, 3, 4, 5, 6, 7, 8

The 8 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A281048: 4650 Broadway, Sherman Ave., Garage Pipe Insulation (During) (Report Amended 3/16/2009)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (liters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|---|-----------------|----------------|-------------------------|-----------------|-----------------------|--------|--------|---|--------------------------|--------------|
| 01 | 1 | 03/14/09 | 6 | 330 | 1980 | 100 | 6 | 7.54 | 0.001 | |
| Location: Garage, End Of Ramp At The Critical Barrier | | | | | | | | | | |
| 02 | 2 | 03/14/09 | 6 | 329 | 1974 | 100 | 6 | 10.19 | 0.002 | |
| Location: Inside Personal Decon | | | | | | | | | | |
| 03 | 3 | 03/14/09 | 6 | 328 | 1968 | 100 | 10 | 12.74 | 0.002 | |
| Location: Inside Waste Decon | | | | | | | | | | |
| 04 | 4 | 03/14/09 | 6 | 327 | 1962 | 100 | 4 | 5.10 | < 0.001 | |
| Location: Garage, Opposite Personal Decon | | | | | | | | | | |
| 05 | 5 | 03/14/09 | 6 | 326 | 1956 | 100 | 3.5 | 4.46 | < 0.001 | |
| Location: Garage, Parking Number 102 Next To Critical Barrier | | | | | | | | | | |
| 06 | 6 | 03/14/09 | 6 | 325 | 1950 | 100 | 5.5 | 7.01 | 0.001 | |
| Location: Outside Building At The Negative Air Exhaust | | | | | | | | | | |
| 07 | 7 | 03/14/09 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: f |
| Location: Field Blank | | | | | | | | | | |
| 08 | 8 | 03/14/09 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | Footnotes: f |
| Location: Field Blank | | | | | | | | | | |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/13/94. Using an Olympus Model CTS PCM microscope, Serial #0A0076. Analyzed by: Karcom Morales. Date Analyzed: 3/15/2009.
 Limit of Detection - 5.5 fibers (100) fields or 7 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report reflects ONLY the sample analysis expressed as fibers/cc and of fiber area. ND=No fibers observed; N/A= Not Analyzed; Wilson-Beckett particle field area = 0.00785 mm²; TWA = 8 Hr TWA calculation assumes 8-hr exposure for remainder of 8 hr period not sampled. Upper 95% Confidence Limit (Employer Compliance Test) - Calculated as a one sided UCL to determine 94% certainty of compliance with the 0.01 fiber/cc standard. Estimated RSD: Interlab S=0.45, (NY ELAP Lab 11480, ABMA Lab # 102843)

UK for KM

Reviewed By: *Karcom Morales* _____ END OF REPORT _____



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10018

TEL: (212) 679-8800 • FAX: (212) 679-8302

March 11, 2009

CNS Management Corporation
Attn: Charles Powers
500 W. Old Country Road
Suite 309
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 20903032#
P.O. #628104#
A20104# - 4650 Broadway, Sherman Ave / Garage Pipe Insulation (Dur)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Monday, March 16, 2009, for a 24 hour turnaround:

8, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22

The 14 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method T403, Issue #2, 8/15/04. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cm² of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates the opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Boehm
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

AJ201648: 4525 Broadway, Sherman Ave / Garage Pipe Insulation (Dirt)

| AmesSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (Boots) | Fibers | Fibers/cm ² (Boots/cm ²) | Fibers Conc. (Fibers/cc) |
|--|-----------------|----------------|------------------------|----------------|----------------------|--------|---|--------------------------|
| 01 | 0 | 03/18/08 | 0 | 263 | 1580 | 100 | 0.37 | < 0.002 |
| Location: Garage, End Of Ramp At The Critical Barrier | | | | | | | | |
| 02 | 10 | 03/18/08 | 0 | 264 | 1584 | 100 | 0.00 | 0.002 |
| Location: Inside Perimeter Doors | | | | | | | | |
| 03 | 11 | 03/18/08 | 0 | 263 | 1278 | 100 | 0.37 | < 0.002 |
| Location: Inside Window Doors | | | | | | | | |
| 04 | 12 | 03/18/08 | 0 | 263 | 922 | 100 | 1.04 | 0.002 |
| Location: Garage, Opposite Perimeter Doors | | | | | | | | |
| 05 | 13 | 03/18/08 | 0 | 261 | 1000 | 100 | 2.30 | < 0.002 |
| Location: Garage, At The Parking Number 102 Next To C. Barrier | | | | | | | | |
| 06 | 14 | 03/18/08 | 0 | 258 | 1000 | 100 | 3.82 | < 0.002 |
| Location: Outside Building At The Negative Air Exhaust | | | | | | | | |
| 07 | 15 | 03/18/08 | 0 | 248 | 1970 | 100 | 0.02 | 0.002 |
| Location: Garage, End Of Ramp At The Critical Barrier | | | | | | | | |
| 08 | 16 | 03/18/08 | 0 | 269 | 1470 | 100 | 10.19 | 0.002 |
| Location: Inside Perimeter Doors | | | | | | | | |
| 09 | 17 | 03/18/08 | 0 | 268 | 1470 | 100 | 0.32 | 0.002 |
| Location: Inside Window Doors | | | | | | | | |
| 10 | 18 | 03/18/08 | 0 | 268 | 1970 | 100 | 10.19 | 0.002 |
| Location: Garage, Opposite Perimeter Doors | | | | | | | | |
| 11 | 19 | 03/18/08 | 0 | 248 | 1970 | 100 | 6.19 | < 0.002 |
| Location: Garage, At The Parking Number 102 Next To C. Barrier | | | | | | | | |



AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

March 19, 2009

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 209032469
P.O. #A281048
A281048; 4650 Broadway, Sherman Ave, Garage Pipe Insulation (Durings) (Report Amended
3/19/2009)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Tuesday, March 17, 2009, for a 24 hour turnaround:

23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36

The 14 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/sq mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

Client Name: CMS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A211048: 4650 Broadway, Sherman Ave, Garage Fibre Insulation (Dunnig) (Report Amended 3/18/2009)

| AmuSci Sample # | Client Sample # | Date Collected | Fiber Type (Microin.) | Duration (min.) | Air Filtered (bars) | Pushes | Fibers | Fiber Density (Fibers/cm ²) | Fibers Count (Fibers/cm ²) | TWA |
|--|-----------------|----------------|-----------------------|-----------------|---------------------|--------|--------|---|--|-----|
| 01 | 21 | 02/17/09 | 0 | 200 | 1000 | 100 | 0 | 0.00 | 0.000 | |
| Location: Garage End Of Ramp At The Office Garage | | | | | | | | | | |
| 02 | 24 | 02/17/09 | 0 | 210 | 1074 | 100 | 0 | 0.00 | 0.000 | |
| Location: Inside Penthouse Deck | | | | | | | | | | |
| 03 | 25 | 02/17/09 | 0 | 210 | 1038 | 600 | 4.5 | 5.75 | 4.000 | |
| Location: Inside Office Deck | | | | | | | | | | |
| 04 | 26 | 02/17/09 | 0 | 217 | 990 | 600 | 0 | 2.50 | 0.000 | |
| Location: Garage Opposite Penthouse Deck | | | | | | | | | | |
| 05 | 27 | 02/17/09 | 0 | 215 | 1008 | 600 | 0 | 3.00 | 0.000 | |
| Location: Garage At The Parking Number 100 Next To C. Ramp | | | | | | | | | | |
| 06 | 28 | 02/17/09 | 0 | 219 | 1008 | 600 | 0 | 1.10 | 0.000 | |
| Location: Office Building At The Negative Air Exhaust | | | | | | | | | | |
| 07 | 29 | 02/17/09 | 0 | 240 | 1140 | 100 | 0 | 0.00 | 0.000 | |
| Location: Garage End Of Ramp At The Office Ramp | | | | | | | | | | |
| 08 | 30 | 02/17/09 | 0 | 240 | 1440 | 100 | 0 | 1.64 | 0.000 | |
| Location: Inside Penthouse Deck | | | | | | | | | | |
| 09 | 31 | 02/17/09 | 0 | 240 | 1440 | 600 | 0 | 6.37 | 4.000 | |
| Location: Inside Office Deck | | | | | | | | | | |
| 10 | 32 | 02/17/09 | 0 | 240 | 1440 | 600 | 0 | 5.10 | 4.000 | |
| Location: Garage Opposite Penthouse Deck | | | | | | | | | | |
| 11 | 33 | 02/17/09 | 0 | 240 | 1440 | 600 | 0.8 | 7.01 | 0.000 | |
| Location: Garage At The Parking Number 100 Next To C. Ramp | | | | | | | | | | |
| 12 | 34 | 02/17/09 | 0 | 240 | 1440 | 600 | 0 | 1.10 | 0.000 | |
| Location: Office Building At The Negative Air Exhaust | | | | | | | | | | |

See following pages for test maps

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

A281048: 4650 Broadway, Sherman Ave, Garage Pipe Insulation (Durings) (Report Amended 3/19/2009)

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (filters) | Fields | Fibers | Fiber Density (Fibers/min ²) | Fibers Conc. (Fibers/cc) | TWA |
|-----------------------|-----------------|----------------|-------------------------|-----------------|------------------------|--------|--------|--|--------------------------|--------------|
| 13 | 35 | 03/17/09 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |
| Location: Field Blank | | | | | | | | | | |
| 14 | 36 | 03/17/09 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |
| Location: Field Blank | | | | | | | | | | |
| | | | | | | | | | | Footnotes: 1 |
| | | | | | | | | | | Footnotes: 1 |

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Olympus Model CH5 PCM microscope, Serial #CNA0976, Analyzed by Kenneth R. Harrell. Date Analyzed: 3/18/2009.
 Limit of Detection: 5.5 fibers /100 fields or 7 fibers/wash. Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc (not of fiber area; ND=No fibers observed; NA= Not Analyzed; Walton-Beckett grade); field area = 0.00795 mm²; TWA = 8 Hr TWA calculation assumes 8 hrs exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employee Compliance Test) - Calculated as a one sided 95% to determine 95% certainty of compliance with the 0.01 fibers/cc standard. Estimated RSD: Journal Ser# 403, Interlab Ser# 0.45, (NY ELAP Lab # 11480, ABIA Lab # 102847)

Reviewed By: Kashm _____ END OF REPORT

JK/DRKH

March 17, 2000

CNS Management Corporation
Attn: Charles Powers
800 W. Old Country Road
Suite 300
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 200002470
P.D. #A281048
A281048: 4650 Broadway, Sherman Ave., Garage Pipe Insulation, Phase I, Clearance

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Tuesday, March 17, 2000, for an immediate turnaround:

1, 2, 3, 4, 5, 6, 7

The 7 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cc m³ of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci-certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandate that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,



Marvin E. Brothers
Operations Supervisor



AMERISCI

AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-9392

March 18, 2009

CNS Management Corporation
Attn: Charles Powers
500 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 200003601
P.O. #A281048
A281048: #660 Broadway, Sherman Ave. Garage Pipe Insulation (Pres)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, March 18, 2009, for a 24 hour turnaround:

1, 2, 3, 4, 5, 6, 7

The 7 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 6/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/m³ of fiber area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandates that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates the opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,



Marvin E. Brothers
Operations Supervisor



AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-0500 • FAX: (212) 679-0502

March 18, 2009

CNS Management Corporation
Attn: Charles Powers
550 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 200002602
P.O. #A281048
A281048, 4650 Broadway, Sherman Ave, Garage Pipe Insulation (During)

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Wednesday, March 18, 2009, for a 24 hour turnaround:

1, 2, 3, 4, 5

The 5 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/04. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cc mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandate that this report must not be reproduced, except in full, without the approval of the laboratory.

AmeriSci appreciates the opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

Marvin E. Brothers
Operations Supervisor

Client Name: CNS Management Corporation

Phase Contrast Microscopy (PCM) Fiber Results

AC261048: 4000 Broadway, Sherman Ave. Garage Pipe Insulation (During)

| Analysis Sample # | Client Sample # | Date Collected | Flow Rate (g/min) | Duration (min) | Air Filtered (liters) | Fiber Count | Fibers | Fiber Density (Fibers/cm ³) | Fiber Count (Fibers/cm ³) | TWA |
|--|-----------------|----------------|-------------------|----------------|-----------------------|-------------|--------|---|---------------------------------------|-----|
| 01 | 1 | 03/16/09 | 10 | 75 | 750 | 100 | 0 | 0.00 | < 0.004 | |
| Location: Garage Vent To Inside Room Area | | | | | | | | | | |
| 02 | 2 | 03/16/09 | 10 | 75 | 750 | 100 | 0 | 0.00 | < 0.004 | |
| Location: Inside Perimeter Ductwork | | | | | | | | | | |
| 03 | 3 | 03/16/09 | 10 | 75 | 750 | 100 | 0 | 0.00 | < 0.004 | |
| Location: Outside Building Vent To Outside | | | | | | | | | | |
| 04 | 4 | 03/16/09 | 0 | 0 | 0 | 100 | 0.0 | 0.04 | Exceedance: 8 | |
| Location: First Floor | | | | | | | | | | |
| 05 | 5 | 03/16/09 | 0 | 0 | 0 | 100 | 0.0 | 0.04 | Exceedance: 8 | |
| Location: First Floor | | | | | | | | | | |

Reporting Notes:

(1) Fibers could be collected for analysis (in health) with an air volume

of approximately 100 liters (3.5 cu ft) or more. For fibers collected in a volume of less than 100 liters, the results are reported with a note that the results are based on a volume of approximately 100 liters. The results are reported with a note that the results are based on a volume of approximately 100 liters. The results are reported with a note that the results are based on a volume of approximately 100 liters.

KAH by MB

March 23, 2009

CNS Management Corporation
Attn: Charles Powers
500 W. Old Country Road
Suite 308
Hicksville, NY 11801

Re: CNS Management Corporation
Job Number 200032753
P.O. #A281048
A281048; 4650 Berrisley, Sherman Ave. - Garage Pipe Insulation (PII) (Report Amend)
3/23/2009

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Thursday, March 19, 2009, for a 24 hour turnaround:

A, B, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19

The 12 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/10/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cm of fiber area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,



Maron E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A28154B, 4850 Broadway, Sherman Ave. - Garage Pipe Insulation (Pip) (Report Amended 3/23/2009)

| Ames/Scl Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min.) | All Filament (Items) | Fibers | Fiber Density (Fibers/cm ²) | Fiber Count (Fibers/cm ²) | TWA |
|---|-----------------|----------------|------------------------|-----------------|----------------------|--------|---|---------------------------------------|---------------|
| 01 | 8 | 03/18/09 | 8 | 200 | 1481 | 118 | 17.02 | 0.004 | |
| Location: Pip - Garage, At The Deck Near To Electrical Panel | | | | | | | | | |
| 02 | 9 | 03/18/09 | 8 | 210 | 1614 | 21 | 26.18 | 0.006 | |
| Location: Pip - Garage, End Of Ramp Near To Ceiling Beam | | | | | | | | | |
| 03 | 10 | 03/18/09 | 8 | 216 | 928 | 68 | 19.87 | 0.006 | |
| Location: Pip - Garage, Near To Personal Desk | | | | | | | | | |
| 04 | 11 | 03/18/09 | 8 | 217 | 1623 | 41 | 30.38 | 0.012 | |
| Location: Pip - Garage, Near To Vehicle Desk | | | | | | | | | |
| 05 | 12 | 03/18/09 | 8 | 216 | 1028 | 18 | 23.83 | 0.005 | |
| Location: Pip - Garage, At The Ceiling Beam Near To Personal Desk | | | | | | | | | |
| 06 | 13 | 03/18/09 | 8 | 240 | 1440 | 11 | 19.01 | 0.004 | |
| Location: Pip - Garage, At The Deck Near To Electrical Panel | | | | | | | | | |
| 07 | 14 | 03/18/09 | 8 | 240 | 1440 | 42 | 15.29 | 0.004 | |
| Location: Pip - Garage, End Of Ramp Near To Ceiling Beam | | | | | | | | | |
| 08 | 15 | 03/18/09 | 8 | 246 | 1440 | 8 | 11.48 | 0.003 | |
| Location: Pip - Garage, Near To Personal Desk | | | | | | | | | |
| 09 | 16 | 03/18/09 | 8 | 240 | 1440 | 9 | 19.19 | 0.005 | |
| Location: Pip - Garage, Near To Vehicle Desk | | | | | | | | | |
| 10 | 17 | 03/18/09 | 8 | 240 | 1440 | 8.8 | 10.31 | 0.003 | |
| Location: Pip - Garage, At The Ceiling Beam Near To Personal Desk | | | | | | | | | |
| 11 | 18 | 03/18/09 | 8 | 0 | 0 | 0.3 | 0.00 | | Precaution: 1 |
| Location: Field Site | | | | | | | | | |
| 12 | 19 | 03/18/09 | 8 | 0 | 0 | 0.8 | 0.00 | | Precaution: 1 |
| Location: Field Site | | | | | | | | | |

Reporting Name:

(1) Fibers count be calculated by samples for (study) with no all volume by PCM (see A) results from 2) or 3) (only in cases where 100% of all volume had occurred, including Panel in Items 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100, 101, 102, 103, 104, 105, 106, 107, 108, 109, 110, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124, 125, 126, 127, 128, 129, 130, 131, 132, 133, 134, 135, 136, 137, 138, 139, 140, 141, 142, 143, 144, 145, 146, 147, 148, 149, 150, 151, 152, 153, 154, 155, 156, 157, 158, 159, 160, 161, 162, 163, 164, 165, 166, 167, 168, 169, 170, 171, 172, 173, 174, 175, 176, 177, 178, 179, 180, 181, 182, 183, 184, 185, 186, 187, 188, 189, 190, 191, 192, 193, 194, 195, 196, 197, 198, 199, 200, 201, 202, 203, 204, 205, 206, 207, 208, 209, 210, 211, 212, 213, 214, 215, 216, 217, 218, 219, 220, 221, 222, 223, 224, 225, 226, 227, 228, 229, 230, 231, 232, 233, 234, 235, 236, 237, 238, 239, 240, 241, 242, 243, 244, 245, 246, 247, 248, 249, 250, 251, 252, 253, 254, 255, 256, 257, 258, 259, 260, 261, 262, 263, 264, 265, 266, 267, 268, 269, 270, 271, 272, 273, 274, 275, 276, 277, 278, 279, 280, 281, 282, 283, 284, 285, 286, 287, 288, 289, 290, 291, 292, 293, 294, 295, 296, 297, 298, 299, 300, 301, 302, 303, 304, 305, 306, 307, 308, 309, 310, 311, 312, 313, 314, 315, 316, 317, 318, 319, 320, 321, 322, 323, 324, 325, 326, 327, 328, 329, 330, 331, 332, 333, 334, 335, 336, 337, 338, 339, 340, 341, 342, 343, 344, 345, 346, 347, 348, 349, 350, 351, 352, 353, 354, 355, 356, 357, 358, 359, 360, 361, 362, 363, 364, 365, 366, 367, 368, 369, 370, 371, 372, 373, 374, 375, 376, 377, 378, 379, 380, 381, 382, 383, 384, 385, 386, 387, 388, 389, 390, 391, 392, 393, 394, 395, 396, 397, 398, 399, 400, 401, 402, 403, 404, 405, 406, 407, 408, 409, 410, 411, 412, 413, 414, 415, 416, 417, 418, 419, 420, 421, 422, 423, 424, 425, 426, 427, 428, 429, 430, 431, 432, 433, 434, 435, 436, 437, 438, 439, 440, 441, 442, 443, 444, 445, 446, 447, 448, 449, 450, 451, 452, 453, 454, 455, 456, 457, 458, 459, 460, 461, 462, 463, 464, 465, 466, 467, 468, 469, 470, 471, 472, 473, 474, 475, 476, 477, 478, 479, 480, 481, 482, 483, 484, 485, 486, 487, 488, 489, 490, 491, 492, 493, 494, 495, 496, 497, 498, 499, 500, 501, 502, 503, 504, 505, 506, 507, 508, 509, 510, 511, 512, 513, 514, 515, 516, 517, 518, 519, 520, 521, 522, 523, 524, 525, 526, 527, 528, 529, 530, 531, 532, 533, 534, 535, 536, 537, 538, 539, 540, 541, 542, 543, 544, 545, 546, 547, 548, 549, 550, 551, 552, 553, 554, 555, 556, 557, 558, 559, 560, 561, 562, 563, 564, 565, 566, 567, 568, 569, 570, 571, 572, 573, 574, 575, 576, 577, 578, 579, 580, 581, 582, 583, 584, 585, 586, 587, 588, 589, 590, 591, 592, 593, 594, 595, 596, 597, 598, 599, 600, 601, 602, 603, 604, 605, 606, 607, 608, 609, 610, 611, 612, 613, 614, 615, 616, 617, 618, 619, 620, 621, 622, 623, 624, 625, 626, 627, 628, 629, 630, 631, 632, 633, 634, 635, 636, 637, 638, 639, 640, 641, 642, 643, 644, 645, 646, 647, 648, 649, 650, 651, 652, 653, 654, 655, 656, 657, 658, 659, 660, 661, 662, 663, 664, 665, 666, 667, 668, 669, 670, 671, 672, 673, 674, 675, 676, 677, 678, 679, 680, 681, 682, 683, 684, 685, 686, 687, 688, 689, 690, 691, 692, 693, 694, 695, 696, 697, 698, 699, 700, 701, 702, 703, 704, 705, 706, 707, 708, 709, 710, 711, 712, 713, 714, 715, 716, 717, 718, 719, 720, 721, 722, 723, 724, 725, 726, 727, 728, 729, 730, 731, 732, 733, 734, 735, 736, 737, 738, 739, 740, 741, 742, 743, 744, 745, 746, 747, 748, 749, 750, 751, 752, 753, 754, 755, 756, 757, 758, 759, 760, 761, 762, 763, 764, 765, 766, 767, 768, 769, 770, 771, 772, 773, 774, 775, 776, 777, 778, 779, 780, 781, 782, 783, 784, 785, 786, 787, 788, 789, 790, 791, 792, 793, 794, 795, 796, 797, 798, 799, 800, 801, 802, 803, 804, 805, 806, 807, 808, 809, 810, 811, 812, 813, 814, 815, 816, 817, 818, 819, 820, 821, 822, 823, 824, 825, 826, 827, 828, 829, 830, 831, 832, 833, 834, 835, 836, 837, 838, 839, 840, 841, 842, 843, 844, 845, 846, 847, 848, 849, 850, 851, 852, 853, 854, 855, 856, 857, 858, 859, 860, 861, 862, 863, 864, 865, 866, 867, 868, 869, 870, 871, 872, 873, 874, 875, 876, 877, 878, 879, 880, 881, 882, 883, 884, 885, 886, 887, 888, 889, 890, 891, 892, 893, 894, 895, 896, 897, 898, 899, 900, 901, 902, 903, 904, 905, 906, 907, 908, 909, 910, 911, 912, 913, 914, 915, 916, 917, 918, 919, 920, 921, 922, 923, 924, 925, 926, 927, 928, 929, 930, 931, 932, 933, 934, 935, 936, 937, 938, 939, 940, 941, 942, 943, 944, 945, 946, 947, 948, 949, 950, 951, 952, 953, 954, 955, 956, 957, 958, 959, 960, 961, 962, 963, 964, 965, 966, 967, 968, 969, 970, 971, 972, 973, 974, 975, 976, 977, 978, 979, 980, 981, 982, 983, 984, 985, 986, 987, 988, 989, 990, 991, 992, 993, 994, 995, 996, 997, 998, 999, 1000)

Reported by: *[Signature]*

PT by WB

03/18/09



AMERISCI

AmeriSci New York

117 EAST 30TH STREET
NEW YORK, NY 10016

TEL: (212) 679-8500 • FAX: (212) 679-9552

March 21, 2009

CNS Management Corporation
Attn: Charles Powers
500 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 209032800
P.O. #A281048
6281048, 4830 Broadway, Sherman Ave., Garage Pipe Insulation; Pgr

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Friday, March 20, 2009, for a 24 hour turnaround:

20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31

The 12 samples contained in Air Cassettes were shipped to AmeriSci via Hand Delivery. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 6/15/04. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within this report. The table attached represents a summary of the fiber count results.

This report relates ONLY to the sample analysis expressed as fibers/cc m³ of fiber area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is archived and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandate that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,



Martin E. Brothers
Operations Supervisor

Phase Contrast Microscopy (PCM) Fiber Results

A281048, 4550 Broadway, Sherrin Ave., Garage Pipe Installation, Pyp

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (Bar/min.) | Duration (min.) | As Filtered (liters) | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/ml) | TMAA |
|---|-----------------|----------------|----------------------|-----------------|----------------------|--------|---|--------------------------|------|
| 01 | 20 | 03/20/09 | 8 | 342 | 1424 | 18 | 24.28 | 0.008 | |
| Location: Garage, At The Down Head To Panel Bus | | | | | | | | | |
| 02 | 21 | 03/20/09 | 8 | 343 | 1438 | 18 | 25.28 | 0.009 | |
| Location: Garage, End Of Run At The Critical Items | | | | | | | | | |
| 03 | 22 | 03/20/09 | 8 | 343 | 1432 | 12 | 18.28 | 0.004 | |
| Location: Garage, Near To Personnel Decou | | | | | | | | | |
| 04 | 22 | 03/20/09 | 8 | 341 | 1448 | 11 | 14.01 | 0.004 | |
| Location: Garage, Near To Waste Decou | | | | | | | | | |
| 05 | 24 | 03/20/09 | 8 | 349 | 1440 | 12 | 15.28 | 0.004 | |
| Location: Garage, At The Critical Items Near To Bus Panel | | | | | | | | | |
| 06 | 25 | 03/20/09 | 8 | 348 | 1436 | 14.8 | 18.41 | 0.005 | |
| Location: Garage, At The Down Head To Panel Bus | | | | | | | | | |
| 07 | 23 | 03/20/09 | 8 | 348 | 1438 | 16 | 17.81 | 0.009 | |
| Location: Garage, End Of Run At The Critical Items | | | | | | | | | |
| 08 | 27 | 03/20/09 | 8 | 345 | 1432 | 17 | 21.88 | 0.008 | |
| Location: Garage, Near To Personnel Decou | | | | | | | | | |
| 09 | 28 | 03/20/09 | 8 | 349 | 1438 | 8 | 18.38 | 0.003 | |
| Location: Garage, Near To Waste Decou | | | | | | | | | |
| 10 | 29 | 03/20/09 | 8 | 345 | 1438 | 15 | 18.74 | 0.003 | |
| Location: Garage, At The Critical Items Near To Panel Bus | | | | | | | | | |
| 11 | 29 | 03/20/09 | 8 | 6 | 0 | 0.8 | 2.64 | | |
| Location: Floor Blank | | | | | | | | | |

Feet/Inch: 1

Phase Contrast Microscopy (PCM) Fiber Results

A281048; 4650 Broadway, Sherman Ave.; Garage Pipe Insulation; Prp

| AmeriSci Sample # | Client Sample # | Date Collected | Flow Rate (liters/min.) | Duration (min.) | Air Filtered (filters) | Fields | Fibers | Fiber Density (Fibers/mm ²) | Fibers Conc. (Fibers/cc) | TWA |
|-------------------|-----------------|----------------|-------------------------|-----------------|------------------------|--------|--------|---|--------------------------|-----|
| 12 | 31 | 03/20/09 | 0 | 0 | 0 | 100 | 0.5 | 0.64 | | |

Location: Field Blank

Footnotes: f

Reporting Notes:

(1) Fibers/cc cannot be calculated for samples (or blanks) with no air volume.

By NIOSH 7400(A) Method, Issue #2, 8/15/94. Using an Oxytop, Model CTS PCM microscope, Serial #0A0076. Analyzed by: Katsum Momin. Date Analyzed: 3/21/2009.
 Limit of Detection= 5.3 fibers /100 fields or 2 fibers/mm². Blank analyses are reported when available, however are not used to adjust results of associated samples in this report. This report relates ONLY to the sample analysis expressed as fibers/cc mm of fiber area. ~~ND= No fibers observed. NA= Not Analyzed. Wilson-Bokken granulic field area = 0.00785 mm². TWA = 8 Hr TWA calculation assumes zero exposure for remainder of 8 hr period not sampled. Upper 95% Confidence limit (Employers Compliance Test)- Calculated at 95% confidence level. 95% variability of compliance with the 0.01 fibers/cc standard. Estimated MSD - Intractab 5=0.405, Intractab 5=0.45, (NY ELAP Lab 11480, ADHA Lab # 102843)~~

Reviewed By:  _____
 END OF REPORT

The logo for AmeriSci, featuring the company name in a stylized font with a swoosh above and below the letters.

AmeriSci New York

117 EAST 30TH STREET

NEW YORK, NY 10018

TEL: (212) 679-8800 • FAX: (212) 679-9352

March 24, 2009

CNS Management Corporation
Attn: Charles Powers
500 W. Old Country Road
Suite 308
Hicksville, NY 11801

RE: CNS Management Corporation
Job Number 200003126
P.O. #A281048
A281048; 4650 Broadway, Sherman Ave.; Garage Pipe Insulation; Drying

Dear Charles Powers:

Enclosed are the results for PCM asbestos analysis of the following CNS Management Corporation samples received at AmeriSci on Monday, March 23, 2009, for a 24 hour turnaround:

32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45

The 14 samples contained in Air Cassettes were stopped to AmeriSci via Hand Delivered. These samples were prepared according to PCM methodology as specified in NIOSH Method 7400, Issue #2, 8/15/94. The counting rules used are described in previous versions of this method as "A" rules unless otherwise noted within the report. The table attached represents a summary of the 51ar count results.

This report relates ONLY to the sample analysis expressed as fibers/cc mm of filter area. AmeriSci assumes no responsibility for customer supplied data such as "sample location" or "air volume sampled". This report must not be used to claim product endorsement by AmeriSci or any AmeriSci certifying agency. Complete analytical documentation is provided and available upon written request. The National Institute of Standards and Technology Accreditation requirements, mandate that this report must not be reproduced, except in full without the approval of the laboratory.

AmeriSci appreciates this opportunity to serve your organization. Please contact us for any further assistance or with any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Mervin Brothers".

Mervin E. Brothers
Operations Supervisor

7461

Phase Contrast Microscopy (PCM) Fiber Results

Address: 4250 Broadway, Sherman Ave., Garage Pipe Installation, During

| AmesSol Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Diameter (mm) | Air Filtered (bars) | Fibers | Fiber Density (Fibers/cm ²) | Fiber Count (Estimated) | YMA |
|--|-----------------|----------------|------------------------|---------------|---------------------|--------|---|-------------------------|-------|
| 01 | 32 | 03/23/09 | 0 | 260 | 1800 | 100 | 1.50 | 1,500 | 0.002 |
| Location: Garage, End Of Ramp At The Ceiling Beam | | | | | | | | | |
| 02 | 33 | 03/23/09 | 0 | 220 | 1500 | 100 | 12.74 | 1,274 | 0.003 |
| Location: Inside Perimeter Duct | | | | | | | | | |
| 03 | 34 | 03/23/09 | 0 | 220 | 1500 | 100 | 10.18 | 1,018 | 0.003 |
| Location: Inside Waste Duct | | | | | | | | | |
| 04 | 35 | 03/23/09 | 0 | 220 | 1500 | 100 | 7.84 | 784 | 0.003 |
| Location: Garage, Opposite Perimeter Duct | | | | | | | | | |
| 05 | 36 | 03/23/09 | 0 | 250 | 1300 | 100 | 8.37 | 837 | 0.002 |
| Location: Garage, At The Ceiling Beam Next To E. Panel | | | | | | | | | |
| 06 | 37 | 03/23/09 | 0 | 200 | 1200 | 100 | 8.44 | 844 | 0.002 |
| Location: Outside Building At The Negative Exhaust | | | | | | | | | |
| 07 | 38 | 03/23/09 | 0 | 180 | 1400 | 100 | 11.40 | 1,140 | 0.003 |
| Location: Garage, End Of Ramp At The Ceiling Beam | | | | | | | | | |
| 08 | 39 | 03/23/09 | 0 | 240 | 1400 | 100 | 13.74 | 1,374 | 0.003 |
| Location: Inside Perimeter Duct | | | | | | | | | |
| 09 | 40 | 03/23/09 | 0 | 340 | 1000 | 100 | 8.92 | 892 | 0.002 |
| Location: Inside Waste Duct | | | | | | | | | |
| 10 | 41 | 03/23/09 | 0 | 340 | 1000 | 100 | 10.18 | 1,018 | 0.003 |
| Location: Garage, Opposite Perimeter Duct | | | | | | | | | |
| 11 | 42 | 03/23/09 | 0 | 300 | 1400 | 100 | 8.37 | 837 | 0.002 |
| Location: Garage, At The Ceiling Beam Next To E. Panel | | | | | | | | | |

Phase Contrast Microscopy (PCM) Fiber Results

A381048: 4800 Broadway, Sherman Ave., Garage Pipe Insulation, During

| AmesCo Sample # | Client Sample # | Date Collected | Flow Rate (liters/min) | Duration (min) | Air Filtered (heets) | Fibers | Fiber Density (Fibers/cm ²) | Fiber Count (Fibers/cm ²) | YMA |
|---|-----------------|----------------|------------------------|----------------|----------------------|--------|---|---------------------------------------|---------------|
| 12 | 42 | 02/02/09 | 0 | 30 | 100 | 1 | 0.37 | 0.002 | 19/08 |
| Location: Outside Building At The Program Exhaust | | | | | | | | | |
| 13 | 43 | 02/02/09 | 0 | 0 | 0 | 0.8 | 3.84 | | Footcandle: 1 |
| Location: First Floor | | | | | | | | | |
| 14 | 44 | 02/02/09 | 0 | 0 | 0 | 0.8 | 0.84 | | Footcandle: 1 |
| Location: First Floor | | | | | | | | | |

Reporting Notes:

(1) Fibers cannot be collected for samples for analysis with no air volume.

By Order: Tom A. Mahan, Issue 02, 01/14/09, Using as Directed, Model 015/014 parameters, being retained, analysis: Paul N. Thomas

Date Analyzed: 02/02/09

Site of Collection: 4200 Broadway, Sherman Ave., Garage Pipe Insulation, During. This report contains only the data which was reported in this report. The report contains only the data which was reported in this report. This report contains only the data which was reported in this report. This report contains only the data which was reported in this report.

Report Generated by: *[Signature]* Date: 02/02/09

[Signature]